

**SURVEY OF RANGES OF  
COMPONENT RELIABILITY DATA  
FOR USE IN  
PROBABILISTIC SAFETY ASSESSMENT**



A TECHNICAL DOCUMENT ISSUED BY THE  
INTERNATIONAL ATOMIC ENERGY AGENCY, VIENNA, 1989

SURVEY OF RANGES OF COMPONENT RELIABILITY DATA  
FOR USE IN PROBABILISTIC SAFETY ASSESSMENT  
IAEA, VIENNA, 1989  
IAEA-TECDOC-508  
ISSN 1011-4289

Printed by the IAEA in Austria  
June 1989

PLEASE BE AWARE THAT  
ALL OF THE MISSING PAGES IN THIS DOCUMENT  
WERE ORIGINALLY BLANK

The IAEA does not normally maintain stocks of reports in this series.  
However, microfiche copies of these reports can be obtained from

INIS Clearinghouse  
International Atomic Energy Agency  
Wagramerstrasse 5  
P.O. Box 100  
A-1400 Vienna, Austria

Orders should be accompanied by prepayment of Austrian Schillings 100,—  
in the form of a cheque or in the form of IAEA microfiche service coupons  
which may be ordered separately from the INIS Clearinghouse.

## FOREWORD

Generic component reliability data are still widely used in probabilistic safety assessment (PSA), either to quantify component failure directly, or to serve as a prior in the updating process. In order to make generic component data widely available, the IAEA has compiled component reliability data from a number of literature sources in the IAEA Component Reliability Data Base. During compilation of the IAEA Data Base it was recognized that in some cases failure rates or probabilities for the same components and failure modes differ substantially, perhaps by up to two orders of magnitude. The component reliability data used in the PSA study could greatly influence the final result of the study. Comparison of the data from different sources could therefore yield some interesting insights. As the data have been derived from many sources, on the basis of differing assumptions, the clearest way of comparing data is to plot them on the same graph.

This document presents the ranges of rates or probabilities of component failure for selected components that are usually considered in PSA studies. It could also be used to compare particular data with the bulk of data found in the literature. No effort has been made to explain the differences in data. However, some of these differences can be explained by a knowledge of the source of the data. The sources are described in detail in the IAEA Data Base (see IAEA-TECDOC-478), and it is strongly suggested that this document be used together with the IAEA Data Base.

This document is intended to be used mainly by people who are knowledgeable in data analysis and the use of data in PSAs. The interpretation of data ranges without regard to the background information and assumptions from the original data source is strongly discouraged.

This report was prepared by the staff of the Reliability and Risk Assessment Section, Division of Nuclear Safety, under the programme on PSA. The principal investigator was Mr. Bojan Tomic. The entire report was reviewed by Mr. Luis Lederman.

## *EDITORIAL NOTE*

*In preparing this material for the press, staff of the International Atomic Energy Agency have mounted and paginated the original manuscripts and given some attention to presentation*

*The views expressed do not necessarily reflect those of the governments of the Member States or organizations under whose auspices the manuscripts were produced*

*The use in this book of particular designations of countries or territories does not imply any judgement by the publisher, the IAEA, as to the legal status of such countries or territories, of their authorities and institutions or of the delimitation of their boundaries*

*The mention of specific companies or of their products or brand names does not imply any endorsement or recommendation on the part of the IAEA*

## CONTENTS

1	INTRODUCTION	7
2	PURPOSE OF THE DATA RANGES OVERVIEW	8
3	LIMITATIONS OF THE DATA RANGES OVERVIEW	9
4	SELECTION OF DATA	10
4 1	Selection of component type and failure mode	10
4 2	Data sources selection	12
4 3	Operating mode selection	14
5	INPUT DATA PREPARATION	15
5 1	Treatment of demand related failures	15
6	USES OF THE DATA RANGES OVERVIEW	18
APPENDIX 1	DATA SOURCES AND RESPECTIVE CODING	19
APPENDIX 2	DATA GRAPHS AND TABLES	23

## 1. INTRODUCTION

The Data Ranges Overview is a follow-up activity to the compilation of the IAEA Component Reliability Data Base (published as IAEA-TECDOC-478, Component Reliability Data for Use in Probabilistic Safety Assessment, IAEA, Vienna, 1988). The IAEA Component Reliability Data Base as of October 1988 contains more than 1000 records (data points) on 420 component types, categorized into 100 component groups and derived from 21 literature sources.

Most of the data sources used for the IAEA Data Base are either probabilistic safety analysis (PSA) studies or sources that provided input for PSA studies. As all sources deal with more or less similar components, it was considered interesting to compare reliability parameters for the important components and failure modes.

The clearest way to compare data points is to plot them on the same graph. For meaningful comparison, separate graphs with data from different sources were made for each component type, failure mode, operating mode or type of environment (when applicable).

The level of resolution in data comparison is governed by two competing elements: the availability and the comparability of data. A higher degree of resolution in component type, failure mode, operating mode and environment type would result in fewer data points being available. Conversely, the requirement for a higher quantity of data usually results in inferior resolution, leading to the comparison of 'non-comparable' items. Establishing a balance between these two elements was one of the objectives in the Data Ranges Overview.

After component types, failure modes and operating modes were selected for the Data Ranges Overview, the appropriate records from the IAEA Reliability Data Base were stored in separate files and each file was then plotted. Finally, about 70 charts were plotted. Each of the charts is accompanied by the data table (in the same format as in the IAEA Component Reliability Data Base), where for the user's convenience a complete record form for each of the data points is reproduced.



## 2. PURPOSE OF THE DATA RANGES OVERVIEW

The IAEA Data Ranges Overview graphs are intended for comparing reliability data from a variety of sources for use in PSA studies.

The purpose of the Data Ranges Overview is to present in an easy-to-understand graphical form ranges of component reliability data for components having similar characteristics in terms of type, failure mode and operating mode. These graphs can also be useful in comparing reliability data from a particular source with the data found in the literature.

Another purpose of these graphs is to facilitate the assessment of the centre points as well as of the higher and lower bounds of the data found in the literature. On comparing a data set used with the ranges of data presented in the graphs, tendencies towards lower or higher values are easily identifiable. Whenever a plant model is available, sensitivity analysis using the extreme values depicted in the graphs can also be performed.

It is recognized that changes in the failure rate or failure probability of certain critical components lead to significant changes in the core melt frequency in PSA studies. In particular, when PSA results are used to show compliance with probabilistic safety criteria, confidence in the numerical results of the PSA study is essential. The component reliability data used should therefore be carefully evaluated.

### 3. LIMITATIONS OF THE DATA RANGES OVERVIEW

The basic limitation of the Data Ranges Overview is the lack of precise and standard definitions which would allow more strict comparison of data. Lack of precise definition is the problem encountered when generic data are used for specific analyses. Loose definitions of component boundaries, operating mode and environment, demand interval and operating and maintenance policy could strongly influence the failure rate.

Another characteristic of the Data Ranges Overview graphs is that different types of data are plotted on the same graph. Some of the sources provide point estimates as the mean value of a distribution; others provide medians; while some others recommend values without a formal distribution, terming them either best estimates or recommended values. Owing to the limited number of available data points, it was not possible to plot separately means, medians or best estimates. All these data are therefore plotted on the same graph and termed 'centre points'. The rationale for having all of them on the same graph is that, irrespectively of definition, centre points are used in point estimate calculations, and therefore are to a certain extent comparable. The same applies to the upper and lower bounds, which are sometimes 95% and 5% of log-normal distributions, sometimes 90% and 10%, and occasionally best estimate maximum and minimum values. The exact meaning of the centre point and upper and lower bounds for each of the sources plotted on one graph can be found in the data tables accompanying each graph.

For most of the sources there are also unique assumptions and limitations relating to the data provided. Sometimes these are not clearly stated. This is also a major obstacle to the formal combination of different data sources and it influences comparisons such as this one. More information about each of the sources may be found in the IAEA Component Reliability Data Base.

## 4. SELECTION OF DATA

### 4.1 Selection of component type and failure mode

The IAEA Component Reliability Data Base contains more than 420 component types sorted into 100 categories. The number of data points available for each component type is usually small, varying between one and three data points per component type and failure mode. There are, of course, components with fine resolutions (e.g. when the piping diameter is provided for valves), and components with coarse resolutions (e.g. batteries). As a rule, the number of data points is smaller when the resolution is finer, and larger when it is coarser.

The next level of resolution in the IAEA Data Base is the component category. The component category in principle corresponds to a generic component type as found in the literature, although sometimes the level of resolution is still more detailed than for the generic sources (e.g. in the IAEA Data Base transformers are divided in seven categories). At this level the amount of data in one category was adequate for meaningful plots. Out of 100 component categories in the IAEA Data Base, 20 generic component types were selected (e.g. all transformers were considered to be in one category).

The following component types were selected:

- (1) Diesel driven pump
- (2) Motor driven pump
- (3) Turbine driven pump
- (4) Air operated valve
- (5) Motor operated valve
- (6) Solenoid operated valve
- (7) Manual valve
- (8) Relief valve
- (9) Safety valve
- (10) Diesel generator
- (11) Battery
- (12) Battery charger
- (13) Bus
- (14) Motor
- (15) Inverter

- (16) Rectifier
- (17) Transformer
- (18) Relay
- (19) Switch
- (20) Transmitter.

The next step was the selection of the applicable failure mode. The general rule for all component types was that the failure modes that are most important and/or that are often addressed in PSAs have to be selected. As illustrated in Appendix 2 of the IAEA Data Base, failure modes given in the original sources vary substantially, even in descriptions of the same failure. In the compilation of the IAEA Data Base a set of generic failure modes was developed. The original failure modes from the sources were then put into one of the generic categories. These generic failure mode categories were used in the Data Ranges Overview. The limitation in the failure mode selection was again data availability. Specific components and failure modes having very few data points were not considered.

Finally, between one and four failure modes per component type were selected. These were:

- (1) Failure to start
- (2) Failure to run
- (3) Failure to change position
- (4) Failure to open
- (5) Failure to close
- (6) Failure to remain in position
- (7) Failure to function
- (8) All modes

In a few cases, when it was found that two failure modes actually described the same failure (e.g. 'all modes' and 'failure to function'), they were combined. For some component types, two or more failure modes describing quite similar failures were plotted (e.g. 'fail to change position' and 'fail to open' for valves). The detail definition and possible applications for each failure mode is found in the Appendix 2 of the IAEA Component Reliability Data Base.

## 4.2 Data sources selection

All the sources in the IAEA Data Base were considered for inclusion in the Data Ranges Overview. The ultimate sources of data among all these are quite diverse, however. The same applies to the methods used to collect or generate the reliability data. In order to make a meaningful comparison, data sources had to be categorized.

The availability of data also plays a major role in source categorization. Defining a large number of categories would lead to few data points in each category. However, defining three categories seemed adequate in view of the constraints.

These three categories are:

- (1) Generic sources
- (2) Plant specific sources
- (3) Updated sources

Each of these three exhibits some unique characteristics and in principle should be considered separately.

The plant specific and updated categories commonly have few data points which are, in addition, easily identifiable, thus they were plotted together. When only a few (three or four) data points were available in the three categories, only one graph was made. Each category was, however, plotted separately in the graph.

The plant specific category contains reliability data based on operating experience of a single plant or a group of similar plants with data collected in the same manner. Out of 21 sources included in the IAEA Data Base, two fully qualify as plant specific (referred to as PS) sources, and in two additional sources the majority of the data fit in this category.

These sources are (the complete title, table number, etc., are given in Chapter 6):

- (1) NUREG/CR-4550, Vol. 3, Surry NPP
- (2) Swedish Reliability Data Book, Ringhals 2 data

- (3) HWR Data (some data are in generic category)
- (4) EPRI-NP-2433 (diesel generators)

The updated category consists of sources obtained by updating generic data with the plant specific operating experience. Three sources qualify for this category (all are the PSA studies). Two of these sources (Oconee PSA and Zion PSA) used fairly similar generic priors (NUREG with LER Rates, IEEE 500/1977, WASH-1400. The third source used its own prior, which is not independent of the documents mentioned. To permit comparison, data tables give information about the prior and the operating experience (in terms of recorded number of failures and operating time or number of demands).

The updated sources are:

- (1) Zion NPP PSS
- (2) NASC 60, Oconee NPP PRA
- (3) Old PWR reactor

The third category is termed generic and it contains all the remaining sources from the IAEA Data Base. This category includes the whole range of ultimate data sources from expert opinion (single or aggregate) to operating experience. The reason for placing all in one category is that all of these sources provide some kind of averaging of reliability data (because of the population involved) and therefore depict a smoother behaviour. The number of data points in this category is usually the largest of all three.

The generic sources are:

- (1) German Risk Study
- (2) IEEE Standard 500
- (3) NUREG/CR-2728, IREP
- (4) NUREG/CR-1205 pumps
- (5) NUREG/CR-1363 valves
- (6) NUREG/CR-1740 I & C equipment
- (7) NUREG/CR-2815 PSA Procedure Guide
- (8) NUREG/CR-2886 pumps
- (9) NUREG/CR-3831 DG's, batteries
- (10) NUREG/CR-4450 Vol. 1 Methodology
- (11) Shoreham NPP PSA

- (12) Sizewell B NPP Pre-construction Safety Report
- (13) Swedish Reliability Data Book (Data from seven BWR plants)
- (14) WASH-1400, RSS
- (15) WWER Component Reliability Data Base

#### 4.3 Operating mode selection

The operating mode of the component has a major influence on its failure rate. Separate graphs for every component operating mode in each failure mode category are therefore desirable. However, information on component operating modes is usually sparse and rarely found in the sources. Consequently, it was only possible in a few cases to have separate graphs for component operating modes.

The operating mode is more important for components that perform their function by continuously moving (e.g. by rotating, such as pumps) and less important for 'open-closed' components (such as valves) or for electrical and electronic components that do not change state on a macroscopic level. Owing to data availability, the only component for which separation into different operating modes was possible was the motor operating pump.

For the motor operating pumps, two failure modes were included in the Data Ranges Overview: failure to start and failure to run. The starting failures were considered in three operating modes: standby, alternating and all. (The operating mode 'all modes' is also the default mode used in the IAEA Component Data Base whenever information on particular operating modes was not available). Running failures were regarded in four operating modes: standby, alternating, running and all modes. For all other components and failure modes, operating modes were considered to be 'all modes'.

## 5. INPUT DATA PREPARATION

One of the objectives of the IAEA Component Reliability Data Base was to reproduce the information found in original sources to the maximal extent possible. No changes or alterations of any kind were made in the data during the compilation of the IAEA Data Base. It is recognized, however, that the data for some of the components and failure modes originating from different sources are not compatible.

This situation did not cause any problems in compiling the IAEA Data Base, but to permit comparison the data should be made compatible. The problem of incompatibility is most severe in dealing with demand related failures.

The philosophy and mechanisms of demand related failures as well as the methods used to denote the time and demand related failures in common form are considered next.

### 5.1 Treatment of demand related failures

The majority of sources included in the IAEA Data Base define failures of components to change state or position (e.g. fail to start) as demand related failure. Some of the sources, however, define all or part of the failures of this kind as time dependent. To permit comparison of failure rates, all of these should be expressed in the same form.

In analysing the failure mechanism, in most cases the component failures are modelled as the sum of two contributions, one time dependent and the second demand related. The fractional contribution of each of these two depends on component type, failure mode, operating mode and demand interval, and varies significantly from case to case. If this approach is to be introduced in the modelling, unique data are needed for each contribution. Data of this type are sparse and usually not available, at least for the components normally modelled in PSA studies. None of the sources in the IAEA Data Base provide data of this type. Instead it is assumed that both contributions are included in either demand related or time related failure data.



The demand related failure probabilities are always coupled with the specific test interval for periodically tested standby components, or with the demand interval for frequently demanded components or untested components. The use of the data is then limited to the components having (among other similarities) comparable demand rates. However, if the demand related failure probability is utilized for components which have significantly different demand intervals, this could result in either the underestimation or the overestimation of component reliability.

When the component failure rate is expressed as time dependent, differences in demand interval are considered. If the portion of the failure rate which is demand related is high and the demand interval is substantially different from the interval originally taken into account, it could again introduce errors in failure rate estimation. The use of the time related concept is preferable, because the potential error caused by neglecting the demand related contribution is generally smaller than that caused by neglecting differences in the demand interval.

For the purpose of the Data Ranges Overview, it was necessary to convert time related failure rates to demand related rates, or vice versa. As the majority of sources provided failure data for the failure modes in question as demand related, it was easier to convert the time related data to demand related data.

The simplest way to convert time related failure rates to demand related rates is to assess the test or demand interval and to assume failure to occur at half of this interval. The failure rate is then multiplied by the number of hours to obtain the probability of the component's failing when demanded.

This was the procedure followed in the Data Ranges Overview. As the exact test or demand intervals taken into account in the sources were not always known, some generally accepted intervals were used. Three demand intervals were chosen depending on the generic type of component:

- (1) 1/month (720 h) used for components found in standby safety systems. It is a widely accepted test policy to test this category of components once per month.

(2) 1/quarter (2160 H) used for safety and relief valves which are tested during refuellings, and in addition demanded on average three times per year (in some of the transients).

(3) 1/day (24 hrs.) for components such as relays or switches located in the control/protection systems, which are demanded at a fairly high rate owing to continuous changes of process parameters.

Whenever a time related failure rate is converted to a demand related rate, this is indicated in the data tables together with the exact time interval used in the conversion.

## 6. USES OF THE DATA RANGES OVERVIEW

The plots provided in Appendix 2 can be used in a number of ways. One possible application is the establishment of failure rate (or failure probability) ranges for sensitivity analysis.

A useful application is to use the plots to compare data with those in the available literature. In this case the proper figure should be chosen on the basis of the component type and failure mode of interest and of whether the data to be compared are representative of a generic data source or the result of plant specific experience.

A more ambitious application is, however, the use of the plots to establish acceptable ranges for component failure rates or failure probabilities in PSA.

# Appendix 1

## DATA SOURCES AND RESPECTIVE CODING

SOURCE NAME	CODE
1. HWR assessment	F
2. EPRI-NP-2433, Diesel-Generator Reliability at Nuclear power Plants:Data and Preliminary Analysis, Science Application, Inc., June, 1982.	R
3. German Risk Study (Deutsche Risikostudie Kernkraftwerke), GRS, FRG, 1979.	G
4. IEEE Standard 500, IEEE Guide to the Collection and Presentation of Electrical, Electronic, Sensing Component, and Mechanical Equipment Reliability Data for Nuclear-Power Generating Stations, Appendix D, Reliability Data for Nuclear-Power Generating Stations, IEEE 1984.	E
5. NUREG/CR-2728 Interim Reliability Evaluation Program Procedure Guide, Sandia National Laboratories, January 1983.	I
6. NUREG/CR-1205 Data Summaries of Licencee Events Reports of Pumps at U.S. Commercial Nuclear Power Plants EG& Idaho, Inc., January 1982	P

7. NUREG/CR-1331 Data Summaries of Licencee Event Reports of Control Rods and Drive Mechanisms at US Commercial Nuclear Power Plants, EG&G Idaho, Feb, 1980.

C

8. NUREG/CR-1363 Data Summaries of Licencee Event Reports of Valves at US Commercial Nuclear Power Plants, EG&G Idaho, Inc., October 1982.

V

9. NUREG/CR-1740 Data Summaries of Licencee Event Reports of Selected Instrumentation and Control Components at US Commercial Nuclear Power Plants, EG&G Idaho, Inc., July, 1984.

M

10. NUREG/CR-2815 Probabilistic Safety Analysis Procedure Guide, Brookhaven National Laboratory, August 1985.

B

11. NUREG/CR-2886 In-Plant Reliability Data Base for Nuclear Plant Components: Interim Data Report, the Pump Component, Oak Ridge National Lab, December 1982.

D

12. NUREG/CR-3831 In-Plant Reliability Data Base for Nuclear Plant Components: Interim Data Report, Diesel Generators, Batteries, Chargers and Inverters. Oak Ridge National Lab, January 1985.

N

13. NUREG/CR 4550 Vol.1 Analysis of Core Damage Frequency From Internal Events: Methodology Guidelines September 1987.

J

14. NUREG/CR 4550 Vol.3, Analysis of Core Damage Frequency from Internal Events :Surry, Unit 1. Sandia National Laboratory, November 1986.

A

15. NASC 60, OCONEE PRA, A Probabilistic Risk Assessment of Oconee Unit 3, The Nuclear Safety Research Center, EPRI, and Duke Power Co., June, 1984.

O

16. Old PWR reactor

H

17. Shoreham Nuclear Power Station Probabilistic Safety Assessment,  
Science Application, Inc.,

S

18. PWR/RX 312 Sizewell 'B' PWR Pre-Construction Safety Report,  
Component Failure Data for PWR System Reliability Assessment, NNC,  
UK, June, 1982.

U

19. RKS 85-25 Reliability Data Book for Components in Swedish  
Nuclear Power Plants, RKS, SKI Sweden

T

20. WASH-1400, Reactor Safety Study, An Assessment of Accident in  
U.S. Commercial Nuclear Power Plants, US NRC, October 1975

W

21. Zion Nuclear Power Station, Probabilistic Safety Study,  
Commonwealth Edison Co., 1981.

Z

22. VVER Component Reliability Data Base, IAEA RER/9/005, June 1988.

X

In cases where for the same component type more than one record is  
available, a consecutive numbering system following the source ID was  
defined.

## Appendix 2

### DATA GRAPHS AND TABLES

This section presents the failure rates or failure probabilities for different component types and failure modes from the 21 data sources included in the IAEA Data Base. One additional source reproduced is the WWER Component Reliability Data Base.

Whenever this is available, the operating mode is indicated. Centre points and upper and lower estimates are plotted according to their availability in the sources.

Each plot is accompanied by printouts of the specific record as stored in the IAEA Data Base. Inspection of the actual record is most useful for analysing each data point.

Graphs are plotted as described in Section 4.2 in two categories, namely:

- generic sources;
- plant specific and updated sources

The source identification used in the plots is the one defined in the IAEA Data Base and reproduced in the following:

<u>Mechanical components</u>	<u>Page</u>
1. Diesel driven pump, fail to start, operating modes all and standby (generic and updated sources)	28
2. Diesel driven pump, fail to run, operating modes all and standby (generic and updated sources)	30
3. Motor driven pump, fail to start, operating mode all (generic sources)	32

	<u>Page</u>
4. Motor driven pump, fail to start, operating mode all (updated sources)	34
5. Motor driven pump, fail to start, operating mode standby (generic sources)	36
6. Motor driven pump, fail to start, operating mode standby (PS and updated sources)	40
7. Motor driven pump, fail to start, operating mode alternating (generic sources)	44
8. Motor driven pump, fail to start, operating mode alternating (PS and updated sources)	46
9. Motor driven pump, fail to run, operating mode all operating environment normal and extreme (E), (generic sources)	50
10. Motor driven pump, fail to run, operating mode all (updated sources)	54
11. Motor driven pump, fail to run, operating mode standby (updated sources)	56
12. Motor driven pump, fail to run, operating mode alternating (generic sources)	60
13. Motor driven pump, fail to run, operating mode alternating (PS and updated sources)	62
14. Motor driven pump, fail to run, operating mode running (generic and PS sources)	68
15. Turbine driven pump, fail to start, op.mode all and standby (generic sources)	72
16. Turbine driven pump, fail to start, op.mode standby (updated and PS sources)	74



	<u>Page</u>
17. Turbine driven pump, fail to run, op.modes, standby and all (generic and updated sources)	76
18. Air operated valve, fail to change position (generic sources)	78
19. Air operated valve, fail to change position (PS and updated sources)	82
20. Air operated valve, fail to open (generic and updated sources)	84
21. Air operated valve, fail to close (updated sources)	86
22. Air operated valve, fail to remain in position, all operating modes (generic and updated sources)	88
23. Manual valve, fail to change position (generic sources)	92
24. Manual valve, fail to change position (PS sources)	96
25. Manual valve, fail to remain in position (PS and generic sources)	98
26. Motor operated valve, fail to change position (generic sources)	100
27. Motor operated valve, fail to change position (PS and updated sources)	104
28. Motor operated valve, fail to remain in position (generic sources)	108
29. Motor operated valve, fail to remain in position (updated sources)	110
30. Check valve, fail to open (generic sources)	112
31. Check valve, fail to open (PS and updated sources)	116

	<u>Page</u>
32. Check valve, fail to close (generic sources)	118
33. Check valve, fail to close (PS and updated sources)	122
34. Solenoid operated valve, fail to change position (generic sources)	126
35. Relief valve, fail to open (generic and updated sources)	128
36. Relief valve, fail to close (generic and updated sources)	132
37. Safety valve, fail to open (generic and updated sources)	136
38. Safety valve, fail to close (generic and updated sources)	140

#### Emergency Power Sources

1. Diesel generator, fail to start (generic sources)	144
2. Diesel generator, fail to start (PS and updated sources)	148
3. Diesel generator, fail to run (generic sources)	150
4. Diesel generator, fail to run (PS and updated sources)	154

#### Electrical Components


1. Battery, fail to function (generic sources)	156
2. Battery, fail to function (PS and updated sources)	160
3. Battery charger, fail to function (generic sources)	162
4. Battery charger, fail to function (PS and updated sources)	164

	<u>Page</u>
5. Bus, fail to function and all modes (generic sources)	166
6. Bus, fail to function and all modes (PS and updated sources)	170
7. Inverter, fail to function and all modes (generic sources)	174
8. Inverter, fail to function (PS and updated sources)	178
9. Motor, fail to start, normal environment (generic sources)	180
10. Motor, fail to run, normal environment (generic sources)	182
11. Rectifier, fail to function (generic sources)	186
12. Relay, fail to remain in position (generic sources)	188
13. Transformer (all types and voltage levels), fail to function (generic sources)	190
14. Transformer (all types and voltage levels), fail to function (updated sources)	194

#### Instruments and Control Equipment

1. Switch (flow, level, limit, pressure, temperature, torque), fail to function (generic sources)	198
2. Transmitter (all types), fail to function (PS and generic sources)	204

# IAEA RELIABILITY DATA BASE



D Source category: generic

PDASD pump diesel driven  
Component boundary: pump,shaft,diesel,local instrumentation and control circuitry Operating mode: standby Operating environment: normal  
Generic failure mode: fail to start Original failure mode: fails to start  
FAILURE RATE OR PROBABILITY mean :  $2.1\text{E-}2/\text{d}$  :  $3.0\text{E-}1/\text{d}$  :  $4.0\text{E-}3/\text{d}$   
Source: NUREG 2886 (1982) (tbl.19) Ultimate source: plant operating experience-maintenance records(2PWR & 4BWR)  
Comment: Pop.24. 9 catastrophic demand related failures of 427 demands. Upbound and lowbound are largest and smallest rate of the functional aggregates of selected pumps classified by dr ver

Z Source category: updated

PDCSZ pump diesel driven containment spray pump  
Component boundary: detail n/a Operating mode: standby Operating environment: normal  
Generic failure mode: fail to start Original failure mode: failure to start on demand  
FAILURE RATE OR PROBABILITY mean :  $4.2\text{E-}3/\text{d}$   
Source: ZION NPP PSS (tbl.1.5.1-5) Ultimate source: generic data upgraded with plant specific experience  
Comment: Prior:NUREG 1205(diesel pump,stdby)(M),WASH 1400(diesel plant??). (D).Op.exp.183 demands,1 failure. N-1205 population of 4 include 2 ZION diesel pumps and only 1 failure occurring.Failrate too low?

P Source category: generic

PDASP pump diesel driven  
Component boundary: incl.mech.control,governor,emergency tripping,blower,lube oil sys Operating mode: standby Operating environment: normal  
Generic failure mode: fail to start Original failure mode: does not start  
FAILURE RATE OR PROBABILITY mean :  $3.0\text{E-}3/\text{d}$   
Source: NUREG 1205 (1982) (table 15) Ultimate source: US plant LER report evaluation  
Comment: Pop.4 (PWR & BWR) 1 failure. W/o command faults.W command faults  $3.0\text{E-}2/\text{d}$  Standby hourly rate with command faults  $6.5\text{E-}5/\text{hr}$

I Source category: generic

PDASI pump diesel driven  
Component boundary: pump,diesel,lube oil system,fuel oil,suction and exhaust,starting Operating mode: all Operating environment: normal  
Generic failure mode: fail to start Original failure mode: failure to start  
FAILURE RATE OR PROBABILITY mean :  $1.0\text{E-}3/\text{d}$  ERROR FACTOR: 3  
Source: IREP NUREG 2728 (tbl.5.1-1) Ultimate source: expert opinion  
Comment:


J Source category: generic

PDASJ pump diesel driven general  
Component boundary: detail n/a Operating mode: all Operating environment: normal  
Generic failure mode: fail to start Original failure mode: fails to start  
FAILURE RATE OR PROBABILITY mean :  $1.0\text{E-}3/\text{d}$  ERROR FACTOR: 3  
Source: NUREG 4550, Vol.1,tbl.VIII.1-2 Ultimate source: assesed from several nuclear data sources  
Comment: ASEP used the generic value from LERs. Failure to start incl.two types of failure:circuit breaker command faults ( $3.0\text{E-}2$ ) and pump hardware faults( $3.0\text{E-}3$ ).

B Source category: generic

PDASB pump diesel driven  
Component boundary: Pump,diesel,lube oil system,fuel oil,suction and exhaust,starting Operating mode: all Operating environment: normal  
Generic failure mode: fail to start Original failure mode: failure to start  
FAILURE RATE OR PROBABILITY mean :  $3.6\text{E-}4/\text{d}$  max:  $1.8\text{E-}2/\text{d}$  min:  $7.2\text{E-}5/\text{d}$   
Source: NUREG 2815 (table C.1.) Ultimate source: expert opinion agregation and IREP data  
Comment: Original time related value changed to demand related assuming monthly test interval.

# IAEA RELIABILITY DATA BASE



Z Source category:

PDCRZ pump diesel driven containment spray pump  
Component boundary: detail n/a Operating mode: standby Operating environment: normal  
Generic failure mode: fail to run Original failure mode: fail during operation  
FAILURE RATE OR PROBABILITY mean : 2.9E-2/hr  
Source: ZION NPP PSS (tbl.1.5.1-5) Ultimate source: generic data updated with plant experience  
Comment: Prior:WASH 1400 pumps (w/o motor),failure to run, normal environ. WASH 1400, Diesel(engine only),failure to run.  
Operating experience: 33 hours of operation, 2 failures.


J Source category:

PDARJ pupm diesel driven general  
Component boundary: detail n/a Operating mode: all Operating environment: normal  
Generic failure mode: fail to run Original failure mode: fails to run  
FAILURE RATE OR PROBABILITY mean : 8.0E-4/hr ERROR FACTOR: 10  
Source: NUREG 4550, Vol.1,tbl.VIII.1-2 Ultimate source: assessed from several nuclear data sources  
Comment: ASEP used generic values from LERs.

I Source category

PDARI pump diesel driven  
Component boundary: pump,diesel,lube oil system,fuel oil,suction and exhaust,starting Operating mode: all Operating environment: normal  
Generic failure mode: fail to run Original failure mode: failure to run given start  
FAILURE RATE OR PROBABILITY mean : 8.0E-4/hr ERROR FACTOR: 30  
Source: IREP NUREG 2728 (tb.5 1-1) Ultimate source: expert opinion  
Comment:

## IAEA RELIABILITY DATA BASE





B Source category: generic

PMYSB pump motor driven  
Component boundary: including motor, excluding control circuitry Operating mode: all Operating environment: normal  
Generic failure mode: fail to start Original failure mode: failure to start  
FAILURE RATE OR PROBABILITY mean : 1.0E-5/hr max: 5.0E-5/hr min: 2.0E-7/hr  
Source: NUREG 2815 (table C.1.) Ultimate source: expert opinion aggregation & IREP data  
Comment: Original time related value changed to demand related assuming monthly test interval.

J Source category: generic

PMASJ pump motor driven general  
Component boundary: detail n/a Operating mode: all Operating environment: normal  
Generic failure mode: fail to start Original failure mode: fails to start  
FAILURE RATE OR PROBABILITY mean : 3.0E-3/d ERROR FACTOR: 10  
Source: NUREG 4550, Vol.1, tbl.VIII.1-2 Ultimate source: assessed from several nuclear data sources  
Comment: ASEP used generic values developed in Station Blackout Study (NUREG/CR-3226). Value for fails to start included two types of failures-Pump hardware (4.0E-4/d) and circuit br.command(2.5E-3).

I Source category: generic

PMYSI pump motor driven  
Component boundary: including motor, excluding control circuitry Operating mode: all Operating environment: normal  
Generic failure mode: fail to start Original failure mode: failure to start on demand  
FAILURE RATE OR PROBABILITY mean : 3.0E-3/d ERROR FACTOR: 10  
Source: IREP NUREG 2728 (tbl.5.1-1) Ultimate source: expert opinion  
Comment:

U Source category: generic

PULSU pump motor driven low pressure <20bar  
Component boundary: detail n/a Operating mode: all Operating environment: normal  
Generic failure mode: fail to start Original failure mode: failure to start  
FAILURE RATE OR PROBABILITY mean : 2.0E-3/d  
Source: Sizewell B (PWR/RX312 pg.11) Ultimate source: assessed from nuclear and industrial experience and data  
Comment: Assessment based on W data, WASH 1400, EDF data item(1.8E-4/d out of 16800 demands) and two SRS data items (4.0E-3/d for HHS1,RHR and auxfeed) and (2.0E-3/d for CVCS and CCWS).


W Source category: generic

PMYSW pump motor driven  
Component boundary: detail n/a, including motor Operating mode: all Operating environment: normal  
Generic failure mode: fail to start Original failure mode: failure to start on demand  
FAILURE RATE OR PROBABILITY median: 1.0E-3/d : 3.0E-3/d : 3.0E-4/d ERROR FACTOR: 3  
Source: WASH 1400 (table III 4-1) Ultimate source: assessed from nuclear, industrial and military experience and data  
Comment:

X Source category:

PMASX pump motor driven general  
Component boundary: detail n/a Operating mode: all Operating environment: normal  
Generic failure mode: fail to start Original failure mode: fail to start  
FAILURE RATE OR PROBABILITY mean : 1.0E-3/d 80%: 6.0E-3/d 20%: 3.3E-4/d  
Source: VVER reliability data base Ultimate source: expert opinion, operating experience  
Comment:

## IAEA RELIABILITY DATA BASE



H1 Source category: updated

PUWSH pump motor driven residual heat removal pump  
Component boundary: detail n/a Operating mode: all Operating environment: normal  
Generic failure mode: fail to start Original failure mode: fail to start on demand  
FAILURE RATE OR PROBABILITY mean :  $6.5\text{E-}3/\text{d}$  95%:  $1.7\text{E-}2/\text{d}$  5%:  $7.1\text{E-}4/\text{d}$   
Source: Old PWR Ultimate source: generic data updated with plant specific operating experience  
Comment: Generic mean  $3.3\text{E-}3/\text{d}$ . Operating experience 58 demands, 1 failure

H2 Source category: updated

PUVSH pump motor driven well water pump  
Component boundary: detail n/a Operating mode: all Operating environment: normal  
Generic failure mode: fail to start Original failure mode: fail to start on demand  
FAILURE RATE OR PROBABILITY mean :  $3.7\text{E-}3/\text{d}$  95%:  $8.4\text{E-}3/\text{d}$  5%:  $5.3\text{E-}4/\text{d}$   
Source: Old PWR Ultimate source: generic data updated with plant operating experience  
Comment: Generic mean  $3.3\text{E-}3/\text{d}$ . Operating experience 192 demands, 1 failure.


H3 Source category: updated

PMGSH pump motor driven electric equipment area ventilation cooling pump  
Component boundary: detail n/a Operating mode: all Operating environment: normal  
Generic failure mode: fail to start Original failure mode: fail to start on demand  
FAILURE RATE OR PROBABILITY mean :  $1.4\text{E-}3/\text{d}$  95%:  $3.2\text{E-}3/\text{d}$  5%:  $2.0\text{E-}4/\text{d}$   
Source: Old PWR Ultimate source: generic data updated with plant operating experience  
Comment: Generic mean  $2.4\text{E-}3/\text{d}$ . Operating experience 329 demands, no failures.

H4 Source category: updated

PUZSH pump motor driven recirculation pump  
Component boundary: detail n/a Operating mode: all Operating environment: normal  
Generic failure mode: fail to start Original failure mode: fail to start on demand  
FAILURE RATE OR PROBABILITY mean :  $1.0\text{E-}3/\text{d}$  95%:  $2.5\text{E-}3/\text{d}$  5%:  $1.3\text{E-}4/\text{d}$   
Source: Old PWR Ultimate source: generic data updated with plant operating experience  
Comment: Generic mean  $3.3\text{E-}3/\text{d}$ . Operating experience 684 demands, no failures.

# IAEA RELIABILITY DATA BASE



D Source category: generic

PMTSD pump motor driven include containment spray,standby liquid control  
Component boundary: pump,shaft,motor,switches,local control and instrumentation Operating mode: standby Operating environment: normal  
Generic failure mode: fail to start Original failure mode: failure to start  
FAILURE RATE OR PROBABILITY mean : 5.5E-3/d : 6.0E-4/d : 5.0E-2/d  
Source: NUREG 2886 (1982)(tbl.18 & 19) Ultimate source: plant operating experience-maintenance records(2PWR & 4BWR)  
Comment: Pop.95.31 catastrophic demand related failures of 5456 demands Up & lowbound derived from funct.aggregation.Failrate is based on  
1 demand/month.(actual 2-3 times higher)very conservative

T1 Source category: generic

PMQST pump motor driven centrifugal,horisontal and vertical  
Component boundary: pump,motor,transmission,switch,fuse,protection,controls Operating mode: standby Operating environment: normal  
Generic failure mode: fail to start Original failure mode: failure to start  
FAILURE RATE OR PROBABILITY mean : 5.1E-3/d 95%: 2.1E-2/d REPAIR TIME: 3 hr  
Source: Swedish Rel.data book, tbl.8 Ultimate source: plant operating experience (7 BWR plants),ATV reports, LERs  
Comment: Operating experience:total pop.18. No.of demands 784. 4 failures. a=0.387; b=75.4 Critical failures occurred at 2 plants.

T2 Source category: generic

PUPST pump motor driven reciprocating(positive displacement)  
Component boundary: pump,transmission,motor,switch,fuse,protection,control Operating mode: standby Operating environment: normal  
Generic failure mode: fail to start Original failure mode: failure to start  
FAILURE RATE OR PROBABILITY mean : 4.0E-3/d 95%: 2.1E-2/d REPAIR TIME: 7 hr  
Source: Swedish Rel.data book, tbl.10 Ultimate source: plant operating experience (7 BWR plants)  
Comment: Operating experience:total pop 22. No.of demands 1238. 5 failures a=0.186; b=46. Critical failures occurred at 3 plants.

U Source category: generic

PMISU pump motor driven high pressure (>20 bar)  
Component boundary: detail n/a Operating mode: standby Operating environment: normal  
Generic failure mode: fail to start Original failure mode: failure to start on demand  
FAILURE RATE OR PROBABILITY mean : 4.0E-3/d  
Source: Sizewell B (PWR/RX312 pg.9) Ultimate source: assessed from nuclear and industrial experience and data  
Comment: Assesment based on W data,WASH 1400,EDF data and 2 SRS data items one applies to HHSI,RHR and auxfeed(4.0E-3/d) and other to CVCS  
and CCWS (2.0E-3/d).

X Source category: generic

PMASX pump motor driven HPECCS  
Component boundary: detail n/a Operating mode: standby Operating environment: all  
Generic failure mode: fail to start Original failure mode: fail to start  
FAILURE RATE OR PROBABILITY mean : 3.0E-3/d 80%: 9.0E-3/d 20%: 6.0E-4/d  
Source: VVER reliability data base Ultimate source: Expert opinion, operating experience  
Comment.


T3 Source category: generic

PMOST pump motor driven centrifugal horizontal and vertical  
 Component boundary: pump, transmission, motor, switch, fuses, protection, controls Operating mode: standby Operating environment: normal  
 Generic failure mode: fail to start Original failure mode: failure to start  
 FAILURE RATE OR PROBABILITY mean :  $1.4\text{E-}3/\text{d}$  95%:  $8.3\text{E-}3/\text{d}$  REPAIR TIME: 2 hr  
 Source: Swedish Rel.data book, tbl.7 Ultimate source: operating experience (7 BWR plants), ATV reports, LERs, plant infor.  
 Comment: Data derived from observation of 12 components, 696 demands (per op.time), 1 failure occurring (critical)  
 Critical failures occurred at one plant only.  $a=0.116$ ;  $b=80.3$

P Source category: generic

PMASP pump motor driven  
 Component boundary: pumping unit, motor, coupling, mech. control Excl. MCC, breakers, ect Operating mode: standby Operating environment: normal  
 Generic failure mode: fail to start Original failure mode: does not start  
 FAILURE RATE OR PROBABILITY median:  $5.1\text{E-}4/\text{d}$  95%:  $7.1\text{E-}4/\text{d}$  5%:  $3.4\text{E-}4/\text{d}$   
 Source: NUREG 1205 (1982) (pg.362) Ultimate source: US plant LER report evaluation  
 Comment: Overall data, includes all types of reactors, LER-s from 1972 to 1980. Ttl. pop. 596. No. of failures 91 W/o command faults.  
 W command faults  $3.0\text{E-}3$ . Sdbdy hourly rate  $1.0\text{E-}6$

# IAEA RELIABILITY DATA BASE



A1 Source category: plant specific

PMCSA pump motor driven inside spray recirculation  
Component boundary: detail n/a Operating mode: standby Operating environment: normal  
Generic failure mode: fail to start Original failure mode: fail to start/run  
FAILURE RATE OR PROBABILITY median: 3.6E-2/d ERROR FACTOR: 1.8  
Source: NUREG 4550/Vol.3,tbl.IV.8-1 Ultimate source: Surry NPP operating experience (test data)  
Comment: It was not possible to identify failure mode in table. It seems to cover starting failure and initial running failure (during test)

H1 Source category: updated

PMSSH pump motor driven safety injection pump  
Component boundary: detail n/a Operating mode: standby Operating environment: normal  
Generic failure mode: fail to start Original failure mode: fail to start on demand  
FAILURE RATE OR PROBABILITY mean : 8.4E-3/d 95%: 1.3E-2/d 5%: 3.7E-3/d  
Source: Old PWR Ultimate source: generic data updated with plant operating experience  
Comment: Generic mean 3.3E 3/d. Operating experience 719 demands,7 failures.

Q1 Source category: updated

PMCSO pump motor driven reactor building spray  
Component boundary: detail n/a Operating mode: standby Operating environment: normal  
Generic failure mode: fail to start Original failure mode: failure to start  
FAILURE RATE OR PROBABILITY mean : 8.1E-3/d 95%: 1.8E-2/d 5%: 1.1E-3/d REPAIR TIME: 28.6 hours  
Source: Oconee NPP PRA (tbl.b-1.) Ultimate source: generic data updated with plant specific operating experience  
Comment: Prior:Mean NUREG 1205(1980),80%/20% is based on RSS distribution. Same prior as for injection pumps.Op.experience:140 dem.3 failures  
Repair time is mean of plant spec.update of maintenance duration.

A2 Source category: plant specific

PMXSA pump motor driven auxiliary feedwater  
Component boundary: detail n/a Operating mode: standby Operating environment: normal  
Generic failure mode: fail to start Original failure mode: fail to start/run  
FAILURE RATE OR PROBABILITY median: 5.6E-3/d ERROR FACTOR: 2.2  
Source: NUREG 4550/Vol.3,tbl.IV.8-1 Ultimate source: Surry NPP operating experience (test data??)  
Comment: It was not possible to identify failure mode as appear in table. It seems to cover starting failure and initial running failure.

H2 Source category: updated

PMCSH pump motor driven containment spray  
Component boundary: detail n/a Operating mode: standby Operating environment: normal  
Generic failure mode: fail to start Original failure mode: fail to start on demand  
FAILURE RATE OR PROBABILITY mean : 5.1E-3/d 95%: 9.0E-3/d 5%: 1.7E-3/d  
Source: Old PWR Ultimate source: generic data updated with plant operating experience  
Comment: Generic mean 3.3E-3/d. Operating experience 634 demands, 4 failures.

O2 Source category: updated

PMVSO pump motor driven high pressure injection  
Component boundary: detail n/a Operating mode: standby Operating environment: normal  
Generic failure mode: fail to start Original failure mode: failure to start  
FAILURE RATE OR PROBABILITY mean : 8.4E-4/d 95%: 2.1E-3/d 5%: 6.0E-5/d REPAIR TIME: 21.5 hours  
Source: Oconee NPP PRA (tbl.b-1.) Ultimate source: generic data updated with plant specific operating experience  
Comment: Prior:Mean NUREG 1205(1980),standby pump,80%/20% ratio based on RSS distribution.Operating experience: 530 demands,1 failure.  
Repair time is mean of updated component maintenance duration.




Z Source category: updated  
 PMASZ pump motor driven  
 Component boundary: detail n/a Operating mode: standby Operating environment: normal  
 Generic failure mode: fail to start Original failure mode: failure to start on demand  
 FAILURE RATE OR PROBABILITY mean :  $7.2E-4/d$   
 Source: ZION NPP PSS (tbl.1.5.1.5) Ultimate source: generic data upgraded with plant specific experience  
 Comment: Priors:NUREG 1205(tbl.14)standby system does not start,w/o comman (mean),and WASH 1400 table III 2-1,electric motor failure to strt for distribution. Experience:3138 demands,3 failures

03 Source category: updated  
 PMFSO pump motor driven emergency feedwater pump  
 Component boundary: detail n/a Operating mode: standby Operating environment: normal  
 Generic failure mode: fail to start Original failure mode: failure to start  
 FAILURE RATE OR PROBABILITY mean :  $4.8E-4/d$  95%:  $1.4E-3/d$  5%:  $1.4E-5/d$  REPAIR TIME: 20.9 hours  
 Source: Oconee NPP PRA (tbl.b-1.) Ultimate source: generic data updated with plant specific operating experience  
 Comment: Prior:mean NUREG 1205(1980),standby pump,80%/20% ratio based on RSS distrib.Op.expereince:18 demands, no failures.  
 Repair time is mean generic component maintenance duration.

04 Source category: updated  
 PMLS0 pump motor driven low pressure injection  
 Component boundary: detail n/a Operating mode: standby Operating environment: normal  
 Generic failure mode: fail to start Original failure mode: failure to start  
 FAILURE RATE OR PROBABILITY mean :  $3.7E-4/d$  95%:  $1.0E-3/d$  5%:  $1.4E-5/d$  REPAIR TIME: 10.8 hours  
 Source: Oconee NPP PRA (tbl.b-1 ) Ultimate source: generic data updated with plant specific operational experience  
 Comment: Prior:mean NUREG 1205(1980),standby pump,80%/20% ratio based on RSS distrib.Same prior as for HPI pump.Op.exp.223 demands,no fail  
 Repair time is mean generic component maintenance duration.

# IAEA RELIABILITY DATA BASE



D Source category: generic

PMZSD pump motor driven include CCW,SW,RHR, boric acid transfer, boron injection recirc  
Component boundary: pump, shaft, motor, switches, local control & instrumentation Operating mode: alternating Operating environment: normal  
Generic failure mode: fail to start Original failure mode: fails to start  
FAILURE RATE OR PROBABILITY mean :  $5.3\text{E-}3/\text{d}$  :  $6.0\text{E-}4/\text{d}$  :  $5.0\text{E-}2/\text{d}$   
Source: NUREG 2886 (1982) (tbl.19) Ultimate source: plant operating experience-maintenance records (2PWR & 4BWR)  
Comment: Pop.102. 22 catastrophic demand related failures of 4148 demand Upbound & lowbound are largest and smallest rate of func.aggreg.  
of the pumps class.by driver type.Include altern.and stdby pumps

T1 Source category: generic

PMMST pump motor driven centrifugal horizontal and vertical  
Component boundary: pump, transmission, motor, breaker, fuse, protection, controls Operating mode: alternating Operating environment: normal  
Generic failure mode: fail to start Original failure mode: failure to start  
FAILURE RATE OR PROBABILITY mean :  $3.9\text{E-}3/\text{d}$  95%:  $2.1\text{E-}2/\text{d}$  REPAIR TIME: 10 hr  
Source: Swedish Rel.data book, tbl.5 Ultimate source: plant operating experience (7 BWR plants), ATV reports, LERs  
Comment: Operating experience: total pop. 66. Other data not known. Critical failures occurred at 6 plants.


T2 Source category: generic

PUSST pump motor driven screw  
Component boundary: pump, transmission, motor, switch, fuses, protection, controls Operating mode: alternating Operating environment: normal  
Generic failure mode: fail to start Original failure mode: failure to start  
FAILURE RATE OR PROBABILITY mean :  $2.5\text{E-}3/\text{d}$  95%:  $1.4\text{E-}2/\text{d}$  REPAIR TIME: 8 hours  
Source: Swedish Rel.data book, tbl.6 Ultimate source: plant operating experience (1 BWR plant), ATV reports, LERs  
Comment: Operating experience: total pop.7. No.of demands 399. 1 failure. a=0.164; b=65.2

P Source category: generic

PMBSP pump motor driven  
Component boundary: pumping unit, motor, coupling, mech.control.excl.MCC, breaker ect. Operating mode: alternating Operating environment: normal  
Generic failure mode: fail to start Original failure mode: does not start  
FAILURE RATE OR PROBABILITY median:  $3.4\text{E-}4/\text{d}$  95%:  $5.1\text{E-}4/\text{d}$  5%:  $2.3\text{E-}4/\text{d}$   
Source: NUREG 1205 (1982) (pg.305) Ultimate source: US plant LER report evaluation  
Comment: Overall data, include all types of reactors, LER-s from 1972 to 1980. Total pop.720 pumps. Total No.of failures 18. W/o command flt  
W.command faults  $1.4\text{E-}3/\text{d}$ . Stdby hourly rate  $1.4\text{E-}6/\text{hr}$ .

# IAEA RELIABILITY DATA BASE



A1 Source category: plant specific

PUCSA pump motor driven service water pump used in charging pump cooling system  
 Component boundary: detail n/a Operating mode: alternating Operating environment: normal  
 Generic failure mode: fail to start Original failure mode: fail to start  
 FAILURE RATE OR PROBABILITY median:  $5.9E-3/d$  ERROR FACTOR: 3.5  
 Source: NUREG 4550/Vol 3,tbl.IV.8-1 Ultimate source: Surry NPP operating experience  
 Comment:

H1 Source category: updated

PMXSH pump motor driven auxiliary feedwater pump  
 Component boundary: detail n/a Operating mode: alternating Operating environment: normal  
 Generic failure mode: fail to start Original failure mode: fail to start on demand  
 FAILURE RATE OR PROBABILITY mean:  $5.4E-3/d$  95%:  $1.1E-2/d$  5%:  $1.5E-3/d$   
 Source: Old PWR Ultimate source: generic data updated with plant operating experience  
 Comment: Generic mean  $3.3E-3/d$ . Operating experience 424 demands, 3 failures.

Z Source category: updated

PMXSZ pump motor driven auxiliary feedwater  
 Component boundary: DETAIL n/a Operating mode: alternating Operating environment: normal  
 Generic failure mode: fail to start Original failure mode: failure to start on demand  
 FAILURE RATE OR PROBABILITY mean:  $5.0E-3/d$   
 Source: ZION NPP PSS (tbl.1.5.1-5) Ultimate source: generic data updated with plant specific experience  
 Comment: Priors: NUREG 1205(tbl.14) standby system,does not start, w/o comm (mean)and WASH 1400(tbl.III 2-1)electric motor failure to start (distribution)Experience: 462 demands,4 failures

H2 Source category: updated

PUESH pump motor driven primary component cooling water pump  
 Component boundary: detail n/a Operating mode: alternating Operating environment: normal  
 Generic failure mode: fail to start Original failure mode: fail to start on demand  
 FAILURE RATE OR PROBABILITY mean:  $3.4E-3/d$  95%:  $5.2E-3/d$  5%:  $1.7E-3/d$   
 Source: Old PWR Ultimate source: generic data updated with plant operating experience  
 Comment: Generic mean  $2.4E-3/d$ . Operating experience 1840 demands, 7 failures.

A2 Source category: plant specific

PMHSA pump motor driven charging/high pressure injection  
 Component boundary: detail n/a Operating mode: alternating Operating environment: normal  
 Generic failure mode: fail to start Original failure mode: fail to start  
 FAILURE RATE OR PROBABILITY median:  $3.1E-3/d$  ERROR FACTOR: 3.5  
 Source: NUREG 4550/Vol.3,tbl.IV.8-1 Ultimate source: Surry NPP operating experience  
 Comment: Charging pumps provide normal RCS makeup and RCP cooling flow in normal operation and serve as a high pressure injection recirculation following accident.

H3 Source category: updated

PMKSH pump motor driven secondary service water pump  
 Component boundary: detail n/a Operating mode: alternating Operating environment: normal  
 Generic failure mode: fail to start Original failure mode: fail to start on demand  
 FAILURE RATE OR PROBABILITY mean:  $1.7E-3/d$  95%:  $3.8E-3/d$  5%:  $2.3E-4/d$   
 Source: Old PWR Ultimate source: generic data updated with plant operating experience  
 Comment: Generic mean  $2.4E-3/d$ . Operating experience 203 demands, no failures.

H4 Source category: updated

PUFSH pump motor driven secondary component cooling water  
 Component boundary: detail n/a Operating mode: alternating Operating environment: normal  
 Generic failure mode: fail to start Original failure mode: fail to start on demand  
 FAILURE RATE OR PROBABILITY mean :  $1.7E-3/d$  95%:  $3.9E-3/d$  5%:  $2.3E-4/d$   
 Source: Old PWR Ultimate source: generic data updated with plant operating experience  
 Comment: Generic mean  $2.4E-3/d$  Operating experience 193 demands, no failures.

H5 Source category: updated

PUBSH pump motor driven primary service water booster pump  
 Component boundary: detail n/a Operating mode: alternating Operating environment: normal  
 Generic failure mode: fail to start Original failure mode: fail to start on demand  
 FAILURE RATE OR PROBABILITY mean :  $1.6E-3/d$  95%:  $3.7E-3/d$  5%:  $2.2E-4/d$   
 Source: Old PWR Ultimate source: generic data updated with plant operating experience  
 Comment: Generic mean  $2.4E-3/d$  Operating experience 222 demands, no failures.

Y Source category: plant specific

PMMSY pump motor driven centrifugal horizontal and vertical  
 Component boundary: pump, transmission, motor, breaker, fuses, protection, controls Operating mode: alternating Operating environment: normal  
 Generic failure mode: fail to start Original failure mode: failure to start  
 FAILURE RATE OR PROBABILITY mean :  $1.4E-3/d$  REPAIR TIME: 24 hr  
 Source: Swedish Rel. data book, tbl.5 Ultimate source: plant operating experience (Ringhals 2 PWR)  
 Comment: 10 components observed, other information not available

H6 Source category: updated

PUKSH pump motor driven primary service water pump  
 Component boundary: detail n/a Operating mode: alternating Operating environment: normal  
 Generic failure mode: fail to start Original failure mode: fail to start on demand  
 FAILURE RATE OR PROBABILITY mean :  $1.3E-3/d$  95%:  $2.3E-3/d$  5%:  $3.9E-4/d$   
 Source: Old PWR Ultimate source: generic data updated with plant operating experience  
 Comment: Generic mean  $2.4E-3/d$  Operating experience 1909 demands, 2 failures.

H7 Source category: updated

PMHSH pump motor driven charging pump  
 Component boundary: detail n/a Operating mode: alternating Operating environment: normal  
 Generic failure mode: fail to start Original failure mode: fail to start on demand  
 FAILURE RATE OR PROBABILITY mean :  $1.2E-3/d$  95%:  $2.6E-3/d$  5%:  $1.4E-4/d$   
 Source: Old PWR Ultimate source: generic data updated with plant operating experience  
 Comment: Generic mean  $2.4E-3/d$  Operating experience 559 demands, no failures.


H8 Source category: updated

PURSH pump motor driven main steam relief hydraulic pump  
 Component boundary: detail n/a Operating mode: alternating Operating environment: normal  
 Generic failure mode: fail to start Original failure mode: fail to start on demand  
 FAILURE RATE OR PROBABILITY mean :  $6.9E-4/d$  95%:  $1.2E-3/d$  5%:  $2.6E-4/d$   
 Source: Old PWR Ultimate source: generic data updated with plant operating experience  
 Comment: Generic mean  $3.3E-3/d$  Operating experience 5636 demands, 3 failures.

0 Source category. updated

PMKSO pump motor driven low pressure service water  
Component boundary: detail n/a Operating mode: alternating Operating environment: normal  
Generic failure mode: fail to start Original failure mode: failure to start  
FAILURE RATE OR PROBABILITY mean :  $4.5E-4/d$  95%:  $1.3E-3/d$  5%:  $1.4E-5/d$  REPAIR TIME: 10.5 hours  
Source: Oconee NPP PRA (tbl.b-1.) Ultimate source: generic data updated with plant specific operating experience  
Comment: Prior: mean NUREG 1205(1980), standby pump,80%/20%ratio based on RSS. Op.experience: 61 demands, no failures.  
Repair time is mean of plant spec.update of maintenance duration.

# IAEA RELIABILITY DATA BASE





I(E) Source category: generic

PMURI pump motor driven  
 Component boundary: pump and motor excludes control circuits Operating mode: all Operating environment: extreme  
 Generic failure mode: fail to run Original failure mode: failure to run given start  
 FAILURE RATE OR PROBABILITY mean : 3.0E-3/hr max: 2.0E-2/hr min: 6.0E-5/hr ERROR FACTOR: 10  
 Source: IREP NUREG 2728 (tb.5.1-1) Ultimate source: expert opinion  
 Comment: Extreme operating environment is characterised with interface with heavy chemical environment-boric acid.

B(E) Source category: generic

PMURB pump motor driven  
 Component boundary: pump and motor,excludes control circuits Operating mode: all Operating environment: extreme  
 Generic failure mode: fail to run Original failure mode: failure to run, given start  
 FAILURE RATE OR PROBABILITY mean : 3.0E-3/hr max: 2.0E-2/hr min: 6.0E-5/hr  
 Source: NUREG 2815 (table C.1.) Ultimate source: expert opinion agregation and IREP data  
 Comment: Extreme operating environment characterise interface with heavy chemical environment-boric acid.

W(E) Source category: generic

PMURW pump motor driven  
 Component boundary: detail n/e, including motor Operating mode: all Operating environment: extreme, post accident inside containment  
 Generic failure mode: fail to run Original failure mode: failure to run given start  
 FAILURE RATE OR PROBABILITY median: 1.0E-3/hr 95%: 1.0E-2/hr 5%: 1.0E-4/hr ERROR FACTOR: 10  
 Source: WASH 1400 (table III 4-1) Ultimate source: assesed from test & resesarch reactors and military experience  
 Comment:

B Source category: generic

PMYRB pump motor driven  
 Component boundary: pump and motor, excludes control circuits Operating mode: all Operating environment: normal  
 Generic failure mode: fail to run Original failure mode: failure to run, given start  
 FAILURE RATE OR PROBABILITY mean : 1.0E-4/hr max: 5.0E-4/hr min: 2.0E-6/hr  
 Source: NUREG 2815 (table C.1.) Ultimate source: expert opinion agregation and IREP data  
 Comment:

U1 Source category: generic

PMIRU pump motor driven high pressure(> 20 bar)  
 Component boundary: detail n/a Operating mode: standby Operating environment: normal  
 Generic failure mode: fail to run Original failure mode: failure to continue operation  
 FAILURE RATE OR PROBABILITY mean : 6.0E-5/hr  
 Source: Sizewell B (PWR/RX312 pg.10) Ultimate source: assesed from nuclear and industrial experience and data  
 Comment: Assesement based on W data and 3 SRS data items. Two of them applies to RHR,HHSI and auxfeed ( 5.0E-5/hr and 1.0E-5/hr) and one to CVCS and CCWS (2.0E-5/hr).

J Source category: generic

PMARJ pump motor driven general  
 Component boundary: detail n/a Operating mode: all Operating environment: normal  
 Generic failure mode: fail to run Original failure mode: fails to run  
 FAILURE RATE OR PROBABILITY mean : 3.0E-5/hr ERROR FACTOR: 10  
 Source: NUREG 4550, Vol.1,tbl.VIII.1-2 Ultimate source: assesed from several nuclear data sources  
 Comment: ASEP used the generic values developed in the Station Blackout Study (NUREG/CR 3226).

W Source category: generic

PMYRW pump motor driven  
 Component boundary: detail n/a, include motor Operating mode: all Operating environment: normal  
 Generic failure mode: fail to run Original failure mode: failure to run given start  
 FAILURE RATE OR PROBABILITY median:  $3.0E-5/hr$  95%:  $3.0E-4/hr$  5%:  $3.0E-6/hr$  ERROR FACTOR: 10  
 Source: WASH 1400 (table III 4-1) Ultimate source: assessed from nuclear, industrial and military experience and data  
 Comment:

X Source category: generic

PMARX pump motor driven general  
 Component boundary: detail n/a Operating mode: all Operating environment: normal  
 Generic failure mode: fail to run Original failure mode: failure to run  
 FAILURE RATE OR PROBABILITY mean:  $3.0E-5/hr$  80%:  $9.0E-5/hr$  20%:  $7.5E-6/hr$   
 Source: VVER reliability data base Ultimate source: expert opinion, operating experience  
 Comment:

I Source category: generic

PMYRI pump motor driven  
 Component boundary: pump and motor, exclude control circuits Operating mode: all Operating environment: normal  
 Generic failure mode: fail to run Original failure mode: failure to run given start  
 FAILURE RATE OR PROBABILITY mean:  $3.0E-5/hr$  ERROR FACTOR: 10  
 Source: IREP NUREG 2728 (tb.5 1-1) Ultimate source: expert opinion  
 Comment:

U2 Source category: generic


PULRU pump motor driven low pressure <20 bar  
 Component boundary: detail n/a Operating mode: all Operating environment: normal  
 Generic failure mode: fail to run Original failure mode: failure to continue operation  
 FAILURE RATE OR PROBABILITY mean:  $1.5E-5/hr$   
 Source: Sizewell B (PWR/RX312 pg.11) Ultimate source: assessed from nuclear and industrial experience and data  
 Comment: Assesment based on W data, 4 EDF data items ( $1.2E-4/hr$  ESW pumps) ( $6.8E-6/hr$  CCW), ( $5.6E-6/hr$  cond.extraction), ( $3.5E-6/hr$  cond.cool.), 2 SRS items (industrial use) ( $2.1E-4(1E5hrs)$  and  $1.8E-5(5E5hrs)$ ).

S Source category: generic

PMYRS pump motor driven  
 Component boundary: pump and motor Operating mode: all Operating environment: normal  
 Generic failure mode: fail to run Original failure mode: failure to run  
 FAILURE RATE OR PROBABILITY mean:  $7.9E-6/hr$   
 Source: Shoreham PRA, GE data (tb.A 2-1) Ultimate source: evaluation of BWR operating experience  
 Comment: From the data tables it is assumed that the given value include failure for pump to start and to continue running.

## IAEA RELIABILITY DATA BASE

Motor driven pump, fail to run, operating mode all  
(updated sources)



H1 Source category: updated

PMGRH pump motor driven electrical equipment area ventilation cooling pump  
Component boundary: detail n/a Operating mode: all Operating environment: normal  
Generic failure mode: fail to run Original failure mode: fail during operation  
FAILURE RATE OR PROBABILITY mean : 4.7E-5/hr 95%: 7.4E-5/hr 5%: 2.2E-5/hr  
Source: Old PWR Ultimate source: generic data updated with plant operating experience  
Comment: Generic mean 3.4E-5/hr. Operating experience 1.3E+5 hours of operation, 7 failures.

H2 Source category: updated


PJZRH pump motor driven recirculation pump  
Component boundary: detail n/a Operating mode: all Operating environment: normal  
Generic failure mode: fail to run Original failure mode: fail during operation  
FAILURE RATE OR PROBABILITY mean : 3.4E-5/hr 95%: 8.1E-5/hr 5%: 2.8E-6/hr REPAIR TIME: 4.2 hours  
Source: Old PWR Ultimate source: generic data updated with plant operating experience  
Comment: Generic mean 3.4E-5/hr. Operating experience 56 hours of operation, no failures. Repair time is mean of 14 maintenance events.

H3 Source category: updated

PUVRH pump motor driven well water pump  
Component boundary: detail n/a Operating mode: all Operating environment: normal  
Generic failure mode: fail to run Original failure mode: fail during operation  
FAILURE RATE OR PROBABILITY mean : 3.4E-5/hr 95%: 8.0E-5/hr 5%: 2.8E-6/hr  
Source: Old PWR Ultimate source: generic data updated with plant operating experience  
Comment: Generic mean 3.4E-5/hr. Operating experience 108 hours, no failures.

# IAEA RELIABILITY DATA BASE

Motor driven pump, fail to run, operating mode standby  
(updated sources)



01 Source category: updated

PMLRO pump motor driven low pressure injection  
 Component boundary: detail n/a Operating mode: standby Operating environment: normal  
 Generic failure mode: fail to run Original failure mode: operational failure  
 FAILURE RATE OR PROBABILITY mean : 3.7E-5/hr 95%: 9.5E-5/hr 5%: 2.5E-6/hr REPAIR TIME: 10.8 hours  
 Source: Oconee NPP PRA (tbl.b-1.) Ultimate source: generic data updated with plant specific operating experience  
 Comment: Prior:mean NUREG 1205(1980),alternating pump,80%/20% ratio based on RSS.Same prior as for HPI pump.Op.experience:11.287 op.hrs,  
 1 failure.Repair time is mean of generic maintenance duration.

H1 Source category: updated

PMSRH pump motor driven safety injection pump  
 Component boundary: detail n/a Operating mode: standby Operating environment: normal  
 Generic failure mode: fail to run Original failure mode: fail during operation  
 FAILURE RATE OR PROBABILITY mean : 3.6E-5/hr 95%: 7.8E-5/hr 5%: 2.8E-6/hr REPAIR TIME: 4.8 hours  
 Source: Old PWR Ultimate source: generic data updated with plant specific operating experience  
 Comment: Generic mean 3.4E-5/hr. Operating experience 272 hours of operation, no failures. Repair time is mean of 21 recorded  
 maintenance events.

H2 Source category: updated

PMCRH pump motor driven containment spray  
 Component boundary: detail n/a Operating mode: standby Operating environment: normal  
 Generic failure mode: fail to run Original failure mode: fail during operation  
 FAILURE RATE OR PROBABILITY mean : 3.4E-5/hr 95%: 7.8E-5/hr 5%: 2.8E-6/hr REPAIR TIME: 6.6 hours  
 Source: Old PWR Ultimate source: generic data updated with plant operating experience  
 Comment: Generic mean 3.4E-5/hr. Operating experience 209 hours of operation, no failures. Repair time is mean of 16 maintenance  
 events.

02 Source category: updated

PMCRO pump motor driven reactor building spray  
 Component boundary: detail n/a Operating mode: standby Operating environment: normal  
 Generic failure mode: fail to run Original failure mode: operational failure  
 FAILURE RATE OR PROBABILITY mean : 2.0E-5/hr 95%: 6.0E-5/hr 5%: 5.9E-7/hr REPAIR TIME: 28.6 hours  
 Source: Oconee NPP PRA (tbl.b-1.) Ultimate source: generic data updated with plant specific operating experience  
 Comment: Prior:mean NUREG 1205(1980),alternating pump,ratio of 80%/20% is based on RSS distrib.Same as for injection pumps.Op.exp.40 hrs  
 of operation,no failures Repair time is mean maintenance duration

03 Source category: updated

PMFRO pump motor driven emergency feedwater pump  
 Component boundary: detail n/a Operating mode: standby Operating environment: normal  
 Generic failure mode: fail to run Original failure mode: operational failure  
 FAILURE RATE OR PROBABILITY mean : 2.0E-5/hr 95%: 6.0E-5/hr 5%: 5.9E-7/hr REPAIR TIME: 20.9 hours  
 Source: Oconee NPP PRA (tbl.b-1.) Ultimate source: generic data updated with plant specific operating experience  
 Comment: Prior:mean NUREG 1205(1980),alternating pump,80%/20% based on RSS distribution Same prior as injection pumps.Op.exper:15 op.hrs,  
 no failures.Repair time is mean generic maintenance duration.


Z Source category: edited

PMCRZ pump motor driven containment spray  
 Component boundary: detail n/a Operating mode: standby Operating environment: normal  
 Generic failure mode: fail to run Original failure mode: fail during operation  
 FAILURE RATE OR PROBABILITY mean :  $1.5E-5/hr$   
 Source: ZION NPP PSS (tbl.1.5.1-5) Ultimate source: generic data updated with plant specific experience  
 Comment: Priors:NUREG 1205,alternating system,does not operate given start (mean) and WASH 1400, pump(w/o motor),failure to run(distrib.)  
 Operating experience:66 hours of operation,no failures

04 Source category: updated

PMVRO pump motor driven high pressure injection  
 Component boundary: detail n/a Operating mode: standby Operating environment: normal  
 Generic failure mode: fail to run Original failure mode: operational failure  
 FAILURE RATE OR PROBABILITY mean :  $8.4E-6/hr$  95%:  $2.0E-5/hr$  5%:  $4.4E-7/hr$  REPAIR TIME: 21.5 hours  
 Source: Oconee NPP PRA (tbl.b-1.) Ultimate source: generic data updated with plant specific operating experience  
 Comment: Prior:Mean NUREG 1205(1980),alternating pump,80%/20% ratio based on RSS.Op.experience: 38.787 hours of operation, no failures.  
 Repair time is mean of updated component maintenance duration.

# IAEA RELIABILITY DATA BASE





D Source category: generic

PMZRD pump motor driven include CCW,SW,RHR,boric acid transfer,boron injection recirc.  
Component boundary: pump,shaft motor switches,local control and instrumentation Operating mode: alternating Operating environment: normal  
Generic failure mode: fail to run Original failure mode: fails while running  
FAILURE RATE OR PROBABILITY mean : 2.7E-5/hr : 3.0E-4/hr : 1.0E-6/hr  
Source: NUREG 2886 (1982)(tbl.18 & 19) Ultimate source: plant operating experience-maintenance records(2PWR & 4BWR)  
Comment: Pop.102.33 catastrophic failures of 1.24E+6 population hours Upbound and lowbound identical as running pumps(see comment).


P Source category: generic

PMBRP pump motor driven  
Component boundary: pumping unit,coupling,motor,mech.control.Excl.MCC,breakers Operating mode: alternating Operating environment: normal  
Generic failure mode: fail to run Original failure mode: does not operate given start  
FAILURE RATE OR PROBABILITY median: 1.8E-5/hr 95%: 2.0E-5/hr 5%: 1.6E-5/hr  
Source: NUREG 1205 (1982) (pg.340) Ultimate source: US plant LER report evaluation  
Comment: Overall data (PWR&BWR)LER from72 to 80.Ttl pop.720,no.of fail 110 W/o command faults(w.command faults 2.1E-5).F.mode does not operate incl:leakage/rupt.ls.of function,does not cont.to run

T Source category: generic

PMMRT pump motor driven centrifugal horizontal and vertical  
Component boundary: pump,transmission,motor,breaker,fuse protection,controls Operating mode: alternating Operating environment: normal  
Generic failure mode: fail to run Original failure mode: spurious stop  
FAILURE RATE OR PROBABILITY mean : 1.7E-5/hr 95%: 8.4E-5/hr REPAIR TIME: 10 hr  
Source: Swedish Rel.data book, tbl.5 Ultimate source: plant operating experience (7 BWR plants),ATV reports,LERs  
Comment: Operating experience:Total pop.66. Operational time 78.6E+4 hours 13 failures. a=0.21; b=12700. Critical failures occurred at 6 plants.

# IAEA RELIABILITY DATA BASE



H1 Source category: updated

PMHRH pump motor driven charging pump  
 Component boundary: detail n/a Operating mode: alternating Operating environment: normal  
 Generic failure mode: fail to run Original failure mode: fail during operation  
 FAILURE RATE OR PROBABILITY mean : 2.7E-4/hr 95%: 3.4E-4/hr 5%: 2.0E-4/hr REPAIR TIME: 16 hours  
 Source: Old PWR Ultimate source: generic data updated with plant operating experience  
 Comment: Generic mean 3.4E-5/hr. Operating experience 1.3E+5 hours of operation, 38 failures. Repair time is mean of 168 recorded maintenance events(short single pump outage).Long outage=667 hrs.

A1 Source category: plant specific

PUCRA pump motor driven service water pump used in charging pump cooling system  
 Component boundary: detail n/a Operating mode: alternating Operating environment: normal  
 Generic failure mode: fail to run Original failure mode: fail to run  
 FAILURE RATE OR PROBABILITY median: 1.6E-4/hr ERROR FACTOR: 1.6  
 Source: NUREG 4550/Vol 3,tbl.IV.8-1 Ultimate source: Surry NPP operating experience  
 Comment:

H2 Source category: updated

PUWRH pump motor driven residual heat removal pump  
 Component boundary: detail n/a Operating mode: alternating Operating environment: normal  
 Generic failure mode: fail to run Original failure mode: fail during operation  
 FAILURE RATE OR PROBABILITY mean : 1.1E-4/hr 95%: 2.4E-4/hr 5%: 2.5E-5/hr REPAIR TIME: 4.8 hours  
 Source: Old PWR Ultimate source: generic data updated with plant operating experience  
 Comment: Generic mean 3.4E-5/hr. Operating experience 1.4E+4 hours of operation, 3 failures. Repair time is mean of 2 maintenance event (short duration). Long duration maintenance 6.1E+3 hours??

Z1 Source category: updated

PMXRZ pump motor driven auxiliary feedwater  
 Component boundary: detail n/a Operating mode: alternating Operating environment: normal  
 Generic failure mode: fail to run Original failure mode: fail during operation  
 FAILURE RATE OR PROBABILITY mean : 9.9E-5/hr  
 Source: ZION NPP PSS (tbl.1.5.1-5) Ultimate source: generic data updated with plant specific operating experience  
 Comment: Priors:NUREG 1205 alternating system,does not operate given start (mean) and WASH 1400 pump(w/o motor)failure to run(distrib). Operating experience:3800 hours of operation, 1 failure.

Y1 Source category: plant specific

PMMRY pump motor driven centrifugal, horisontal and vertical  
 Component boundary: pump,transmission,motor,breaker,fuses,protection,controls Operating mode: alternating Operating environment: normal  
 Generic failure mode: fail to run Original failure mode: spurious stop  
 FAILURE RATE OR PROBABILITY mean : 8.1E-5/hr REPAIR TIME: 24 hr  
 Source: Swedish Rel.data book, tbl.5 Ultimate source: plant operating experience (Ringhals 2 PWR)  
 Comment: Operating experience.total pop.10. Operating time 8.67E+4 hours 7 failures

H3 Source category: updated

PUBRH pump motor driven primary service water booster pump  
 Component boundary: detail n/a Operating mode: alternating Operating environment: normal  
 Generic failure mode: fail to run Original failure mode: fail during operation  
 FAILURE RATE OR PROBABILITY mean : 6.4E-5/hr 95%: 1.0E-4/hr 5%: 2.8E-5/hr REPAIR TIME: 12.1  
 Source: Old PWR Ultimate source: generic data updated with plant operating experience  
 Comment: Generic mean 3.4E-5/hr. Operating experience 9.2E+4 hours of operation, 7 failures. Repair time is mean of 17 maintenance events.

H4 Source category: updated

PMXRH pump motor driven auxiliary feedwater pump  
 Component boundary: detail n/a Operating mode: alternating Operating environment: normal  
 Generic failure mode: fail to run Original failure mode: fail during operation  
 FAILURE RATE OR PROBABILITY mean : 5.9E-5/hr 95%: 1.7E-4/hr 5%: 8.9E-6/hr REPAIR TIME: 5.5 hours  
 Source: Old PWR Ultimate source: generic data updated with plant operating experience  
 Comment: Generic mean 3.4E-5/hr. Operating experience 5641 hour of operation, 1 failure. Repair time is mean of 27 maintenance events.

H5 Source category: updated

PUKRH pump motor driven primary service water pump  
 Component boundary: detail n/a Operating mode: alternating Operating environment: normal  
 Generic failure mode: fail to run Original failure mode: fails during operation  
 FAILURE RATE OR PROBABILITY mean : 5.5E-5/hr 95%: 9.2E-5/hr 5%: 2.7E-5/hr REPAIR TIME: 17.4 hours  
 Source: Old PWR Ultimate source: generic data updated with plant operating experience  
 Comment: Generic mean 3.4E-5/hr. Operating experience 1.6E+5 hours of operation, 10 failures. Repair time is mean of 46 maintenance events.

H6 Source category: updated

PMKRH pump motor driven secondary service water  
 Component boundary: detail n/a Operating mode: alternating Operating environment: normal  
 Generic failure mode: fail to run Original failure mode: fail during operation  
 FAILURE RATE OR PROBABILITY mean : 5.5E-5/hr 95%: 8.6E-5/hr 5%: 2.5E-5/hr REPAIR TIME: 32.5 hours  
 Source: Old PWR Ultimate source: generic data updated with plant operating experience  
 Comment: Generic mean 3.4E-5/hr. Operating experience 1.4E+5 hours of operation, 9 failures. Repair time is mean of 17 maintenance events.

A2 Source category: plant specific

PMHRA pump motor driven charging/high pressure injection  
 Component boundary: detail n/a Operating mode: alternating Operating environment: normal  
 Generic failure mode: fail to run Original failure mode: fail to run  
 FAILURE RATE OR PROBABILITY median: 5.5E-5/hr ERROR FACTOR: 2.9  
 Source: NUREG 4550/Vol 3, tbl. IV.8-1 Ultimate source: Surry NPP operating experience  
 Comment: Charging pump provide RCS makeup and RPS seal cooling flow in normal operation and serve as a high pressure injection/recirculation pump following accident.

Y2 Source category: plant specific

PUSRY pump motor driven screw  
 Component boundary: pump, transmission, motor, breaker, fuse, protection, control Operating mode: alternating Operating environment: normal  
 Generic failure mode: fail to run Original failure mode: spurious stop  
 FAILURE RATE OR PROBABILITY mean : 3.1E-5/hr REPAIR TIME: 32 hr  
 Source: Swedish Rel. data book, tbl. 6 Ultimate source: plant operating experience (Ringhals 2 PWR)  
 Comment: Operating experience: total pop. 6 Operating time 12.97E+4 hours 4 failures.  
 No failure to start recorded on this component.

O Source category: updated

PMKRO pump motor driven low pressure service water  
 Component boundary: detail n/a Operating mode: alternating Operating environment: normal  
 Generic failure mode: fail to run Original failure mode: operational failure  
 FAILURE RATE OR PROBABILITY mean : 2.8E-5/hr 95%: 5.6E-5/hr 5%: 4.1E-6/hr REPAIR TIME: 10.5 hours  
 Source: Oconee NPP PRA (tbl. b-1 ) Ultimate source: generic data updated with plant specific operating experience  
 Comment: Prior mean NUREG 1205(1980), alternating pump, 80%/20% ratio based on RSS Op experience: 47,991 hours of operation, 2 failures.  
 Repair time is mean of plant spec. update of maintenance duration.

Z2 Source category. updated

PMSRZ pump motor driven safety injection pump  
Component boundary: detail n/a Operating mode: alternating Operating environment: normal  
Generic failure mode: fail to run Original failure mode: fail during operation  
FAILURE RATE OR PROBABILITY mean : 1.6E-5/hr  
Source: ZION NPP PSS (tbl.1.5.1-5) Ultimate source: generic data updated with plant specific experience  
Comment: Prior: NUREG 1205,alternating system,does not operate given start (M) and WASH 1400,pump (w/o motor),fail to run(distrib.)  
Operating experience: 46 hours of operation, no failures.

H7 Source category: updated

PUERH pump motor driven primary component cooling water pump  
Component boundary: detail n/a Operating mode: alternating Operating environment: normal  
Generic failure mode: fail to run Original failure mode: fail during operation  
FAILURE RATE OR PROBABILITY mean : 1.4E-5/hr 95%: 2.5E-5/hr 5%: 3.9E-6/hr REPAIR TIME: 8 hours  
Source: Old PWR Ultimate source: generic data updated with plant operating experience  
Comment: Generic mean 3.4E-5/hr. Operating experience 1.7E+5 hours of operation, 2 failures. Repair time is mean of 14 maintenance events.

H8 Source category: updated

PUFRH pump motor driven secondary component cooling water  
Component boundary: detail n/a Operating mode: alternating Operating environment: normal  
Generic failure mode: fail to run Original failure mode: fail during operation  
FAILURE RATE OR PROBABILITY mean : 7.3E-6/hr 95%: 1.6E-5/hr 5%: 1.3E-6/hr REPAIR TIME: 73.8 hours  
Source: Old PWR Ultimate source: generic data updated with plant operating experience  
Comment: Generic mean 3.4E-5/hr. Operating experience 1.4E+5 hours of operation, no failures. Repair time is mean of 7 maintenance events.

Z3 Source category: updated

PUWRZ pump motor driven residual heat removal pump  
Component boundary: detail n/a Operating mode: alternating Operating environment: normal  
Generic failure mode: fail to run Original failure mode: fail during operation  
FAILURE RATE OR PROBABILITY mean : 2.5E-6/hr  
Source: ZION NPP PSS (tbl.1.5.1-5) Ultimate source: generic data updated with plant specific experience  
Comment: Priors:NUREG 1205 alternating system,does not operate given start (mean) and WASH 1400,pump(w/o motor),failure to run(distrib.).  
Operating experience:3.25E+4 hrs of operation, no failures.

Z4 Source category. updated

PMHRZ pump motor driven centrifugal charging pump  
Component boundary: detail n/a Operating mode: alternating Operating environment: normal  
Generic failure mode: fail to run Original failure mode: fail during operation  
FAILURE RATE OR PROBABILITY mean : 1.8E-6/hr  
Source: ZION NPP PSS (tbl.1.5.1-5) Ultimate source: generic data updated with plant specific experience  
Comment: Priors:NUREG 1205,Alternating sys.,motor driven,does not operate given strt(M); WASH 1400,pumps,fail to run,extreme environment(D)  
Operating experience:7.6E+4 hours of operation, no failures

Z5 Source category: updated

PMERZ pump motor driven component cooling  
Component boundary: detail n/a Operating mode: alternating Operating environment: normal  
Generic failure mode: fail to run Original failure mode: fail during operation  
FAILURE RATE OR PROBABILITY mean : 1.8E-6/hr  
Source: ZION NPP PSS (tbl.1.5.1-5) Ultimate source: generic data upgraded with plant specific experience  
Comment: Priors:NUREG 1205,alternating system,does not operate given start, (Mean) and WASH 1400 pump(w/o motor) failure to run (Distrib.).  
Operating experience:7.6E+4 hrs of operation,no failures.

Z6 Source category: updated

PMKRZ pump motor driven service water


Component boundary: detail n/a Operating mode: alternating Operating environment: normal  
Generic failure mode: fail to run Original failure mode: fail during operation

FAILURE RATE OR PROBABILITY mean :  $1.3E-6/hr$

Source: ZION NPP PSS (tbl 1.5.1-5) Ultimate source: generic data updated with plant specific experience

Comment: Priors:NUREG 1205,alternating system,does not operate given start (mean) and WASH 1400, pump(w/o motor),failure to run(distrib).  
Operating experience:  $1.52E+5$  hours of operation,no failures

# IAEA RELIABILITY DATA BASE



U Source category: generic

PUMRU pump motor driven main feed pumps  
 Component boundary: detail n/a Operating mode: running Operating environment: normal  
 Generic failure mode: fail to run Original failure mode: failure to continue operation  
 FAILURE RATE OR PROBABILITY mean : 8.0E-4/hr  
 Source: Sizewell B (PWR/RX312 pg.8) Ultimate source: assessed from nuclear and industrial experience and data  
 Comment: Assessment based on W data, CEGB data item, EDF PWR data (3.1E-4/hr out of 4.2E+6 hrs) and 2 SRS data items (7.4E-4/hr) and (1.7E-3/hr based on operating experience 2.5E+5 hr).

T1 Source category: generic

PMWRT pump motor driven centrifugal wet  
 Component boundary: pump, transmission, motor, breakers, fuses, protection, controls Operating mode: running Operating environment: normal  
 Generic failure mode: fail to run Original failure mode: spurious stop  
 FAILURE RATE OR PROBABILITY mean : 7.8E-5/hr 95%: 1.9E-4/hr REPAIR TIME: 18 hr  
 Source: Swedish Rel. data book, tbl.3 Ultimate source: plant operating experience (7 BWR plants), ATV reports, LERS  
 Comment: Operating experience: total pop 14. Operating time 27.2E+4 hours 19 failures. a=1.93; b=24900. Critical failures occurred at 6 plants.

T2 Source category: generic

PMNRT pump motor driven centrifugal horizontal  
 Component boundary: pump, transmission, motor, breaker, fuses, protection, controls Operating mode: running Operating environment: normal  
 Generic failure mode: fail to run Original failure mode: spurious stop  
 FAILURE RATE OR PROBABILITY mean : 2.8E-5/hr 95%: 1.1E-4/hr REPAIR TIME: 11 hr  
 Source: Swedish Rel. data book, tbl.1 Ultimate source: plant operating experience (7 BWR plants), ATV reports, LERS  
 Comment: Operating experience: total pop. 14. operating time 28.8E+4 hours 8 failures. a=0.0527; b=19000. Critical failures occurred at 4 plants.

T3 Source category: generic

PMDRT pump motor driven centrifugal horizontal  
 Component boundary: pump, transmission, motor, breaker, fuse, protection, controls Operating mode: running Operating environment: normal  
 Generic failure mode: fail to run Original failure mode: spurious stop  
 FAILURE RATE OR PROBABILITY mean : 2.3E-5/hr 95%: 1.0E-4/hr REPAIR TIME: 18 hr  
 Source: Swedish Rel. data book, tbl.2 Ultimate source: plant experience (6 BWR plants), ATV reports, LERS, plant inform.  
 Comment: Operating experience: total pop. 16. Operating time 18.1E+4 hours 5 failures. a=0.315; b=13800. Critical failures occurred at 3 plants.

D Source category: generic

PMJRD pump motor driven includes reactor coolant, reactor recirculating, CW, feedwater, cond.  
 Component boundary: pump, shaft, motor, switches, local control & instrumentation Operating mode: running Operating environment: normal  
 Generic failure mode: fail to run Original failure mode: fails while running  
 FAILURE RATE OR PROBABILITY mean : 2.2E-5/hr : 3.0E-4/hr : 1.0E-6/hr  
 Source: NUREG 2886 (1982) (tbl.18 & 19) Ultimate source: plant operating experience-maintenance records (2PWR & 4BWR)  
 Comment: Pop. 79. 35 catastrophic time related failures of 1.6E+6 operating hours. Upbound and lowbound are the largest and smallest rate of funct. aggregation by driver.

P Source category: generic

PMRRP pump motor driven  
 Component boundary: pumping unit, motor, coupling, mech, control. Excl. MCC, breakers ect Operating mode: running Operating environment: normal  
 Generic failure mode: fail to run Original failure mode: does not operate given start  
 FAILURE RATE OR PROBABILITY median: 5.3E-6/hr 95%: 6.9E-6/hr 5%: 4.1E-6/hr  
 Source: NUREG 1205 (1982) (pg.292) Ultimate source: US plant LER report evaluation  
 Comment: Overall data (PWR & BWR) LER from 72 to 80. Tot. pop. 209, no of fail. 12 W/o command faults (w. command faults 1.4E-5). Fmode "does not operate" incl: leakage/rupt, ls of function, does not cont. to run



T4 Source category: generic

PMPRT pump motor driven centrifugal reactor coolant pump  
 Component boundary: pump,transmission,motor,breaker,fuses,protection,controls Operating mode: running Operating environment: normal  
 Generic failure mode: fail to run Original failure mode: spurious stop  
 FAILURE RATE OR PROBABILITY mean :  $2.7E-6/hr$  95%:  $1.5E-5/hr$  REPAIR TIME: 5 hr  
 Source: Swedish Rel.data book, tbl.4 Ultimate source: plant operating experience (7 BWR plants), ATV reports, LERs  
 Comment: Operating experience: total pop. 38.Operating time  $112E+4$  hours. No.of failures 3.  $a=0.0671$ ;  $b=25100$ . Critical failures occurred at 3 plants.


Y1 Source category: updated

PMWRY pump motor driven centrifugal wet  
 Component boundary: pump,transmission,motor,breaker,fuse,protection,controls Operating mode: running Operating environment: normal  
 Generic failure mode: fail to run Original failure mode: spurious stop  
 FAILURE RATE OR PROBABILITY mean :  $1.2E-4/hr$  REPAIR TIME: 24 hr  
 Source: Swedish Rel.data book, tbl.3 Ultimate source: plant operating experience (Ringhals 2 PWR)  
 Comment: Operating experience: total pop 2. Operating time  $2.56E+4$  hours 3 failures.

Y2 Source category: updated

PMNRY pump motor driven centrifugal,horisontal  
 Component boundary: pump,transmission,motor,breaker,fuse,protection,controls Operating mode: running Operating environment: normal  
 Generic failure mode: fail to run Original failure mode: spurious stop  
 FAILURE RATE OR PROBABILITY mean :  $6.9E-5/hr$  REPAIR TIME: 3 hr  
 Source: Swedish Rel.data book, tbl.1 Ultimate source: plant operating experience (Ringhals 2 PWR)  
 Comment: Operating experience: total pop.2 Operational time  $4.32E+4$  hours 3 failures.

# IAEA RELIABILITY DATA BASE



B Source category: generic

PTYSB pump turbine driven  
Component boundary: pump,turbine,steam and throttle valves,governor Operating mode: all Operating environment: normal  
Generic failure mode: fail to start Original failure mode: failure to start  
FAILURE RATE OR PROBABILITY mean : 3.6E-2/d max: 1.8E-1/d min: 7.2E-4/d  
Source: NUREG 2815 (table C.1.) Ultimate source: expert opinion aggregation and IREP data  
Comment: Failure mode includes under and over speed Org.time related value changed to demand related assuming monthly tests.

I Source category: generic

PTYSI pump turbine driven  
Component boundary: pump,turbine,steam and throttle valves,governor Operating mode: all Operating environment: normal  
Generic failure mode: fail to start Original failure mode: failure to start  
FAILURE RATE OR PROBABILITY mean : 3.0E-2/d ERROR FACTOR: 10  
Source: IREP NUREG 2728 (tb.5.1-1) Ultimate source: expert opinion  
Comment: Failure mode includes under and overspeed

J Source category:

PTASJ pump turbine driven general  
Component boundary: detail n/a Operating mode: all Operating environment: normal  
Generic failure mode: fail to start Original failure mode: fails to start  
FAILURE RATE OR PROBABILITY mean : 3.0E-2/d ERROR FACTOR: 10  
Source: NUREG 4550, Vol.1,tbl.VIII.1-2 Ultimate source: assessed from several nuclear data sources  
Comment: ASEP used generic value from IREP Procedure Guide.The value for fails to start incl.two types of failures:circuit breaker command faults(2.0E-2) and pump hardware(1.0E-2).

U Source category: generic

PTSSU pump turbine driven high pressure > 20 bar  
Component boundary: detail n/a Operating mode: all Operating environment: normal  
Generic failure mode: fail to start Original failure mode: failure to start  
FAILURE RATE OR PROBABILITY mean : 2.0E-2/d  
Source: Sizewell B (PWR/RX312 pg.12) Ultimate source: assessed from nuclear and industrial experience and data  
Comment: Assessment based on W data and SRS data item relevant for PWR (1.0E-2/d )


D Source category: generic

PTASD pump turbine driven  
Component boundary: pump,shaft,turbine,local instrumentation and control Operating mode: standby Operating environment: normal  
Generic failure mode: fail to start Original failure mode: fails to start  
FAILURE RATE OR PROBABILITY mean : 1.1E-2/d : 3.0E-2/d : 2.0E-3/d  
Source: NUREG 2886 (1982) (tbl 19) Ultimate source: plant operating experience-maintenance records(2PWR & 4BWR)  
Comment: Pop.11. 5 catastrophic demand related failures in 469 demands. Upbound and lowbound are the largest and smallest failure rate of the functional aggregate of selected pumps classified by driver

P Source category: generic

PTASP pump turbine driven  
Component boundary: Incl.mech.control,governor,trip-throt.vlv,lube oil sys,bearing lb Operating mode: standby Operating environment: normal  
Generic failure mode: fail to start Original failure mode: does not start  
FAILURE RATE OR PROBABILITY median: 9.6E-3/d 95%: 1.2E-2/d 5%: 8.0E-3/d  
Source: NUREG 1205 (1982) (pg.372) Ultimate source: US plant LER report evaluation  
Comment: Overall data,including all types of reactors,LER 72-80. Ttl.pop. 92. W/o command faults.With command faults 2.5E-2. Standby hour rate w/o command 1.9E-5/hr, with command faults 5.1E-5/hr.

## IAEA RELIABILITY DATA BASE



0 Source category: updated

PTXSO pump turbine driven emergency feedwater  
Component boundary: detail n/a Operating mode: standby Operating environment: normal  
Generic failure mode: fail to start Original failure mode: failure to start  
FAILURE RATE OR PROBABILITY mean :  $3.8E-2/d$  95%:  $5.8E-2/d$  5%:  $1.2E-2/d$  REPAIR TIME: 24.5 hours  
Source: Oconee NPP PRA (tbl.b-1.) Ultimate source: generic data updated with plant specific operating experience  
Comment: Prior:mean NUREG 1205(1980),standby pump.80%/20% ratio based on RSS distribution.Op.experience: 113 demands,6 failures.  
Repair time is mean of plant spec.update of maintenance duration.

Y Source category: updated

PTCSY pump turbine driven centrifugal pump  
Component boundary: auxiliary equipment not included Operating mode: standby Operating environment: normal  
Generic failure mode: fail to start Original failure mode: failure to start  
FAILURE RATE OR PROBABILITY mean :  $3.3E-2/d$  REPAIR TIME: 8 hr  
Source: Swedish Rel.data book, tbl.9 Ultimate source: plant operating experience (Ringshals 2 PWR)  
Comment: One observed component, 30 demands per operational time, one failure recorded.


Z Source category: updated

PTFSZ pump turbine driven auxiliary feedwater  
Component boundary: detail n/a Operating mode: standby Operating environment: normal  
Generic failure mode: fail to start Original failure mode: failure to start on demand  
FAILURE RATE OR PROBABILITY mean :  $2.3E-2/d$   
Source: ZION NPP PSS (tbl.1.5.1-5) Ultimate source: generic data updated with plant specific experience  
Comment: Prior:NUREG 1205,standby system(w/o command) does not start(Mean) Distribution based on engineering judgement.  
Operating experience: 231 demands, 6 failures.

A Source category. plant specific

PTFSA pump turbine driven auxiliary feedwater  
Component boundary: detail n/a Operating mode: standby Operating environment: normal  
Generic failure mode: fail to start Original failure mode: fail to start/run  
FAILURE RATE OR PROBABILITY median:  $7.1E-3/d$  ERROR FACTOR: 4.6  
Source: NUREG 4550/Vol.3,tbl.IV.8-1 Ultimate source: Surry NPP operating experience  
Comment: It was not possible to identify failure mode as appear in table.

# IAEA RELIABILITY DATA BASE



0 Source category: updated

PTXRO pump turbine driven emergency feedwater pump  
 Component boundary: detail n/a Operating mode: standby Operating environment: normal  
 Generic failure mode: fail to run Original failure mode: operational failure  
 FAILURE RATE OR PROBABILITY mean :  $9.9E-4/hr$  95%:  $4.0E-3/hr$  5%:  $4.1E-6/hr$  REPAIR TIME: 24.5 hours  
 Source: Oconee NPP PRA (tbl.b-1.) Ultimate source: generic data updated with plant specific operating experience  
 Comment: Prior:mean NUREG 1205(1980),alternating pump.80%/20% ratio =100 Operating experience:94 hours of operation,1 failure.  
 Repair time is mean of plant spec.update of maintenance duration.

Z Source category: updated

PTFRZ pump turbine driven auxiliary feedwater  
 Component boundary: detail n/a Operating mode: standby Operating environment: normal  
 Generic failure mode: fail to run Original failure mode: fail during operation  
 FAILURE RATE OR PROBABILITY mean :  $7.6E-6/hr$   
 Source: ZION NPP PSS (tbl.1.5.1-5) Ultimate source: generic data updated with plant specific experience  
 Comment: Prior:NUREG 1205("turbine driven pump failure during operation is similar to motor driven).  
 Operating experience:1900 hours of operation, no failures.

J Source category: generic

PTARJ pump turbine driven general  
 Component boundary: detail n/a Operating mode: all Operating environment: normal  
 Generic failure mode: fail to run Original failure mode: fails to run  
 FAILURE RATE OR PROBABILITY mean :  $5.0E-3/hr$  ERROR FACTOR: 10  
 Source: NUREG 4550, Vol.1,tbl.VIII.1-2 Ultimate source: assessed from several nuclear data sources  
 Comment: ASEP value is taken from IREP Procedure Guide.

U Source category: generic

PTSRU pump turbine driven high pressure > 20 bar  
 Component boundary: detail n/a Operating mode: all Operating environment: normal  
 Generic failure mode: fail to run Original failure mode: failure to continue operation  
 FAILURE RATE OR PROBABILITY mean :  $6.0E-5/hr$   
 Source: Sizewell B (PWR/RX312 pg.12) Ultimate source: assessed from nuclear and industrial experience  
 Comment: Assessment based on W data and SRS data item relevant for PWR ( $5.0E-5/hr$ ).


B Source category: generic

PTYRB pump turbine driven  
 Component boundary: pump, turbine,steam and throttle valve, governor Operating mode: all Operating environment: normal  
 Generic failure mode: fail to run Original failure mode: failure to run given start  
 FAILURE RATE OR PROBABILITY mean :  $2.0E-5/hr$  max:  $1.0E-4/hr$  min:  $8.0E-6/hr$   
 Source: NUREG 2815 (table C.1.) Ultimate source: expert opinion aggregation and IREP data  
 Comment:

I Source category: generic

PTYRI pump turbine driven  
 Component boundary: pump,turbine,steam and throttle valves, governor Operating mode: all Operating environment: normal  
 Generic failure mode: fail to run Original failure mode: failure to run given start  
 FAILURE RATE OR PROBABILITY mean :  $1.0E-5/hr$  ERROR FACTOR: 3  
 Source: IREP NUREG 2728 (tb.5.1-1) Ultimate source: expert opinion  
 Comment:

# IAEA RELIABILITY DATA BASE





G Source category: generic

VAACG valve air operated general  
Component boundary: detail n/a Operating mode: all Operating environment: normal  
Generic failure mode: fail to change position Original failure mode: fail to open or to close  
FAILURE RATE OR PROBABILITY mean :  $1.5E-2/d$  ERROR FACTOR: 23  
Source: German Risk Study (pg.P3-76) Ultimate source: generic data  
Comment: Failure rate is combination of several generic data sources. Compared with other valve types failure rate seems to be too high  
Org.time related changed to demand related assuming monthly test.

I Source category: generic

VAHCT valve pneumatic operated isolation valve  
Component boundary: valve,operator,control equipment,relays,logic and automation Operating mode: all Operating environment: normal  
Generic failure mode: fail to change position Original failure mode: failure to change position  
FAILURE RATE OR PROBABILITY mean :  $5.9E-3/d$  95%:  $3.4E-2/d$  REPAIR TIME: 6 hours  
Source: Swedish Rel.data book, tbl.16 Ultimate source: plant operating experience( 7 BWR plants),ATV reports, LERs  
Comment: Total pop.86.No.of demands per operational time 2366, 14 failures a=0.129; b=21.7 Critical failures occurred at 4 plants.

B Source category: generic

VAACB valve air operated general  
Component boundary: detail n/a Operating mode: all Operating environment: normal  
Generic failure mode: fail to change position Original failure mode: failure to operate  
FAILURE RATE OR PROBABILITY mean :  $3.6E-3/d$  max:  $1.8E-2/d$  min:  $7.2E-5/d$   
Source: NUREG 2815 (table C.1.) Ultimate source: expert opinion and IREP data  
Comment: Original time related value changed to demand related assuming monthly testing.

I Source category: generic

VAACI valve air operated general  
Component boundary: detail n/a Operating mode: all Operating environment: normal  
Generic failure mode: fail to change position Original failure mode: failure to operate  
FAILURE RATE OR PROBABILITY mean :  $3.0E-3/d$  ERROR FACTOR: 10  
Source: IREP NUREG 2728 (tb.5.1-1) Ultimate source: expert opinion  
Comment:

E1 Source category: generic

VABCE valve air operated general (BWR application)  
Component boundary: detail n/a(generally excludes operator) Operating mode: all Operating environment: normal  
Generic failure mode: fail to change position Original failure mode: fail to operate  
FAILURE RATE OR PROBABILITY rec :  $3.0E-3/cy$   
Source: IEEE 500 (1984) pg.1027 Ultimate source: expert judgement (delphi procedure) & experience  
Comment: reference EGG-EA-5816 1982.

V1 Source category: generic

VABCV valve air operated BWR (ESF systems valves only)  
Component boundary: valve body & internals,operator,funct.accessories(limit,torque sw) Operating mode: all Operating environment: normal  
Generic failure mode: fail to change position Original failure mode: fail to operate  
FAILURE RATE OR PROBABILITY mean :  $2.6E-3/d$  95%:  $5.2E-3/d$  5%:  $1.1E-3/d$   
Source: NUREG 1363 (1982) (pg 426) Ultimate source: US plants LER reports evaluation  
Comment: With command faults. No failures recorded in w/o comand faults category, 95% confidence bound is  $1.3E-3/d$ . Standby hourly rate  
with command  $1.2E-6/hr$ , w/o command (95%)  $5.9E-7/hr$ .

U Source category: generic

VAACU valve air operated general  
 Component boundary: detail n/a Operating mode: all Operating environment: normal  
 Generic failure mode: fail to change position Original failure mode: failure to operate  
 FAILURE RATE OR PROBABILITY mean : 2.1E-3/d  
 Source: Sizewell B (PWR/RX312 pg.8) Ultimate source: assessed from nuclear experience and generic data  
 Comment: Assessment based on W data item and WASH 1400 data(failrate cited is not one which appears in WASH 1400).Time related value changed to demand related assuming monthly testing.

E2 Source category: generic

VAWCE valve air operated general (PWR application)  
 Component boundary: detail n/a (generally excludes driver) Operating mode: all Operating environment: normal  
 Generic failure mode: fail to change position Original failure mode: fail to operate  
 FAILURE RATE OR PROBABILITY rec : 2.0E-3/cy  
 Source: IEEE 500 (1984) pg.1026 Ultimate source: expert judgement (delphi procedure) & experience  
 Comment: Reference EGG-EA-5B16 1984.

V2 Source category: generic

VAWCV valve air operated PWR (ESF systems valves only)  
 Component boundary: valve body & interiors,operator,functional accessories(eg.limit sw Operating mode: all Operating environment: normal  
 Generic failure mode: fail to change position Original failure mode: fail to operate  
 FAILURE RATE OR PROBABILITY mean : 1.2E-3/d 95%: 2.2E-3/d 5%: 6.0E-4/d  
 Source: NUREG 1363 (1982) (pg.422) Ultimate source: US plants LER reports evaluation  
 Comment: W/o command faults. With command faults 2.1E-3/d. Standby hourly failure rate w/o command 5.6E-7/hr, with command 9.8E-7/hr.

X Source category: generic

VAACX valve air operated general  
 Component boundary: detail n/a Operating mode: all Operating environment: normal  
 Generic failure mode: fail to change position Original failure mode: fail to change position  
 FAILURE RATE OR PROBABILITY mean : 1.0E-3/d 80%: 4.0E-3/d 20%: 5.0E-4/d  
 Source: VVER reliability data base Ultimate source: expert opinion, operating experience  
 Comment:


J Source category: generic

VAACJ valve air operated general  
 Component boundary: detail n/a Operating mode: all Operating environment: normal  
 Generic failure mode: fail to change position Original failure mode: fails to operate  
 FAILURE RATE OR PROBABILITY mean : 1.0E-3/d ERROR FACTOR: 3  
 Source: NUREG 4550,Vol 1,Tbl VIII 1-2 Ultimate source: assessed from several nuclear data sources  
 Comment: Generic value developed in Station Blackout Study(NUREG/CR-3226) Two types of failures are included in the failure rate: valve hardware faults(1.0E-3) and command circuit fault(1.0E-4)

W Source category: generic

VAACW valve air operated general  
 Component boundary: detail n/a Operating mode: all Operating environment: normal  
 Generic failure mode: fail to change position Original failure mode: failure to operate  
 FAILURE RATE OR PROBABILITY median: 3.0E-4/d 95%: 1.0E-3/d 5%: 1.0E-4/d ERROR FACTOR: 3  
 Source: WASH 1400 (table III 4-1) Ultimate source: assessed from nuclear, industrial and military experience and data  
 Comment: Failure to operate includes changing state from open to closed or closed to open.

## IAEA RELIABILITY DATA BASE



Y Source category: plant specific

VAHCY valve pneumatic operated isolation valve  
 Component boundary: valve,operator,control equipment,relays,logic and automation Operating mode: all Operating environment: normal  
 Generic failure mode: fail to change position Original failure mode: failure to change position  
 FAILURE RATE OR PROBABILITY mean : 6.5E-3/d REPAIR TIME: 5 hours  
 Source: Swedish Rel.data book, tbl.16 Ultimate source: plant operating experience (Ringhals 2 PWR)  
 Comment: total pop.33.No.of demand per operational time 1236, no.of failures 8.

F1 Source category: plant specific

VAICF valve air operated butterfly  
 Component boundary: detail n/a Operating mode: all Operating environment: normal  
 Generic failure mode: fail to change position Original failure mode: failure to operate  
 FAILURE RATE OR PROBABILITY mean : 2.6E-3/d 95%: 3.3E-3/d 5%: 2.1E-3/d ERROR FACTOR: 1.3 REPAIR TIME: 6 hours  
 Source: HWR data Ultimate source: HWR operating experience  
 Comment: Pop.70.Cum.operating time 623E+4 hours.No.of failures 45.No.of demands not known.Data based on experience with control valves.  
 Org.time related changed to demand assuming monthly testing.

O Source category: updated

VAACO valve air operated general  
 Component boundary: detail n/a Operating mode: all Operating environment: normal  
 Generic failure mode: fail to change position Original failure mode: failure to operate  
 FAILURE RATE OR PROBABILITY mean : 1.6E-3/d 95%: 3.1E-3/d 5%: 3.2E-4/d  
 Source: Oconee NPP PRA (tbl.b-1.) Ultimate source: generic data updated with plant specific operating experience  
 Comment: Prior:NUREG 1363, PWR air-op valves,failure on demand,w/o command 80%/20% ratio=10.Operating experience; 1349 demands, 3 failures.

Z Source category: updated

VAACZ valve air operated general  
 Component boundary: detail n/a Operating mode: all Operating environment: normal  
 Generic failure mode: fail to change position Original failure mode: failure to operate on demand  
 FAILURE RATE OR PROBABILITY mean : 1.4E-3/d  
 Source: ZION NPP PSS (tbl.1.5.1-5) Ultimate source: generic data updated with plant operating experience  
 Comment: Priors: NUREG 1363 air operated valve(PWR),fail to operate(mean) and WASH 1400 air operated valve, fails to operate (distrib.)  
 Operating experience: 1540 demands, 3 failures.


F2 Source category: plant specific

VAKCF valve air operated globe  
 Component boundary: detail n/a Operating mode: all Operating environment: normal  
 Generic failure mode: fail to change position Original failure mode: fail to operate  
 FAILURE RATE OR PROBABILITY mean : 5.4E-4/d 95%: 7.2E-4/d 5%: 4.0E-4/d ERROR FACTOR: 1.3 REPAIR TIME: 11 hours  
 Source: HWR data Ultimate source: HWR operating experience  
 Comment: Pop.343. Cum.operating time 22.4E+6 hours. 34 failures.Number of demands in operational time is not known.Original time related  
 value changed to demand related assuming monthly testing.

F3 Source category: plant specific

VALCF valve air operated globe  
 Component boundary: detail n/a Operating mode: all Operating environment: normal  
 Generic failure mode: fail to change position Original failure mode: fail to operate  
 FAILURE RATE OR PROBABILITY mean : 3.6E-4/d 95%: 4.7E-4/d 5%: 2.7E-4/d ERROR FACTOR: 1.3 REPAIR TIME: 5 hours  
 Source: HWR data Ultimate source: HWR operating experience  
 Comment: Pop.420.Cum operating time 32.1E+6 hours. 31 failure.No.of demand in operational time is not known.Original time related value  
 changed to demand related assuming monthly testing.

# IAEA RELIABILITY DATA BASE



X Source category: generic

VAAOX valve air operated general  
 Component boundary: detail n/a Operating mode: all Operating environment: normal  
 Generic failure mode: fail to open Original failure mode: fail to open  
 FAILURE RATE OR PROBABILITY mean : 1.0E-3/d 80%: 3.0E-3/d 20%: 5.0E-4/d  
 Source: VVER reliability data base Ultimate source: expert opinion, operating experience  
 Comment:

T Source category: generic

VAGOT valve pneumatic operated isolation valve (hydraulic scram system)  
 Component boundary: valve, operator, control equipment, relays, logic and automation Operating mode: all Operating environment: normal  
 Generic failure mode: fail to open Original failure mode: failure to open  
 FAILURE RATE OR PROBABILITY mean : 1.4E-4/d 95%: 3.3E-4/d REPAIR TIME: 4 hours  
 Source: Swedish Rel.data book, tbl.17 Ultimate source: plant operating experience (7 BWR plants), ATV reports, LERs  
 Comment: Total pop.278.No.of demands per operational time 27816. No.of failures 4. a=0.0203; b=141. Critical failures occurred at one plant

H1 Source category: updated

VAIOH valve air operated vent isolation valve (annulus ventilation)  
 Component boundary: detail n/a Operating mode: all Operating environment: normal  
 Generic failure mode: fail to open Original failure mode: fail to open on demand  
 FAILURE RATE OR PROBABILITY mean : 1.1E-2/d 95%: 2.0E-2/d 5%: 4.0E-3/d  
 Source: Old PWR Ultimate source: generic data updated with plant operating experience  
 Comment: Generic mean 1.5E-3/d Operating experience 362 demands, 6 failures.


H2 Source category: updated

VAPOH valve air operated purge isolation  
 Component boundary: detail n/a Operating mode: all Operating environment: normal  
 Generic failure mode: fail to open Original failure mode: fail to open on demand  
 FAILURE RATE OR PROBABILITY mean : 1.3E-3/d 95%: 2.4E-3/d 5%: 4.6E-4/d  
 Source: Old PWR Ultimate source: generic data updated with plant operating experience  
 Comment: Generic mean 1.5E-3/d. Operating experience 756 demands, 1 failure

H3 Source category: updated

VAAOH valve air operated all systems  
 Component boundary: detail n/a Operating mode: all Operating environment: normal  
 Generic failure mode: fail to open Original failure mode: fail to open on demand  
 FAILURE RATE OR PROBABILITY mean : 8.4E-4/d 95%: 1.4E-3/d 5%: 3.5E-4/d  
 Source: Old PWR Ultimate source: generic data updated with plant operating experience  
 Comment: Generic mean 1.5E-3/d. Operating experience 4970 demands, 3 failures.

# IAEA RELIABILITY DATA BASE



H1 Source category: updated

VAPEH valve air operated purge isolation valve  
 Component boundary: detail n/a Operating mode: all Operating environment: normal  
 Generic failure mode: fail to close Original failure mode: fail to close on demand  
 FAILURE RATE OR PROBABILITY mean : 2.3E-3/d 95%: 4.4E-3/d 5%: 8.4E-4/d  
 Source: Old PWR Ultimate source: generic data updated with plant operating experience  
 Comment: Generic mean 1.5E-3/d. Operating experience 756 demands, 3 failures.

H2 Source category: updated

VAIEH valve air operated vent isolation valve  
 Component boundary: detail n/a Operating mode: all Operating environment: normal  
 Generic failure mode: fail to close Original failure mode: fail to close on demand  
 FAILURE RATE OR PROBABILITY mean : 1.2E-3/d 95%: 2.2E-3/d 5%: 2.8E-4/d  
 Source: Old PWR Ultimate source: generic data updated with plant operating experience  
 Comment: Generic mean 1.5E-3/d. Operating experience 362 demands, no failures

H3 Source category: updated

VAAEH valve air operated all systems  
 Component boundary: detail n/a Operating mode: all Operating environment: normal  
 Generic failure mode: fail to close Original failure mode: fail to close on demand  
 FAILURE RATE OR PROBABILITY mean : 1.2E-3/d 95%: 1.8E-3/d 5%: 6.9E-4/d  
 Source: Old PWR Ultimate source: generic data updated with plant specific operating experience  
 Comment: Generic mean 1.5E-3/d. Operating experience 4970 demands, 6 failures.

H4 Source category: updated


VAZEH valve air operated turbine stop valve  
 Component boundary: detail n/a Operating mode: all Operating environment: normal  
 Generic failure mode: fail to close Original failure mode: fail to close on demand  
 FAILURE RATE OR PROBABILITY mean : 1.1E-4/d 95%: 2.2E-4/d 5%: 3.0E-5/d  
 Source: Old PWR Ultimate source: generic data updated with plant operating experience  
 Comment: Generic mean 1.3E-4/d. Operating experience 1680 demands, no failures.

H5 Source category: updated

VAHEH valve air operated turbine governor valve  
 Component boundary: detail n/a Operating mode: all Operating environment: normal  
 Generic failure mode: fail to close Original failure mode: fail to close on demand  
 FAILURE RATE OR PROBABILITY mean : 1.1E-4/d 95%: 2.2E-4/d 5%: 3.0E-5/d  
 Source: Old PWR Ultimate source: generic data updated with plant operating experience  
 Comment: Generic mean 1.3E-4/d. Operating experience 1680 demands, no failures.



# IAEA RELIABILITY DATA BASE



X Source category: generic

VAADX valve air operated general  
 Component boundary: detail n/a Operating mode: all Operating environment: normal  
 Generic failure mode: fail to remain in position Original failure mode: fail to remain in position  
 FAILURE RATE OR PROBABILITY mean : 6.0E-7/hr 80%: 1.2E-6/hr 20%: 1.5E-7/hr  
 Source: VVER reliability data base Ultimate source: expert opinion, operating experience  
 Comment:

W Source category: generic

VA1DW valve air operated general  
 Component boundary: detail n/a Operating mode: all Operating environment: normal  
 Generic failure mode: fail to remain in position Original failure mode: failure to remain open(plug)  
 FAILURE RATE OR PROBABILITY median: 3.0E-7/hr 95%: 1.0E-6/hr 5%: 1.0E-7/hr ERROR FACTOR: 3  
 Source: WASH 1400 (table 111 4-1) Ultimate source: ultimate source not known(sources presenting plug per demand)  
 Comment: Plug probabilities are given per demand and per hour since phenomena is generally time dependant, but plugged conditions may be discovered only upon demand. See FM comment air valve/demand.

H1 Source category: updated

VAQDH valve air operated raw water return line  
 Component boundary: detail n/a Operating mode: all Operating environment: normal  
 Generic failure mode: fail to remain in position Original failure mode: transfer closed  
 FAILURE RATE OR PROBABILITY mean : 5.5E-6/hr 95%: 1.2E-5/hr 5%: 7.7E-7/hr  
 Source: Old PWR Ultimate source: generic data updated with plant specific operating experience  
 Comment: Generic mean 2.7E-7/hr. Operating experience 1.4E+5 hours of operation, 3 failures.

O Source category: updated

VAADO valve air operated general  
 Component boundary: detail n/a Operating mode: all Operating environment: normal  
 Generic failure mode: fail to remain in position Original failure mode: transfer closed  
 FAILURE RATE OR PROBABILITY mean : 8.0E-7/hr 95%: 2.3E-6/hr 5%: 3.9E-8/hr  
 Source: Oconee NPP PRA (tbl.b 1.) Ultimate source: generic data updated with plant specific operating experience  
 Comment: Prior:WASH 1400,air-op valves,f.to remain open.5%=20%:95%=80%. Per demand rate converted to hrly rate assuming 1 d.in 45 days.  
 Operating experience.1.94E+5 hours of operation,1 failure.

H2 Source category updated

VA1DH valve air operated vent isolation valve (annulus ventilation)  
 Component boundary: detail n/a Operating mode: all Operating environment: normal  
 Generic failure mode: fail to remain in position Original failure mode: transfer open  
 FAILURE RATE OR PROBABILITY mean : 2.2E-7/hr 95%: 5.5E-7/hr 5%: 1.6E-8/hr  
 Source: Old PWR Ultimate source: generic data updated with plant operating experience  
 Comment: Generic mean 2.7E-7/hr. Operating experience 2.4E+5 hours of operation, no failures.

H3 Source category: updated

VAPDH valve air operated purge isolation valve  
 Component boundary: detail n/a Operating mode: all Operating environment: normal  
 Generic failure mode: fail to remain in position Original failure mode: transfer open  
 FAILURE RATE OR PROBABILITY mean : 2.0E-7/hr 95%: 5.0E-7/hr 5%: 1.5E-8/hr  
 Source: Old PWR Ultimate source: generic data updated with plant operating experience  
 Comment: Generic mean 2.7E-7/hr Operating experience 4.7E+5 hours of operation, no failures.


H4 Source category: updated

VARDH valve air operated all systems except raw water return line  
 Component boundary: detail n/a Operating mode: all Operating environment: normal  
 Generic failure mode: fail to remain in position Original failure mode: transfer closed  
 FAILURE RATE OR PROBABILITY mean : 1.2E-7/hr 95%: 2.7E-7/hr 5%: 1.4E-8/hr  
 Source: Old PWR Ultimate source: generic data updated with plant operating experience  
 Comment: Generic mean 2.7E-7/hr. Operating experience 3E+6 hours of operation, no failures.

Z Source category: updated

VAADZ valve air operated general  
 Component boundary: detail n/a Operating mode: all Operating environment: normal  
 Generic failure mode: fail to remain in position Original failure mode: transfer closed, plugged  
 FAILURE RATE OR PROBABILITY mean : 1.1E-7/hr  
 Source: ZION NPP PSS (tbl.1.5.1-5) Ultimate source: generic data updated with plant operating experience  
 Comment. Prior: WASH 1400, air operated valve, failure to remain open (plug). 1 demand in 45 days used to convert to hourly rate.  
 Operating experience: 2.13E+6 hours of operation, no failures.

# IAEA RELIABILITY DATA BASE



B Source category: generic

VXACB valve manual general  
Component boundary: detail n/a Operating mode: all Operating environment: normal  
Generic failure mode: fail to change position Original failure mode: failure to operate  
FAILURE RATE OR PROBABILITY mean : 2.6E-2/d max: 1.3E-1/d min: 1.0E-2/d  
Source: NUREG 2815 (table C.1.) Ultimate source: expert opinion and IREP data  
Comment: Failure to operate is dominated by human error. Rate is based on one actuation per month. Original time related value changed to demand related assuming monthly testing.

G Source category: generic

VXACG valve manual general  
Component boundary: detail n/a Operating mode: all Operating environment: normal  
Generic failure mode: fail to change position Original failure mode: fail to open or to close  
FAILURE RATE OR PROBABILITY mean : 1.7E-4/d ERROR FACTOR: 12  
Source: German Risk Study (pg.F3-79) Ultimate source: generic data and operating experience  
Comment: Both generic and specific sources were combined for this failure rate. Original time related value changed to demand related assuming monthly testing.

X Source category: generic

VXACX valve manual general  
Component boundary: detail n/a Operating mode: all Operating environment: normal  
Generic failure mode: fail to change position Original failure mode: fail to change position  
FAILURE RATE OR PROBABILITY mean : 1.0E-4/d 80%: 3.0E-4/d 20%: 2.0E-5/d  
Source: VVER reliability data base Ultimate source: expert opinion, operating experience  
Comment:

I Source category: generic

VXACI valve manual general  
Component boundary: detail n/a Operating mode: all Operating environment: normal  
Generic failure mode: fail to change position Original failure mode: failure to operate  
FAILURE RATE OR PROBABILITY mean : 1.0E-4/d ERROR FACTOR: 3  
Source: IREP NUREG 2728 (tb.5.1-1) Ultimate source: expert opinion  
Comment: Failure to operate is dominated by human error Hourly rate 3.0E-7 (EF 10) is based on one actuation per month

E1 Source category: generic

VXPCE valve manual general (PWR application)  
Component boundary: detail n/a Operating mode: all Operating environment: normal  
Generic failure mode: fail to change position Original failure mode: failed to operate  
FAILURE RATE OR PROBABILITY rec : 7.0E-5/cy  
Source: IEEE 500 (1984) pg.1018 Ultimate source: expert judgement aggregation (delphi method)  
Comment:


V Source category: generic

VXECV valve manual PWR + BWR (ESF systems valves only)  
 Component boundary: valve body and interiors, operating mechanism Operating mode: all Operating environment: normal  
 Generic failure mode: fail to change position Original failure mode: fail to operate  
 FAILURE RATE OR PROBABILITY mean :  $6.3E-5/d$  95%:  $1.6E-4/d$  5%:  $2.1E-5/d$   
 Source: NUREG 1363 (1982) (pg.454) Ultimate source: US plants LER reports evaluation  
 Comment: Overall data PWR and BWR about equal. Standby hourly rate  $2.9E-8/hr$ .

E2 Source category: generic

VXSCE valve manual general (BWR application)  
 Component boundary: detail n/a Operating mode: all Operating environment: normal  
 Generic failure mode: fail to change position Original failure mode: failed to operate  
 FAILURE RATE OR PROBABILITY rec :  $6.0E-5/cy$   
 Source: IEEE 500 (1984) pg.1019 Ultimate source: expert opinion aggregation (delphi method) & operating experience  
 Comment: Reference EGG-EA-5816 82.Data Summaries of LER of Valves at US Commercial NPP

# IAEA RELIABILITY DATA BASE



F1 Source category: plant specific

VXGCF valve manual gate  
Component boundary: detail n/a Operating mode: all Operating environment: normal  
Generic failure mode: fail to change position Original failure mode: fail to operate  
FAILURE RATE OR PROBABILITY mean : 1.5E-4/d 95%: 2.4E-4/d 5%: 1.0E-4/d ERROR FACTOR: 1.5 REPAIR TIME: 14 hours  
Source: HWR data Ultimate source: HWR operating experience  
Comment: Pop.520. Cumulative operating time 34.6E+6 hours.15 failures. Number of demand per operational time is not known.Original time  
related value changed to demand related assuming monthly testing.

F2 Source category: plant specific

VXICF valve manual gate  
Component boundary: detail n/a Operating mode: all Operating environment: normal  
Generic failure mode: fail to change position Original failure mode: fail to operate  
FAILURE RATE OR PROBABILITY mean : 7.9E-5/d 95%: 1.2E-4/d 5%: 5.4E-5/d ERROR FACTOR: 1.4 REPAIR TIME: 9 hours  
Source: HWR data Ultimate source: HWR operating experience  
Comment: Pop.1179. Cum.operating time 84.2E+6 hours.18 failures. Number of demands per operational time in not known.Original time  
related value changed to demand related assuming monthly testing.

F3 Source category: plant specific


VXHCF valve manual gate  
Component boundary: detail n/a Operating mode: all Operating environment: normal  
Generic failure mode: fail to change position Original failure mode: fail to operate  
FAILURE RATE OR PROBABILITY mean : 4.7E-5/d 95%: 5.8E-5/d 5%: 3.3E-5/d ERROR FACTOR: 1.3 REPAIR TIME: 4 hours  
Source: HWR data Ultimate source: HWR operating experience  
Comment: Pop.3546. Cum.operating time 2.5E+8 hours. 30 failures. Number of demands per operating time is not known.Original time  
related value changed to demand related assuming monthly testing.

F4 Source category: plant specific

VXSCF valve manual gate  
Component boundary: detail n/a Operating mode: all Operating environment: normal  
Generic failure mode: fail to change position Original failure mode: fail to operate  
FAILURE RATE OR PROBABILITY mean : 1.2E-5/d 95%: 1.5E-5/d 5%: 9.4E-6/d ERROR FACTOR: 1.3 REPAIR TIME: 2 hours  
Source: HWR data Ultimate source: HWR operating experience  
Comment: Pop.19351. Cum.operating time 1.3E+9 hours. 43 failures. Number of demands per operating time is not known.Original time  
related value changed to demand related assuming monthly testing.



# IAEA RELIABILITY DATA BASE



W Source category: generic

VXADW valve manual general  
Component boundary: detail n/a Operating mode: all Operating environment: normal  
Generic failure mode: fail to remain in position Original failure mode: failure to remain open(plug)  
FAILURE RATE OR PROBABILITY median: 2.7E-7/hr 95%: 8.3E-7/hr 5%: 8.3E-8/hr ERROR FACTOR: 3  
Source: WASH 1400 (table III 4-1) Ultimate source: assessed from US nuclear experience (including test & research R)  
Comment: Failure to remain open refers to reduction of flow to unusable level due to foreign material or gate failure.  
Demand value changed to time related assuming 1 demand per month.

X Source category: generic

VXADX valve manual general  
Component boundary: detail n/a Operating mode: all Operating environment: normal  
Generic failure mode: fail to remain in position Original failure mode: fail to remain in position  
FAILURE RATE OR PROBABILITY mean : 1.0E-7/hr 80%: 5.0E-7/hr 20%: 2.0E-8/hr  
Source: VVER reliability data base Ultimate source: expert opinion, operating experience  
Comment:

O Source category: updated

VXADO valve manual general  
Component boundary: detail n/a Operating mode: all Operating environment: normal  
Generic failure mode: fail to remain in position Original failure mode: transfer closed  
FAILURE RATE OR PROBABILITY mean : 8.9E-8/hr 95%: 2.4E-7/hr 5%: 4.8E-9/hr  
Source: Oconee NPP PRA (tbl.b-1.) Ultimate source: generic data updated with plant specific operating experience  
Comment: Prior: NUREG 1363, failure of internals of manual valves. Operating experience: 3.09E+6 hours of operation, 1 failure.  
95%/5% ratio is 100, indicating high degree of uncertainty.


H1 Source category: updated

VXTDH valve manual butterfly  
Component boundary: detail n/a Operating mode: all Operating environment: normal  
Generic failure mode: fail to remain in position Original failure mode: transfer closed  
FAILURE RATE OR PROBABILITY mean : 3.1E-8/hr 95%: 9.8E-8/hr 5%: 1.5E-9/hr  
Source: Old PWR Ultimate source: generic data updated with plant operating experience  
Comment: Generic mean 4.2E-8/hr. Operating experience 2.2E+6 hours, no failures.

H2 Source category: updated

VXADH valve manual  
Component boundary: detail n/a Operating mode: all Operating environment: normal  
Generic failure mode: fail to remain in position Original failure mode: transfer closed  
FAILURE RATE OR PROBABILITY mean : 1.7E-8/hr 95%: 4.3E-8/hr 5%: 1.4E-9/hr  
Source: Old PWR Ultimate source: generic data updated with plant operating experience  
Comment: Generic mean 4.2E-8/hr Operating experience 1.8E+7 hours of operation, no failures.

# IAEA RELIABILITY DATA BASE



T1 Source category: generic

VMFCT valve motor operated control valve  
 Component boundary: valve,motor,protection,controls,relays,logic and automation Operating mode: all Operating environment: normal  
 Generic failure mode: fail to change position Original failure mode: failure to change position  
 FAILURE RATE OR PROBABILITY mean : 2.5E-2/d 95%: 1.6E-1/d REPAIR TIME: 4 hours  
 Source: Swedish Rel.data book, tbl.20 Ultimate source: plant operating experience(7 BWR plants), ATV reports  
 Comment: Total pop.69.No.of demands per operational time 2012.No of failures 22. a=0.0971; b=3.75 Critical failures reported at 5 plants.

E1 Source category: generic

VMQCE valve motor operated general (BWR application)  
 Component boundary: detail n/a(generally exclude driver) Operating mode: all Operating environment: normal  
 Generic failure mode: fail to change position Original failure mode: fail to operate  
 FAILURE RATE OR PROBABILITY rec : 8.0E-3/cy  
 Source: IEEE 500 (1984) pg.1023 Ultimate source: expert judgement aggregation (delphi procedure) & experience  
 Comment: Reference EGG-EA 5816 1982.

T2 Source category: generic

VMKCT valve motor operated isolation valve =<100 mm  
 Component boundary: valve,motor,protection,controls,switch,fuse,indications Operating mode: all Operating environment: normal  
 Generic failure mode: fail to change position Original failure mode: failure to change position  
 FAILURE RATE OR PROBABILITY mean : 7.9E-3/d 95%: 3.6E-2/d REPAIR TIME: 4 hours  
 Source: Swedish Rel.data book, tbl.11 Ultimate source: plant operating experience (7 BWR plants), ATV reports, LERs  
 Comment: Total pop.71.Number of demands per operational time 2512.Number of failures observed: 18. a=0.307; b=38.5. Critical failures occurred at 6 plants.

T3 Source category: generic

VMNCT valve motor operated isolation valve (>200mm)  
 Component boundary: valve,motor,protection,controls,switch,fuse,indications Operating mode: all Operating environment: normal  
 Generic failure mode: fail to change position Original failure mode: failure to change position  
 FAILURE RATE OR PROBABILITY mean : 7.2E-3/d 95%: 4.2E-2/d REPAIR TIME: 5 hours  
 Source: Swedish Rel.data book, tbl.13 Ultimate source: plant operating experience (7 BWR plants), ATV reports, LERs  
 Comment: Total pop.95.Number of demands per operational time 3059.Number of failures 22. a= 0.11; b=15.2 Critical failures occurred at 4 plants.

V1 Source category: generic

VM1CV valve motor operated BWR (ESF systems valves only)  
 Component boundary: valve body and its internal parts,motor,functional accesories Operating mode: all Operating environment: normal  
 Generic failure mode: fail to change position Original failure mode: fail to operate  
 FAILURE RATE OR PROBABILITY mean : 6.8E-3/d 95%: 7.4E-3/d 5%: 6.2E-3/d  
 Source: NUREG 1363 (1982) (pg.398) Ultimate source: US plants LER reports evaluation  
 Comment: W/o command faults. With command 9.6E-3/d.Standby hourly failure rate:w/o 3.1E-6/hr; with 4.4E-6/hr.LER rates from 'unknown remote and MOV' what better represent MOV population.

T4 Source category: generic

VMOCT valve motor operated isolation valve (100< DN < 200 mm)  
 Component boundary: valve,motor,protection,controls,switch,fuse,indications Operating mode: all Operating environment: normal  
 Generic failure mode: fail to change position Original failure mode: failure to change position  
 FAILURE RATE OR PROBABILITY mean : 6.3E-3/d 95%: 3.7E-2/d REPAIR TIME: 4 hours  
 Source: Swedish Rel.data book, tbl.12 Ultimate source: plant operating experience(7 BWR plants), ATV reports, LERs  
 Comment: Total pop.180.Number of demads per operational time 6181.Number of failures:30. a=0.114; b=18 Critical failures occurred at 6 plants.

G1 Source category: generic

VMHCG valve motor operated MSIV (FD-Schnellschlusschieber)  
 Component boundary: main valve without pilot valve Operating mode: all Operating environment: normal  
 Generic failure mode: fail to change position Original failure mode: fail to open or to close  
 FAILURE RATE OR PROBABILITY median:  $6.0E-3/d$  ERROR FACTOR: 4  
 Source: German Risk Study (tb.F3-7-1) Ultimate source: operating experience  
 Comment: Bases for failure rate is 112 operating demands without failure.

G2 Source category: generic

VMACG valve motor operated general  
 Component boundary: detail n/a Operating mode: all Operating environment: normal  
 Generic failure mode: fail to change position Original failure mode: fail to open or to close  
 FAILURE RATE OR PROBABILITY mean:  $5.4E-3/d$  ERROR FACTOR: 3  
 Source: German Risk Study (pg.F3-74) Ultimate source: generic data and operating experience  
 Comment: The same value is used in FIs for fail to open or close mode. For the standby operating mode, assuming monthly test interval failure per demand is  $5.4E-3$ . (Value changed from hr to demand)

V2 Source category: generic

VMHCV valve motor operated PWR (ESF system valves only)  
 Component boundary: valve body & internals, motor, functional accessories (limit switch) Operating mode: all Operating environment: normal  
 Generic failure mode: fail to change position Original failure mode: fail to operate  
 FAILURE RATE OR PROBABILITY mean:  $4.1E-3/d$  95%:  $4.9E-3/d$  5%:  $3.4E-3/d$   
 Source: NUREG 1363 (1982) (pg.398) Ultimate source: US plants LER reports evaluation  
 Comment: W/o command faults. With command faults  $6.2E-3/d$ . Standby rate  $1.9E-6/hr$ . LER rate from 'unknown remote and motor operated' what better represent MOV population.

E2 Source category: generic

VMPCE valve motor operated general (PWR application)  
 Component boundary: detail n/a (generally excludes operator) Operating mode: all Operating environment: normal  
 Generic failure mode: fail to change position Original failure mode: fail to operate  
 FAILURE RATE OR PROBABILITY rec:  $4.0E-3/cy$   
 Source: IEEE 500 (1984) pg.1022 Ultimate source: expert opinion aggregation (delphi procedure) & plant experience  
 Comment: Reference EGG-EA-5816 1982.

G3 Source category: generic

VMRCG valve motor operated regulating  
 Component boundary: valve with operator Operating mode: all Operating environment: normal  
 Generic failure mode: fail to change position Original failure mode: fail to close (in terms of regulating)  
 FAILURE RATE OR PROBABILITY mean:  $3.6E-3/d$  ERROR FACTOR: 7  
 Source: German Risk Study (pg.F3-79) Ultimate source: generic data  
 Comment: Failure rate is combination of generic data sources Original time related value changed to demand related assuming monthly testing.

X Source category: generic

VMACX valve motor operated general  
 Component boundary: detail n/a Operating mode: all Operating environment: normal  
 Generic failure mode: fail to change position Original failure mode: fail to change position  
 FAILURE RATE OR PROBABILITY mean:  $3.0E-3/d$  80%:  $9.0E-3/d$  20%:  $6.0E-4/d$   
 Source: VVER reliability data base Ultimate source: expert opinion, operating experience  
 Comment:

J Source category: generic

VMACJ valve motor operated general  
Component boundary: detail n/a Operating mode: all Operating environment: normal  
Generic failure mode: fail to change position Original failure mode: fails to operate  
FAILURE RATE OR PROBABILITY mean :  $3.0E-3/d$  ERROR FACTOR: 10  
Source: NUREG 4550, Vol.1, tbl VIII.1-2 Ultimate source: assesed from several nuclear data sources  
Comment: Valuse used is from Station Blachout Study (NUREG/CR-3226). Two types of failures are included: valve hardware faults( $5.0E-4$ ) and command circut faults ( $2.5E-4$ )


U Source category: generic

VMACU valve motor oprated general  
Component boundary: detail n/a Operating mode: all Operating environment: normal  
Generic failure mode: fail to change position Original failure mode: failure to operate  
FAILURE RATE OR PROBABILITY mean :  $1.4E-3/d$   
Source: Sizewell B (PWR/RX312 pg.6) Ultimate source: asesed from nuclear experience and generic sources  
Comment: Assesment based on W data item and WASH 1400 data.If valves are tested montly,given failure rate gives the peak probability of  $1.4E-3/d$ , what is in agreement with WASH 1400.(Hr changed to dem)

W Source category: generic

VMACW valve motor operated general  
Component boundary: detail n/a, include driver. Operating mode: all Operating environment: normal  
Generic failure mode: fail to change position Original failure mode: failure to operate  
FAILURE RATE OR PROBABILITY median:  $1.0E-3/d$  95%:  $3.0E-3/d$  5%:  $3.0E-4/d$  ERROR FACTOR: 3  
Source: WASH 1400 (table III 4-1) Ultimate source: assesed from nuclear,industrial and military experience and data  
Comment: Demand probabilities are based on presence of proper input signal Failure to operate include changing state from closed to open or from open to closed position.

# IAEA RELIABILITY DATA BASE



01 Source category: updated

VMDCO valve motor operated  
 Component boundary: detail n/a Operating mode: all Operating environment: normal  
 Generic failure mode: fail to change position Original failure mode: failure to operate  
 FAILURE RATE OR PROBABILITY mean : 1.0E-1/d 95%: 1.6E-1/d 5%: 2.7E-2/d  
 Source: Oconee NPP PRA (tbl.b.1.) Ultimate source: generic data updated with plant specific operating experience  
 Comment: Prior: NUREG 1363, failure of MOV and remote operated on demand. Operating experience: 30 demands, 5 failures.

02 Source category: updated

VMBCO valve motor operated  
 Component boundary: detail n/a Operating mode: all Operating environment: normal  
 Generic failure mode: fail to change position Original failure mode: failure to operate  
 FAILURE RATE OR PROBABILITY mean : 6.4E-3/d 95%: 7.7E-3/d 5%: 4.5E-3/d  
 Source: Oconee NPP PRA (tbl.b.1.) Ultimate source: generic data updated with plant specific operating experience  
 Comment: Prior: NUREG 1363, failure of MOV and remote operated on demand. Operating experience: 6725 demands, 42 failures.

Z1 Source category: updated

VMECZ valve motor operated  
 Component boundary: detail n/a Operating mode: standby Operating environment: normal  
 Generic failure mode: fail to change position Original failure mode: failure to operate on demand  
 FAILURE RATE OR PROBABILITY mean : 5.7E-3/d  
 Source: ZION NPP PSS (tbl.1.5.1-5) Ultimate source: generic data updated with plant operating experience  
 Comment: Priors: NUREG 1363 MOV+remote (PWR)(w/o command), fail to operate (M) and WASH 1400 MOV, fails to operate (distrib.).  
 Operating experience. 1647 demands, 10 failures.

Y1 Source category: plant specific

VMKCY valve motor operated isolation valve =<100 mm  
 Component boundary: valve, motor, protection, controls, switch, fuse, indications Operating mode: all Operating environment: normal  
 Generic failure mode: fail to change position Original failure mode: failure to change position  
 FAILURE RATE OR PROBABILITY mean : 5.3E-3/d REPAIR TIME: 3 hours  
 Source: Swedish Rel.data book, tbl.11 Ultimate source: plant operating experience (Ringhals 2 PWR)  
 Comment: Total pop.22.Number of demands per operational time 983.Number of failures:5.

Z2 Source category: updated

VMCCZ valve motor operated  
 Component boundary: detail n/a Operating mode: all Operating environment: normal  
 Generic failure mode: fail to change position Original failure mode: failure to operate on demand  
 FAILURE RATE OR PROBABILITY mean : 3.7E-3/d  
 Source: ZION NPP PSS (tbl.1.5.1-5) Ultimate source: generic data updated with plant operating experience  
 Comment: Priors: NUREG 1363, MOV+remote(PWR)(w/o command) fail to operate(M) and WASH 1400 MOV, fails to operate (distrib).  
 Operating experience: 1720 demands, 7 failures

Y2 Source category: plant specific

VMNCY valve motor operated isolation valve (>200 mm)  
 Component boundary: valve, motor, protection, controls, switch, fuse, indications Operating mode: all Operating environment: normal  
 Generic failure mode: fail to change position Original failure mode: failure to change position  
 FAILURE RATE OR PROBABILITY mean : 3.3E-3/d REPAIR TIME: 8 hours  
 Source: Swedish Rel.data book, tbl.13 Ultimate source: plant operating experience (Ringhals 2 PWR) ATV reports  
 Comment: Total pop. 23.Number of demands per operational time 1486.Number of failures 5.



Y3 Source category: plant specific

VMOCY valve motor operated isolation valve (100mm< DN< 200 mm)  
 Component boundary: valve,motor,protection,control,switch,fuse,indications Operating mode: all Operating environment: normal  
 Generic failure mode: fail to change position Original failure mode: failure to change position  
 FAILURE RATE OR PROBABILITY mean : 1.7E-3/d  
 Source: Swedish Rel.data book, tbl.12 Ultimate source: plant operating experience (Ringshals 2 PWR),ATV reports  
 Comment: Total pop. 12.Number of demands per operational time 600.Number of failures 1.FAILMODE regarded open/close operation as one demand

Z3 Source category: updated

VMJCZ valve motor operated  
 Component boundary: detail n/a Operating mode: all Operating environment: normal  
 Generic failure mode: fail to change position Original failure mode: failure to operate on demand  
 FAILURE RATE OR PROBABILITY mean : 1.6E-3/d  
 Source: ZION NPP PSS (tbl.1.5.1-5) Ultimate source: generic data updated with plant operating experience  
 Comment: Priors:NUREG 1363 MOV+ remote(PWR)(w/o command)fail to operate(M) and WASH 1400 failed to operate (distrib.).  
 Operating experience: 11310 demands, 14 failures.

F1 Source category: plant specific

VMTCF valve motor operated butterfly (6-12")  
 Component boundary: detail n/a Operating mode: all Operating environment: normal  
 Generic failure mode: fail to change position Original failure mode: fail to operate  
 FAILURE RATE OR PROBABILITY mean : 1.3E-3/d 95%: 1.7E-3/d 5%: 1.0E-3/d ERROR FACTOR: 1.3 REPAIR TIME: 3 hours  
 Source: HWR data Ultimate source: HWR operating experience  
 Comment: Pop.165.Cum.opearting time 12.95E+6 hours.No.of failures 47. No.of demands not known.Failure mode include actuator failure,but not loss of power.Data based on experience with isolation valves.

F2 Source category: plant specific

VMSCF valve motor operated butterfly (12-24")  
 Component boundary: detail n/a Operating mode: all Operating environment: normal  
 Generic failure mode: fail to change position Original failure mode: fail to operate  
 FAILURE RATE OR PROBABILITY mean : 9.4E-4/d 95%: 1.4E-3/d 5%: 6.8E-4/d ERROR FACTOR: 1.4 REPAIR TIME: 10 hours  
 Source: HWR data Ultimate source: WRU operating experience  
 Comment: Pop.95.Cum.operating time 8E+6 hours.No.of failures 21.No.of demands not known.Failure mode "fail to operate" include actuator failure but not loss of power.Data from isolation valves.

F3 Source category: plant specific

VMGCF valve motor operated gate (12-24")  
 Component boundary: detail n/a Operating mode: all Operating environment: normal  
 Generic failure mode: fail to change position Original failure mode: fail to operate  
 FAILURE RATE OR PROBABILITY mean : 7.9E-4/d 95%: 9.7E-4/d 5%: 5.7E-4/d ERROR FACTOR: 1.2 REPAIR TIME: 21 hour  
 Source: HWR data Ultimate source: HWR operating experience  
 Comment: Pop.356. Cum operating time 29.1E+6 hours.63 failures. Number of demands in operational time is not known "Fail to operate" incl. actuator failure,but not power supply to actuator.


F4 Source category: plant specific

VMLCF valve motor operated globe (2-6")  
Component boundary: detail n/a Operating mode: all Operating environment: normal  
Generic failure mode: fail to change position Original failure mode: fail to operate  
FAILURE RATE OR PROBABILITY mean : 4.7E-4/d 95%: 6.8E-4/d 5%: 3.2E-4/d ERROR FACTOR: 1.1 REPAIR TIME: 5 hours  
Source: HWR data Ultimate source: HWR operating experience  
Comment: Pop.220.Cum.operating time 14E+6 hours.18 failures.No.of demands in operational time is not known. Data based on experience with isolating valves.FM incl.actuator failure,but not power supply.

F5 Source category: plant specific

VMUCF valve motor operated butterfly (2-6")  
Component boundary: detail n/a Operating mode: all Operating environment: normal  
Generic failure mode: fail to change position Original failure mode: fail to operate  
FAILURE RATE OR PROBABILITY mean : 3.3E-5/d 95%: 1.5E-4/d 5%: 1.2E-5/d ERROR FACTOR: 2.7 REPAIR TIME: 1 hour  
Source: HWR data Ultimate source: HWR operating experience  
Comment: Pop.157.Cum.operating time 1080E+4 hours.1 failure.No.of demands in time not known.Data based on expereince with isolating valves (electr.or pneum.operator).FM.incl.failure of actuator, w/o comm.

# IAEA RELIABILITY DATA BASE



W Source category: generic

VMADW valve motor operated general  
Component boundary: detail n/a Operating mode: all Operating environment: normal  
Generic failure mode: fail to remain in position Original failure mode: failure to remain open (plug)  
FAILURE RATE OR PROBABILITY median: 3.0E-7/hr 95%: 1.0E-6/hr 5%: 1.0E-7/hr ERROR FACTOR: 3  
Source: WASH 1400 (table III 4-1) Ultimate source: ultimate data source not known(sources presents plug per demand)  
Comment: Failure to remain open refers to reduction of flow to unusable level due to foreign particles or gate failure. Not included  
in value inadvertant or false signal driving valve closed.

B Source category: generic

VMADB valve motor operated general  
Component boundary: detail n/a Operating mode: all Operating environment: normal  
Generic failure mode: fail to remain in position Original failure mode: failure to remain open  
FAILURE RATE OR PROBABILITY mean : 2.0E-7/hr max: 1.0E-6/hr min: 8.0E-8/hr  
Source: NUREG 2815 (table C.1.) Ultimate source: expert opinion and IREP data  
Comment:

X Source category: generic

VMADX valve motor operated general  
Component boundary: detail n/a Operating mode: all Operating environment: normal  
Generic failure mode: fail to remain in position Original failure mode: fail to remain in position  
FAILURE RATE OR PROBABILITY mean : 2.0E-7/hr 80%: 4.0E-7/hr 20%: 5.0E-8/hr  
Source: VVER reliability data base Ultimate source: expert opinion, operating experience  
Comment:

S1 Source category: generic

VMYDS valve motor operated general  
Component boundary: detail n/a Operating mode: normally closed Operating environment: normal  
Generic failure mode: fail to remain in position\* Original failure mode: failed open  
FAILURE RATE OR PROBABILITY mean : 1.6E-7/hr  
Source: Shoreham PRA,GE data(tb.A.2-1) Ultimate source: evaluation of BWR operating experience  
Comment:


S2 Source category: generic

VMXDS valve motor operated general  
Component boundary: detail n/a Operating mode: normally open Operating environment: normal  
Generic failure mode: fail to remain in position\* Original failure mode: failed closed  
FAILURE RATE OR PROBABILITY mean : 1.5E-7/hr  
Source: Shoreham PRA,GE data(tb.A.2-1) Ultimate source: evaluatiopn of BWR operating experience  
Comment:

I Source category: generic

VMADI valve motor operated general  
Component boundary: detail n/a Operating mode: all Operating environment: normal  
Generic failure mode: fail to remain in position Original failure mode: failure to remain open  
FAILURE RATE OR PROBABILITY mean : 1.0E-7/hr ERROR FACTOR: 3  
Source: IREP NUREG 2728 (tb.5.1-1) Ultimate source: expert opinion  
Comment:

# IAEA RELIABILITY DATA BASE



O Source category: updated

VMADO valve motor operated general  
Component boundary: detail n/a Operating mode: all Operating environment: normal  
Generic failure mode: fail to remain in position Original failure mode: transfer closed  
FAILURE RATE OR PROBABILITY mean : 1.2E-7/hr 95%: 3.0E-7/hr 5%: 5.8E-9/hr  
Source: Oconee NPP PRA (tbl.b-1.) Ultimate source: generic data updated with plant specific operating experience  
Comment: Prior: WASH 1400, MOV fail to remain open. 5%=20%; 95%=80%. Per demand rate converted to hrly rate assuming 1 demand in 45 days.  
Operating experience: 1.89E+6 hours of operation, no failures.

H Source category: updated

VMADH valve motor operated general  
Component boundary: detail n/a Operating mode: all Operating environment: normal  
Generic failure mode: fail to remain in position Original failure mode: transfer closed  
FAILURE RATE OR PROBABILITY mean : 7.3E-8/hr 95%: 1.6E-7/hr 5%: 9.1E-9/hr  
Source: Old PWR Ultimate source: generic data updated with plant operating experience  
Comment: Generic mean 9.3E-8/hr. Operating experience 1.6E+6 hours of operation, no failures.


Z1 Source category: updated

VMADZ valve motor operated general  
Component boundary: detail n/a Operating mode: all Operating environment: normal  
Generic failure mode: fail to remain in position Original failure mode: transfer closed  
FAILURE RATE OR PROBABILITY mean : 5.3E-8/hr  
Source: ZION NPP PSS (tbl.1.5.1-5) Ultimate source: generic data updated with plant specific experience  
Comment: Also applicable to manual valves. Prior: WASH 1400, fail to remain open, plugged. 1 demand in 45 days used to convert to hourly rate.  
Operating experience: 1.1E+7 hours of operation, no failures.

Z2 Source category: updated

VMADZ valve motor operated general  
Component boundary: detail n/a Operating mode: all Operating environment: normal  
Generic failure mode: fail to remain in position Original failure mode: transfer open /excessive leakage through valve  
FAILURE RATE OR PROBABILITY mean : 3.1E-8/hr  
Source: ZION NPP PSS (tbl.1.5.1-5) Ultimate source: generic data updated with plant operating experience  
Comment: Priors: NUREG 1363 MOV+remote(PWR), external leakage (mean) and WASH 1400, MOV, external leakage/rupture (distribution).  
Operating experience: 6.95E+5 hours of operation, no failures.

# IAEA RELIABILITY DATA BASE



T Source category: generic

VCJOT valve self operated check >100 mm  
 Component boundary: detail n/a Operating mode: all Operating environment: normal  
 Generic failure mode: fail to open Original failure mode: failure to open  
 FAILURE RATE OR PROBABILITY mean : 6.3E-4/d REPAIR TIME: 9 hours  
 Source: Swedish Rel.data book, tbl.19 Ultimate source: plant operating experience (7 BWR plants), ATV reports, LERs  
 Comment: Total pop.168. No.of demands per operational time 3211. No of failures 1.a=0.071; b=11.2 Critical failure at one plant only.  
 Ringhals 2 PWR- no failure to open out of 1844 demands.

G Source category: generic

VCEOG valve self operated check (ECCS and RHR systems)  
 Component boundary: detail n/a Per hour value changed to per demand (360 hrs) Operating mode: standby Operating environment: normal  
 Generic failure mode: fail to open Original failure mode: fail to open  
 FAILURE RATE OR PROBABILITY mean : 2.6E-4/d ERROR FACTOR: 4  
 Source: German Risk Study (pg.P3-76) Ultimate source: operating experience  
 Comment: Operating experience: 1.5E+6 operating hours, no failures. For other check valves combination of generic data sources with  
 failure rate of 2.1E-6/hr (EF 10) was used in FTs.

J Source category: generic

VCAOJ valve self operated check  
 Component boundary: detail n/a Operating mode: all Operating environment: normal  
 Generic failure mode: fail to open Original failure mode: fails to open  
 FAILURE RATE OR PROBABILITY mean : 1.0E-4/d ERROR FACTOR: 3  
 Source: NUREG 4550, Vol.1,tbl.VIII.1-2 Ultimate source: assesed from several nuclear data sources  
 Comment: Generic value developed in Station Blackout Study was used.

X Source category: generic

VCAOX valve self operated check  
 Component boundary: detail n/a Operating mode: all Operating environment: normal  
 Generic failure mode: fail to open Original failure mode: fail to open  
 FAILURE RATE OR PROBABILITY mean : 1.0E-4/d 80%: 3.0E-4/d 20%: 2.0E-5/d  
 Source: VVER reliability data base Ultimate source: expert opinion, operating experience  
 Comment:

I Source category: generic

VCAOI valve self operated check  
 Component boundary: detail n/a Operating mode: all Operating environment: normal  
 Generic failure mode: fail to open Original failure mode: failure to open  
 FAILURE RATE OR PROBABILITY mean : 1.0E-4/d ERROR FACTOR: 3  
 Source: IREP NUREG 2728 (tb.5.1-1) Ultimate source: expert opinion  
 Comment: Hourly rate is 3.0E-7 (EF 10), based on one actuation per month

W Source category: generic

VCAOW valve self operated check  
 Component boundary: detail n/a Operating mode: all Operating environment: normal  
 Generic failure mode: fail to open Original failure mode: failure to open  
 FAILURE RATE OR PROBABILITY median: 1.0E-4/d 95%: 3.0E-4/d 5%: 3.0E-5/d ERROR FACTOR: 3  
 Source: WASH 1400 (table III 4-1) Ultimate source: assesed from nuclear, industrial and military expereince and data  
 Comment:



S1 Source category: generic

VCNOS valve self operated check valve testable check valve  
 Component boundary: detail n/a Operating mode: all Operating environment: normal  
 Generic failure mode: fail to open Original failure mode: fails to permit flow  
 FAILURE RATE OR PROBABILITY mean : 7.9E-5/d  
 Source: Shoreham PRA,GE data(tb.A.2-1) Ultimate source: evaluation of BWR operating experience  
 Comment: Original time related value changed to demand related assuming monthly testing.

B Source category: generic

VCAOB valve self operated check  
 Component boundary: detail n/a Operating mode: all Operating environment: normal  
 Generic failure mode: fail to open Original failure mode: failure to open  
 FAILURE RATE OR PROBABILITY mean : 7.2E-5/d max: 3.6E-4/d min: 2.9E-5/d  
 Source: NUREG 2815 (table C.1.) Ultimate source: expert opinion and IREP data  
 Comment: Original time related value changed to demand related assuming monthly testing.

V Source category: generic

VCFOV valve self operated check  
 Component boundary: valve, body and interiors Operating mode: all Operating environment: normal  
 Generic failure mode: fail to open Original failure mode: failure to open  
 FAILURE RATE OR PROBABILITY mean : 6.4E-5/d 95%: 1.7E-4/d 5%: 1.7E-5/d  
 Source: NUREG 1363 (1982) (pg.438) Ultimate source: US plants LER reports  
 Comment: Overall standby hourly failure rate 3.0E-8/hr.


S2 Source category: generic

VCAOS valve self operated check  
 Component boundary: detail n/a Operating mode: all Operating environment: normal  
 Generic failure mode: fail to open Original failure mode: fails to permit flow  
 FAILURE RATE OR PROBABILITY mean : 5.4E-5/d  
 Source: Shoreham PRA,GE data(tb.A.2-1) Ultimate source: evaluation of BWR operating experience  
 Comment: Original time related value changed to demand related assuming monthly testing.

U Source category: generic

VCAOU valve self operated check  
 Component boundary: detail n/a Operating mode: all Operating environment: normal  
 Generic failure mode: fail to open Original failure mode: failure to open  
 FAILURE RATE OR PROBABILITY mean : 3.6E-5/d  
 Source: Sizewell B (PWR/RX312 pg.4) Ultimate source: assessed from nuclear experience and data  
 Comment: Assessment based on 2 W data item, WASH 1400, and SRS data item(PWR) (5.0E-5/d). For monthly tested valves stdby failrate of 1.0E-7/hr gives average failure rate of 3.6E-5/d.

# IAEA RELIABILITY DATA BASE



H Source category: updated

VCAOH valve self operated check  
Component boundary: detail n/a Operating mode: all Operating environment: normal  
Generic failure mode: fail to open Original failure mode: fail to open on demand  
FAILURE RATE OR PROBABILITY mean : 1.8E-4/d 95%: 2.8E-4/d 5%: 6.9E-5/d  
Source: Old PWR Ultimate source: generic data updater with plant operating experience  
Comment: Generic mean 2.7E-4/d. Operating experience 14262 demands, 2 failures.

01 Source category: updated

VCW00 valve self operated check swing  
Component boundary: detail n/a Operating mode: all Operating environment: normal  
Generic failure mode: fail to open Original failure mode: failure to open  
FAILURE RATE OR PROBABILITY mean : 9.8E-5/d 95%: 2.1E-4/d 5%: 2.0E-5/d  
Source: Oconee NPP PRA (tbl.b-1.) Ultimate source: generic data updated with plant specific operating experience  
Comment: Prior:NUREG 1363, check valve failure to open on demand. Operating experience: 427 demands, no failures.  
95%/5% ratio is 10 indicating moderate degree of uncertainty.

02 Source category: updated

VCZ00 valve self operated check tilting disc check valve  
Component boundary: detail n/a Operating mode: all Operating environment: normal  
Generic failure mode: fail to open Original failure mode: failure to open  
FAILURE RATE OR PROBABILITY mean : 8.7E-5/d 95%: 1.7E-4/d 5%: 1.9E-5/d  
Source: Oconee NPP PRA (tbl.b-1.) Ultimate source: generic data updated with plant specific operating experience  
Comment: Prior:NUREG 1363, check valve failure to open on demand Operating experience: 2707 demands, no failures.  
95%/5% ratio is 10 indicating moderate degree of uncertainty.

Z Source category: updated

VCA0Z valve self operated check  
Component boundary: detail n/a Operating mode: all Operating environment: normal  
Generic failure mode: fail to open Original failure mode: failure to open on demand  
FAILURE RATE OR PROBABILITY mean : 4.3E-5/d  
Source: ZION NPP PSS (tbl.1.5.1-5) Ultimate source: generic data updated with plant operating experience  
Comment: Prior:NUREG 1363 check valves(PWR),fail to open (mean) and WASH 1400 check valves, fail to oeph (distrib.).  
Operating experience:6968 demands, no failures.


F1 Source category: plant specific

VCSOF valve self operated check (2-6")  
Component boundary: detail n/a Operating mode: all Operating environment: normal  
Generic failure mode: fail to open Original failure mode: fail to open  
FAILURE RATE OR PROBABILITY mean : 6.8E-6/d 95%: 3.3E-5/d 5%: 2.5E-6/d ERROR FACTOR: 2.8 REPAIR TIME: 6 hours  
Source: HWR data Ultimate source: HWR operating experience  
Comment: Pop.662.Cum.operating time 51E+6 hours. 1 failure. No.of demands in cumulative operational time not known.Original time related value changed to demand related assuming monthly testing.

F2 Source category: plant specific

VCBOF valve self operated check (<2")  
Component boundary: detail n/a Operating mode: all Operating environment: normal  
Generic failure mode: fail to open Original failure mode: fail to open  
FAILURE RATE OR PROBABILITY mean : 2.5E-6/d 95%: 1.2E-5/d 5%: 8.3E-7/d ERROR FACTOR: 3.0 REPAIR TIME: 4 hours  
Source: HWR data Ultimate source: HWR operating experience  
Comment: Pop.1907.Cum.operating time 1.4E+8 hours.No.of failure 1. No.of demands not known.Original time related value changed to demand related assuming monthly testing.

# IAEA RELIABILITY DATA BASE



T1 Source category: generic

VCJET valve self operated check (>100 mm)  
 Component boundary: detail n/a Operating mode: all Operating environment: normal  
 Generic failure mode: fail to close Original failure mode: failure to close  
 FAILURE RATE OR PROBABILITY mean : 3.4E-3/d 95%: 1.9E-2/d REPAIR TIME: 9 hours  
 Source: Swedish Rel.data book, tbl.19 Ultimate source: plant operating experience(7 BWR plants), ATV reports, LERs  
 Comment: Total pop.168.No.of demands per operational time 3211.No.of failures 11. a=0.0568; b=16.5 Critical failures reported at 5 plants.

G Source category: generic

VCAEG valve self operated check  
 Component boundary: detail n/a Operating mode: all Operating environment: normal  
 Generic failure mode: fail to close Original failure mode: fail to close  
 FAILURE RATE OR PROBABILITY mean : 1.1E-3/d ERROR FACTOR: 3  
 Source: German Risk Study (pg.P3-77) Ultimate source: generic data  
 Comment: Failure rate used is combination of several generic data sources. Regarding operating experience, there was 1 recorded failure in 2.6E+6 hours.Time rrl.changed to demand assuming monthly testing.

I Source category: generic

VCAEI valve self operated check  
 Component boundary: detail n/a Operating mode: all Operating environment: normal  
 Generic failure mode: fail to close Original failure mode: failure to close  
 FAILURE RATE OR PROBABILITY mean : 1.0E-3/d ERROR FACTOR: 3  
 Source: IREP NUREG 2728 (tb.5.1-1) Ultimate source: expert opinion  
 Comment: Hourly rate 3.0E 6(EF 10) based on one actuation per month

X Source category: generic

VCAEX valve self operated check  
 Component boundary: detail n/a Operating mode: all Operating environment: normal  
 Generic failure mode: fail to close Original failure mode: fail to close  
 FAILURE RATE OR PROBABILITY mean : 1.0E-3/d 80%: 3.0E-3/d 20%: 2.0E-4/d  
 Source: VVER reliability data base Ultimate source: expert opinion, operating experience  
 Comment:

J Source category: generic

VCAEJ valve self operated check  
 Component boundary: detail n/a Operating mode: all Operating environment: normal  
 Generic failure mode: fail to close Original failure mode: fails to close (causing back leakage)  
 FAILURE RATE OR PROBABILITY mean : 1.0E 3/d ERROR FACTOR: 3  
 Source: NUREG 4550, Vol.1,tbl.VIII.1.2 Ultimate source: assessed from several nuclear data sources  
 Comment: Value used is from IREP Procedure Guide.

S1 Source category: generic

VCNES valve self operated check testable  
 Component boundary: detail n/a Operating mode: all Operating environment: normal  
 Generic failure mode: fail to close Original failure mode: fails to prevent flow  
 FAILURE RATE OR PROBABILITY mean : 7.9E 4/d  
 Source: Shoreham PRA,GE data(tb A.2-1) Ultimate source: evaluation of BWR operating experience  
 Comment: Original time related value changed to demand related assuming monthly testing.

8 Source category: generic

VCAEB valve self operated check  
 Component boundary: detail n/a Operating mode: all Operating environment: normal  
 Generic failure mode: fail to close Original failure mode: failure to close  
 FAILURE RATE OR PROBABILITY mean :  $7.2E-4/d$  max:  $3.6E-3/d$  min:  $2.2E-4/d$   
 Source: NUREG 2815 (table C.1.) Ultimate source: expert opinion and IREP data  
 Comment: Original time related value changed to demand related assuming monthly testing.

U Source category: generic

VCAEU valve self operated check  
 Component boundary: detail n/a Per hr changed to per demand (360 hrs) Operating mode: all Operating environment: normal  
 Generic failure mode: fail to close Original failure mode: failure to close  
 FAILURE RATE OR PROBABILITY mean :  $7.2E-4/d$   
 Source: Sizewell B (PWR/RX312 pg.4) Ultimate source: assessed from nuclear experience and data  
 Comment: Assessment based on W data item, literature data, and SRS data item ( $2.0E-4/d$ ). For monthly tested valves stdby prob. of  $2.0E-6/hr$  gives average failure prob. of  $7.2E-4/d$ .


S2 Source category: generic

VCAES valve self operated check  
 Component boundary: detail n/a Operating mode: all Operating environment: normal  
 Generic failure mode: fail to close Original failure mode: fails to prevent flow  
 FAILURE RATE OR PROBABILITY mean :  $5.8E-4/d$   
 Source: Shoreham PRA, GE data (tbl.A.2.1) Ultimate source: evaluation of BWR operating experience  
 Comment: Original time related value changed to demand related assuming monthly testing.

T2 Source category: generic

VC1ET valve self operated check <100 mm  
 Component boundary: detail n/a Operating mode: all Operating environment: normal  
 Generic failure mode: fail to close Original failure mode: failure to close  
 FAILURE RATE OR PROBABILITY mean :  $5.5E-4/d$  REPAIR TIME: 12 hours  
 Source: Swedish Rel. data book, tbl.18 Ultimate source: plant operating experience (7 BWR plants), ATV reports, LERs  
 Comment: Total pop. 417. No. of demands per operational time 3628. No of failures  $2.a=0.0129$ ;  $b=23.3$  Critical failures at one plant only.  
 No failure to open observed out of 3628 demands.

# IAEA RELIABILITY DATA BASE



H1 Source category: updated

VCMEH valve self operated check (main steam)  
 Component boundary: detail n/a Operating mode: all Operating environment: normal  
 Generic failure mode: fail to close Original failure mode: fail to close on demand  
 FAILURE RATE OR PROBABILITY mean : 2.4E-4/d 95%: 4.7E-4/d 5%: 5.2E-5/d  
 Source: Old PWR Ultimate source: generic data updated with plant operating experience  
 Comment: Generic mean 2.7E-4/d. Operating experience 378 demands, no failures.

H2 Source category: updated

VCAEH valve self operated check  
 Component boundary: detail n/a Operating mode: all Operating environment: normal  
 Generic failure mode: fail to close Original failure mode: fail to close on demand  
 FAILURE RATE OR PROBABILITY mean : 2.8E-4/d 95%: 4.5E-4/d 5%: 1.4E-4/d  
 Source: Old PWR Ultimate source: generic data updated with plant operating experience  
 Comment: Generic mean 2.7E-4/d. Operating experience 14262 demands, 5 failures.

O1 Source category: updated

VCZEO valve self operated check tilting disc  
 Component boundary: detail n/a Operating mode: all Operating environment: normal  
 Generic failure mode: fail to close Original failure mode: failure to close  
 FAILURE RATE OR PROBABILITY mean : 1.3E-4/d 95%: 2.7E-4/d 5%: 3.0E-5/d  
 Source: Oconee NPP PRA (tbl.b-1.) Ultimate source: generic data updated with plant specific operating experience  
 Comment: Prior: NUREG 1363, check valve failure to close on demand. Operating experience: 2719 demands, 1 failure.  
 95%/5% ratio is 10 indicating moderate degree of uncertainty.

O2 Source category: updated

VCWEO valve self operated check swing  
 Component boundary: detail n/a Operating mode: all Operating environment: normal  
 Generic failure mode: fail to close Original failure mode: failure to close  
 FAILURE RATE OR PROBABILITY mean : 9.8E-5/d 95%: 2.1E-4/d 5%: 2.0E-5/d  
 Source: Oconee NPP PRA (tbl.b-1.) Ultimate source: generic data updated with plant specific operating experience  
 Comment: Prior: NUREG 1363, check valve failure to close on demand. Operating experience: 426 demands, no failures  
 95%/5% ratio is 10 indicating moderate degree of uncertainty.

F1 Source category: plant specific

VCTEF valve self operated check (6-12")  
 Component boundary: detail n/a Operating mode: all Operating environment: normal  
 Generic failure mode: fail to close Original failure mode: fail to close  
 FAILURE RATE OR PROBABILITY mean : 5.0E-5/d 95%: 1.2E-4/d 5%: 2.5E-5/d ERROR FACTOR: 2 REPAIR TIME: 6 hours  
 Source: HWR data Ultimate source: HWR operating experience  
 Comment: Pop.390. Cumulative component operating time 29E+6 hours. No. of failures 4. Number of demands per operational time is not known.  
 Org.time rel.value changed to demand rel.assuming monthly testing

F2 Source category: plant specific

VCLEF valve self operated check (12-24")  
 Component boundary: detail n/a Operating mode: all Operating environment: normal  
 Generic failure mode: fail to close Original failure mode: fail to close  
 FAILURE RATE OR PROBABILITY mean : 4.3E-5/d 95%: 1.2E-4/d 5%: 2.1E-5/d ERROR FACTOR: 2.1 REPAIR TIME: 19 hours  
 Source: HWR data Ultimate source: HWR operating experience  
 Comment: Pop.343. Cum. operating time 24.4E+6 hours. No. of failures 3. No. of demands in cumulative component operating time is not known.  
 Org.time rel.value changed to demand rel.assuming monthly testing



F3 Source category: plant specific

VCSEF valve self operated check (2-6")  
 Component boundary: detail n/a Operating mode: all Operating environment: normal  
 Generic failure mode: fail to close Original failure mode: fail to close  
 FAILURE RATE OR PROBABILITY mean : 4.0E-5/d 95%: 7.9E-5/d 5%: 2.4E-5/d ERROR FACTOR: 1.8 REPAIR TIME: 6 hours  
 Source: HWR data Ultimate source: HWR operating experience  
 Comment: Pop.662.Cum.operating time 51E+6 hours.6 failures. No.of demands in cumulative opearting time is not known.  
 Org.time rel.value changed to demand rel.assuming monthly testing


F4 Source category: plant specific

VCBEF valve self operated check (>2")  
 Component boundary: detail n/a Operating mode: all Operating environment: normal  
 Generic failure mode: fail to close Original failure mode: fail to close  
 FAILURE RATE OR PROBABILITY mean : 1.2E-5/d 95%: 2.5E-5/d 5%: 4.0E-6/d ERROR FACTOR: 2 REPAIR TIME: 4 hours  
 Source: HWR data Ultimate source: HWR operating experience  
 Comment: Pop.1907.Cum.operating time 1.4E+8 hours. No.of failures 4. No.of demands not known.  
 Org.time rel.value changed to demand rel.assuming monthly testing

Z Source category: updated

VCAEZ valve self operated check  
 Component boundary: detail n/a Operating mode: all Operating environment: normal  
 Generic failure mode: fail to close Original failure mode: failure to seat/excessive leakage  
 FAILURE RATE OR PROBABILITY mean : 8.4E-7/d  
 Source: ZION NPP PSS (tbl.1.5.1-5) Ultimate source: generic data updated with plant operating experience  
 Comment: Priors:NUREG 1363 check valve(PWR),internal leakage (mean) and WASH 1400, check valves, reverse leakage (distrib).  
 Operating experience:6.08E+5 hours of operation, no failures.

# IAEA RELIABILITY DATA BASE



G Source category: generic

VDACG valve solenoid operated general  
 Component boundary: detail n/a Operating mode: all Operating environment: normal  
 Generic failure mode: fail to change position Original failure mode: fail to open or to close  
 FAILURE RATE OR PROBABILITY mean : 1.3E-2/d ERROR FACTOR: 20  
 Source: German Risk Study (pg.P3-75) Ultimate source: generic data  
 Comment: There is no specific operating experience data for this component and failure rate is combination of several generic data sources  
 (6).Org.time rel.value changed to demand assuming monthly testing

J Source category: generic

VDACJ valve solenoid operated general  
 Component boundary: detail n/a Operating mode: all Operating environment: normal  
 Generic failure mode: fail to change position Original failure mode: fails to operate  
 FAILURE RATE OR PROBABILITY mean : 1.0E-3/d ERROR FACTOR: 3  
 Source: NUREG 4550, Vol.1,tbl.VIII.1-2 Ultimate source: assessed from several nuclear data sources  
 Comment: Same value as for air operated valve. Two types of failures included in the failure rate: valve hardware fault (1.0E-3) and  
 command circuit faults (1.0E-4).

W Source category: generic

VDACW valve solenoid operated general  
 Component boundary: detail n/a Operating mode: all Operating environment: normal  
 Generic failure mode: fail to change position Original failure mode: failure to operate  
 FAILURE RATE OR PROBABILITY median: 1.0E-3/d 95%: 3.0E-3/d 5%: 3.0E-4/d ERROR FACTOR: 3  
 Source: WASH 1400 (table III 4-1) Ultimate source: assessed from nuclear, industrial and military experience and data  
 Comment: Based on presence of proper input signal Failure of a valve to operate include changing state from closed  
 to open or from open to closed position.

I Source category: generic

VDACI valve solenoid operated general  
 Component boundary: detail n/a Operating mode: all Operating environment: normal  
 Generic failure mode: fail to change position Original failure mode: failure to operate  
 FAILURE RATE OR PROBABILITY mean : 1.0E-3/d ERROR FACTOR: 3  
 Source: IREP NUREG 2728 (tb.5.1-1) Ultimate source: expert opinion  
 Comment:


B Source category: generic

VDACB valve solenoid operated general  
 Component boundary: detail n/a Operating mode: all Operating environment: normal  
 Generic failure mode: fail to change position Original failure mode: failure to operate  
 FAILURE RATE OR PROBABILITY mean : 7.2E-4/d max: 3.6E-3/d min: 2.9E-4/d  
 Source: NUREG 2815 (table C.1.) Ultimate source: expert opinion and IREP data  
 Comment: Original time related value changed to demand related assuming monthly testing

T Source category: generic

VDNCT valve solenoid operated general (normally activated)  
 Component boundary: detail n/a Operating mode: normally activated Operating environment: normal  
 Generic failure mode: fail to change position Original failure mode: failure to function  
 FAILURE RATE OR PROBABILITY mean : 2.6E-4/d 95%: 1.3E-3/d REPAIR TIME: 3 hours  
 Source: Swedish Rel.data book, tbl.23 Ultimate source: plant operating experience (7 BWR plants), ATV reports, LERS  
 Comment: Total pop.513.Operating time 2260E+4 hours. No.of failures 16. Critical failures reported on 2 plants.  
 a=0.0487; b=68600.Time rel.changed to demand assuming month.tests

# IAEA RELIABILITY DATA BASE



V Source category: generic

VRBOV valve primary relief valve BWR  
 Component boundary: valve body and internals, operating mechanism Operating mode: all Operating environment: normal  
 Generic failure mode: fail to open Original failure mode: failure to open  
 FAILURE RATE OR PROBABILITY mean : 8.9E-3/d 95%: 1.1E-2/d 5%: 6.8E-3/d  
 Source: NUREG 1363 (1982) (pg.474) Ultimate source: US plants LER reports evaluation  
 Comment: Incl.all BWR safety-relief vlv(ADS and ordinary relief).W/o comm. W command 1.1E-2/d.No.of demands is 1 test and operational demand equal to tot.no.of forced and manual scrams.Rate 8.7E-6/hr stdby.

U Source category: generic

VRPOU valve power operated relief (PORV)  
 Component boundary: detail n/a Per hour changed to per demand with 2160 hrs Operating mode: standby Operating environment: normal  
 Generic failure mode: fail to open Original failure mode: failure to open  
 FAILURE RATE OR PROBABILITY mean : 5.6E-3/d  
 Source: Sizewell B (PWR/RX312 pg.5) Ultimate source: assessed from nuclear experience and data  
 Comment: The same failure rate applicable for safety valves.Assesment based on W data,WASH 1400 and SRS data item(7.0E-3/d).For yearly testing stdby failrate(2.6E-6/hr)gives peak rate 2.3E-2/d(pessimistic).

X Source category: generic

VRAOX valve power or pilot operated relief valve  
 Component boundary: detail n/a Operating mode: all Operating environment: normal  
 Generic failure mode: fail to open Original failure mode: fail to open  
 FAILURE RATE OR PROBABILITY mean : 1.0E-3/d 80%: 1.0E-2/d 20%: 1.0E-4/d  
 Source: VVER reliability data base Ultimate source: expert opinion, operating experience  
 Comment:

I Source category: generic

VRAOI valve relief valve  
 Component boundary: detail n/a Operating mode: all Operating environment: normal  
 Generic failure mode: fail to open Original failure mode: failure to open  
 FAILURE RATE OR PROBABILITY mean : 3.0E-4/d ERROR FACTOR: 10  
 Source: IREP NUREG 2728 (tbl.5.1-1) Ultimate source: expert opinion  
 Comment:

W Source category: generic

VRAOW valve relief  
 Component boundary: detail n/a Operating mode: all Operating environment: normal  
 Generic failure mode: fail to open Original failure mode: failure to open  
 FAILURE RATE OR PROBABILITY median: 1.0E-5/d 95%: 3.0E-5/d 5%: 3.0E-6/d ERROR FACTOR: 3  
 Source: WASH 1400 (table III 4-1) Ultimate source: assessed from nuclear, industrial(SRS) and mil.experience and data  
 Comment:

O Source category: updated

VRPOO valve power operated relief PORV  
 Component boundary: detail n/a Operating mode: standby Operating environment: normal  
 Generic failure mode: fail to open Original failure mode: failure to open  
 FAILURE RATE OR PROBABILITY mean : 4.9E-3/d 95%: 1.1E-2/d 5%: 2.1E-4/d  
 Source: Oconee NPP PRA (tbl.b-1.) Ultimate source: generic data updated with plant specific operating experience  
 Comment: Prior: NUREG 1363 (1980),BWR relief open on demand. BWR used because lack of PWR PORV data, and similarities between PORV and AD function.Op.experience 31 demand, no failures.

H1 Source category: updated

VRPOH valve power operated relief PORV


Component boundary: detail n/a Operating mode: closed Operating environment: normal  
 Generic failure mode: fail to open Original failure mode: fail to open on demand  
 FAILURE RATE OR PROBABILITY mean : 4.2E-3/d 95%: 8.6E-3/d 5%: 1.0E-3/d  
 Source: Old PWR Ultimate source: generic data updated with plant operating experience  
 Comment: Generic mean 4.3E-3/d . Operating experience 8 demands, no failures.

H2 Source category: updated

VRMOH valve relief (main steam atmospheric relief)

Component boundary: detail n/a Operating mode: closed Operating environment: normal  
 Generic failure mode: fail to open Original failure mode: fail to open on demand  
 FAILURE RATE OR PROBABILITY mean : 3.0E-3/d 95%: 7.0E-3/d 5%: 3.6E-4/d  
 Source: Old PWR Ultimate source: generic data updated with plant operating experience  
 Comment: Generic mean 2.4E-3/d. Operating experience 199 demands, 1 failure.

# IAEA RELIABILITY DATA BASE



J Source category: generic

VRPEJ valve power operated relief valve PORV  
Component boundary: detail n/a Operating mode: all Operating environment: normal  
Generic failure mode: fail to close Original failure mode: fails to reclose  
FAILURE RATE OR PROBABILITY mean :  $3.0E-2/d$  ERROR FACTOR: 10  
Source: NUREG 4550, Vol.1,tbl.VIII.1-2 Ultimate source: assessed from several nuclear data sources  
Comment: This value is also applicable to Safety Relief Valves. ASEP used generic value from IREP procedure guide, but it also falls into the range indicated by LERs.

I Source category: generic

VRAEI valve relief valve  
Component boundary: detail n/a Operating mode: all Operating environment: normal  
Generic failure mode: fail to close Original failure mode: failure to close, given open  
FAILURE RATE OR PROBABILITY mean :  $2.0E-2/d$  ERROR FACTOR: 3  
Source: IREP NUREG 2728 (tbl.5.1-1) Ultimate source: expert opinion  
Comment:

X Source category: generic

VRAEX valve power or pilot operated relief valve  
Component boundary: detail n/a Operating mode: all Operating environment: normal  
Generic failure mode: fail to close Original failure mode: fail to close  
FAILURE RATE OR PROBABILITY mean :  $2.0E-2/d$  80%:  $4.0E-2/d$  20%:  $2.5E-3/d$   
Source: VVER reliability data base Ultimate source: expert opinion  
Comment:

U Source category: generic

VRPEU valve power operated relief valve PORV  
Component boundary: detail n/a Per hour changed to per demand with 2160 hrs. Operating mode: all Operating environment: normal  
Generic failure mode: fail to close Original failure mode: failure to close  
FAILURE RATE OR PROBABILITY mean :  $1.1E-2/d$   
Source: Sizewell B (PWR/RX312 pg.5) Ultimate source: assessed from nuclear experience and data  
Comment: Assessment based on W data item and SRS data item applicable to PORV's( $4.0E-2/d$ ). Original time related value changed to demand related assuming 1 demand/1/2 year.

V Source category: generic

VRBEV valve primary relief valve BWR  
Component boundary: valve body and internals, operating mechanism Operating mode: all Operating environment: normal  
Generic failure mode: fail to close Original failure mode: fail to reseal  
FAILURE RATE OR PROBABILITY mean :  $3.1E-3/d$  95%:  $4.7E-3/d$  5%:  $2.1E-3/d$   
Source: NUREG 1363 (1982) (pg.482) Ultimate source: US plants LER reports evaluation  
Comment: See comment relief failure to open.Standby hourly rate  $3.0E-6/hr$ . W/o command faults. With command faults  $3.2E-3/d$ .Standby hourly rate with command faults  $3.2E-6/hr$ .




H Source category: updated

VRPEH valve power operated relief PORV  
 Component boundary: detail n/a Operating mode: standby Operating environment: normal  
 Generic failure mode: fail to close Original failure mode: fail to close on demand  
 FAILURE RATE OR PROBABILITY mean :  $3.3\text{E-}2/\text{d}$  95%:  $6.7\text{E-}2/\text{d}$  5%:  $1.0\text{E-}2/\text{d}$   
 Source: Old PWR Ultimate source: generic data updated with plant operating experience  
 Comment: Generic mean  $2.5\text{E-}2/\text{d}$ . Operating experience 8 demands, 1 failure.

O Source category: updated

VRPEO valve power operated relief PORV  
 Component boundary: detail n/a Operating mode: standby Operating environment: normal  
 Generic failure mode: fail to close Original failure mode: failure to close  
 FAILURE RATE OR PROBABILITY mean :  $1.1\text{E-}2/\text{d}$  95%:  $3.0\text{E-}2/\text{d}$  5%:  $6.9\text{E-}4/\text{d}$   
 Source: Oconee NPP PRA (tbl.b-1.) Ultimate source: generic data updated with plant specific operating experience  
 Comment: Prior: NUREG 1363. Failure to reclose after water or steam relief has the same distribution, based on EPRI valve test program.  
 Operating experience: 31 demands, 1 failure.

# IAEA RELIABILITY DATA BASE



B1 Source category: generic

VSC08 valve self operated code safety valve  
Component boundary: detail n/a Operating mode: all Operating environment: normal  
Generic failure mode: fail to open Original failure mode: failure to open  
FAILURE RATE OR PROBABILITY mean : 6.5E-3/d max: 8.6E-2/d min: 1.3E-3/d  
Source: NUREG 2815 (table C.1.) Ultimate source: expert opinion and IREP data  
Comment: Applies to PWR only. Premature opening covered under initiating events. Original time related value changed to demand related assuming demand occurring every 1/2 year.

B2 Source category: generic

VSB0B valve self operated primary safety valve  
Component boundary: detail n/a Operating mode: all Operating environment: normal  
Generic failure mode: fail to open Original failure mode: failure to open  
FAILURE RATE OR PROBABILITY mean : 4.3E-2/d max: 4.3E 1/d min: 1.7E-2/d  
Source: NUREG 2815 (table C.1.) Ultimate source: expert opinion and IREP data  
Comment: applies to BWR only Original time related value changed to demand related assuming demand occurring every 1/2 year.

E Source category: generic

VSA0E valve safety  
Component boundary: detail n/a Operating mode: all Operating environment: normal  
Generic failure mode: fail to open Original failure mode: fail to open  
FAILURE RATE OR PROBABILITY rec : 4.0E-3/cy  
Source: IEEE 500 (1984) pg.1040 Ultimate source: expert judgement(delphi procedure) & experience  
Comment: reference EGG-EA -5B16 1982

G Source category: generic

VST0G valve pilot valve operated safety valve (pressurizer or main steam line)(with 2 or 3 pilots)  
Component boundary: detail n/a Operating mode: closed Operating environment: normal  
Generic failure mode: fail to open Original failure mode: fail to open  
FAILURE RATE OR PROBABILITY median: 4.0E-3/d ERROR FACTOR: 6  
Source: German Risk Study (tb.F3,7-1) Ultimate source: operating experience  
Comment: Operating experience: 20 test and 80 operational demands, no failures reported. It is assumed that having more than one pilot valve lower actual valve opening failure rate.N/a to water relief

V Source category: generic

VSP0V valve self operated safety valves PWR  
Component boundary: valve body and internals, operating mechanism Operating mode: all Operating environment: normal  
Generic failure mode: fail to open Original failure mode: fail to open  
FAILURE RATE OR PROBABILITY mean : 3.9E-3/d 95%: 7.4E-3/d 5%: 1.8E-3/d  
Source: NUREG 1363 (1982) (pg.465) Ultimate source: US plants LER reports evaluation  
Comment: Overall data.Standby hourly rate is 1.7E-6/hr. Demand rate is taking into account 5 years test interval,and operational demands in observed period (demand=1/2 of all forced scrams,PWR)

X Source category: generic

VSA0X valve safety  
Component boundary: detail n/a Operating mode: all Operating environment: normal  
Generic failure mode: fail to open Original failure mode: fail to open  
FAILURE RATE OR PROBABILITY mean 2.0E-3/d 80%: 1.2E-2/d 20% 3.3E-4/d  
Source: VVER reliability data base Ultimate source: expert opinion  
Comment:

T Source category: generic

VSR0T valve pilot valve operated safety valve  
 Component boundary: detail n/a Operating mode: all Operating environment: normal  
 Generic failure mode: fail to open Original failure mode: failure to open  
 FAILURE RATE OR PROBABILITY mean :  $7.8E-4/d$  95%:  $1.4E-3/d$  REPAIR TIME: 9 hours  
 Source: Swedish Rel.data book, tbl.22 Ultimate source: plant operating experience( 7 BWR plants),ATV reports, LERs  
 Comment: Total pop.126.No.of demands 1281.No of failures 1.a=0.0167;b=21.4 Pilot valve see "vwkot". Safety valve+pilot valve=pressure relief system.Critical failure on one plant only.

I1 Source category: generic

VSC0I valve self operated code safety valve  
 Component boundary: detail n/a Operating mode: all Operating environment: normal  
 Generic failure mode: fail to open Original failure mode: failure to open  
 FAILURE RATE OR PROBABILITY mean :  $1.0E-5/d$  ERROR FACTOR: 3  
 Source: IREP NUREG 2728 (tbl.5.1-1) Ultimate source: expert opinion  
 Comment: Applies to PWR only. Premature opening is treated as an initiating event.

I2 Source category: generic

VSB0I valve self operated primary safety valves  
 Component boundary: detail n/a Operating mode: all Operating environment: normal  
 Generic failure mode: fail to open Original failure mode: failure to open  
 FAILURE RATE OR PROBABILITY mean :  $1.0E-5/d$  ERROR FACTOR: 3  
 Source: IREP NUREG 2728 (tbl.5.1-1) Ultimate source: expert opinion  
 Comment: applies to BWR only


O Source category: updated

VSD0O valve self operated pressurizer safety valve  
 Component boundary: detail n/a Operating mode: standby Operating environment: normal  
 Generic failure mode: fail to open Original failure mode: failure to open  
 FAILURE RATE OR PROBABILITY mean :  $2.7E-4/d$  95%:  $8.0E-4/d$  5%:  $7.4E-6/d$   
 Source: Oconee NPP PRA (tbl.b-1.) Ultimate source: generic data updated with plant specific operating experience  
 Comment: Prior:Median of General Atomic data base (GCR) for primary relief valves, range factor 10.  
 Operating experience: 10 demands, no failures.

H Source category: updated

VSMOH valve self operated safety(main steam)  
 Component boundary: detail n/a Operating mode: closed Operating environment: normal  
 Generic failure mode: fail to open Original failure mode: fail to open on demand  
 FAILURE RATE OR PROBABILITY mean :  $3.3E-4/d$  95%:  $1.1E-3/d$  5%:  $1.3E-5/d$   
 Source: Old PWR Ultimate source: generic data updated with plant operating experience  
 Comment: Generic mean  $3.3E-4/d$ . Operating experience 10 demands, no failures.

# IAEA RELIABILITY DATA BASE



B1 Source category: generic

VSBE8 valve self operated primary safety valve  
Component boundary: detail n/a Operating mode: all Operating environment: normal  
Generic failure mode: fail to close Original failure mode: failure to close, given open  
FAILURE RATE OR PROBABILITY mean : 4.3E-2/d max: 4.3E-1/d min: 1.7E-2/d  
Source: NUREG 2815 (table C.1.) Ultimate source: expert opinion and IREP data  
Comment: applies to BWR only Original time related value changed to demand related assuming demand occurring every 1/2 year.

B2 Source category: generic

VSCEB valve self operated code safety valve  
Component boundary: detail n/a Operating mode: all Operating environment: normal  
Generic failure mode: fail to close Original failure mode: failure to close, given open  
FAILURE RATE OR PROBABILITY mean : 4.3E-2/d max: 4.3E-1/d min: 1.7E-2/d  
Source: NUREG 2815 (table C.1.) Ultimate source: expert opinion and IREP data  
Comment: Applies to PWR only Original time related value changed to demand related assuming demand occurring every 1/2 year.

I1 Source category: generic

VSBEI valve self operated primary safety valve  
Component boundary: detail n/a Operating mode: all Operating environment: normal  
Generic failure mode: fail to close Original failure mode: failure to close, given open  
FAILURE RATE OR PROBABILITY mean : 3.0E-2/d ERROR FACTOR: 10  
Source: IREP NUREG 2728 (tb.5.1-1) Ultimate source: expert opinion  
Comment: applies to BWR only

X Source category: generic

VSAEX valve safety  
Component boundary: detail n/a Operating mode: all Operating environment: normal  
Generic failure mode: fail to close Original failure mode: fail to close  
FAILURE RATE OR PROBABILITY mean : 1.0E-2/d 80%: 3.0E-2/d 20%: 2.3E-3/d  
Source: VVER reliability data base Ultimate source: expert opinion  
Comment:

I2 Source category: generic

VSCEI valve self operated code safety valve  
Component boundary: detail n/a Operating mode: all Operating environment: normal  
Generic failure mode: fail to close Original failure mode: failure to close, given open  
FAILURE RATE OR PROBABILITY mean : 1.0E-2/d ERROR FACTOR: 3  
Source: IREP NUREG 2728 (tb.5.1-1) Ultimate source: expert opinion  
Comment: applies to PWR only

G Source category: generic

VSTEG valve pilot valve operated safety valve (pressurizer or main steam line)(with 2 or 3 pilot)  
Component boundary: detail n/a Operating mode: closed Operating environment: normal  
Generic failure mode: fail to close Original failure mode: fail to close  
FAILURE RATE OR PROBABILITY median: 7.0E-3/d ERROR FACTOR: 4  
Source: German Risk Study (tb.F3.7-1) Ultimate source: operating experience  
Comment: Operating experience: 20 test and 80 operational demands, no failures. Failure rate is not influenced by number of pilot valves. Not applicable to water relief safety valves.

U Source category: generic

VSAEU valve self operated safety relief valve  
 Component boundary: detail n/a Per hour changed to per demand using 2160hrs. Operating mode: all Operating environment: normal  
 Generic failure mode: fail to close Original failure mode: failure to close  
 FAILURE RATE OR PROBABILITY mean : 1.5E-3/d  
 Source: Sizewell B (PWR/RX312 pg.5) Ultimate source: assessed from nuclear experience and data  
 Comment: Assesment based on W data item and SRS data applicable to SRVs, (6.0E-3/d).Original time related value changed to demand related assuming demand occuring every 1/2 year.

T Source category: generic

VSRET valve self operated (pilot operated) safety valve (pressure relief system)  
 Component boundary: detail n/a Operating mode: all Operating environment: normal  
 Generic failure mode: fail to close Original failure mode: failure to reclose  
 FAILURE RATE OR PROBABILITY mean : 2.4E-3/d 95%: 7.2E-3/d REPAIR TIME: 9 hours  
 Source: Swedish Rel.data book, tbl.22 Ultimate source: plant operating experience (BWR plants), ATV reports, LERS  
 Comment: Total pop.126.No.of demands 1281.No.of failures 2. Pilot valve see "vwket". a=0.0232; b=9.67  
 Critical failures reported on 2 plants.


H Source category: updated

VSMEH valve self operated safety (main steam)  
 Component boundary: detail n/a Operating mode: closed Operating environment: normal  
 Generic failure mode: fail to close Original failure mode: fail to close on demand  
 FAILURE RATE OR PROBABILITY mean : 2.6E-3/d 95%: 7.1E-3/d 5%: 8.8E-5/d  
 Source: Old PWR Ultimate source: generic data updated with plant operating experience  
 Comment: Generic mean 2.9E-3/d.Operating experience 10 demands, no failures.

O Source category: updated

VSDEO valve self operated pressurizer safety valve  
 Component boundary: detail n/a Operating mode: standby Operating environment: normal  
 Generic failure mode: fail to close Original failure mode: failure to close  
 FAILURE RATE OR PROBABILITY mean : 4.8E-3/d 95%: 1.0E-2/d 5%: 1.1E-3/d  
 Source: Oconee NPP PRA (tbl.b-1.) Ultimate source: generic data updated with plant specific operating experience  
 Comment: Prior:Median,failure to reclose(steam relief) Babcock&Wilcox Co. Distribution based on EPRI test.  
 Operating experience: 10 deamnds, no failure. ONLY STEAM RELIEF

# IAEA RELIABILITY DATA BASE





I Source category: generic

DGASI diesel generator emergency AC  
 Component boundary: engine, gen. coupling, governor, out. breaker, exciter, lube & fuel oil Operating mode: standby Operating environment: normal  
 Generic failure mode: fail to start Original failure mode: failure to start  
 FAILURE RATE OR PROBABILITY mean :  $3.0E-2/d$  ERROR FACTOR: 3  
 Source: IREP NUREG 2728 (tb.5.1-1) Ultimate source: expert opinion  
 Comment: BOUNDARY contd. starting system, intake and exhaust air. Excluded: starting air compressor and accumulator, fuel storage & transfer load sequencer & synchroiser. Failmode incl. running for 1/2 hour.

J Source category: generic

DGASJ diesel generator emergency AC  
 Component boundary: detail n/a Operating mode: standby Operating environment: normal  
 Generic failure mode: fail to start Original failure mode: failure to start  
 FAILURE RATE OR PROBABILITY mean :  $3.0E-2/d$  ERROR FACTOR: 3  
 Source: NUREG 4550, Vol.1, tbl. VIII.1-2 Ultimate source: assessed from several nuclear data sources  
 Comment: ASEP used generic value from the Reliability of AC Power System Study (NUREG/CR-2989) which contain industry wide data.

U Source category: generic

DGASU diesel generator emergency AC  
 Component boundary: detail n/a Operating mode: standby Operating environment: normal  
 Generic failure mode: fail to start Original failure mode: failure to start  
 FAILURE RATE OR PROBABILITY mean :  $3.0E-2/d$   
 Source: Sizewell B (PWR/RX312 pg.13) Ultimate source: assessed from nuclear and industrial experience and data  
 Comment: Assessment based on W data, WASH 1400, and SRS data,  $2.6E-2/d$  out of 1567 demands and  $1.3E-2/d$  out of 5500 demands.

W Source category: generic

DGASW diesel generator emergency AC  
 Component boundary: complete plant, including starters, pumps and fueling system Operating mode: standby Operating environment: normal  
 Generic failure mode: fail to start Original failure mode: failure to start  
 FAILURE RATE OR PROBABILITY median:  $3.0E-2/d$  95%:  $1.0E-1/d$  5%:  $1.0E-2/d$  ERROR FACTOR: 3  
 Source: WASH 1400 (table III 4-2) Ultimate source: assessed from nuclear and industrial experience and data  
 Comment:

X Source category: generic

DGASX diesel generator emergency AC  
 Component boundary: detail n/a Operating mode: standby Operating environment: normal  
 Generic failure mode: fail to start Original failure mode: failure to start  
 FAILURE RATE OR PROBABILITY mean :  $3.0E-2/d$  80%:  $9.0E-2/d$  20%:  $1.0E-2/d$   
 Source: VVER reliability data book Ultimate source: expert opinion  
 Comment:

G Source category: generic

DGASG diesel generator emergency AC  
 Component boundary: DG, governor, fuel system, starting system, cooling, controls Operating mode: standby Operating environment: normal  
 Generic failure mode: fail to start Original failure mode: failure to start  
 FAILURE RATE OR PROBABILITY mean :  $3.0E-2/d$  ERROR FACTOR: 3  
 Source: German Risk Study (pg F3-86) Ultimate source: German plants operating experience  
 Comment: Starting failure include failures which happened during initial running time.  
 Operating experience ca. 810 demands, 24 failures.

B Source category: generic

DGASB diesel generator emergency AC  
 Component boundary: SEE IREP DG failure to start Operating mode: standby Operating environment: normal  
 Generic failure mode: fail to start Original failure mode: failure to start  
 FAILURE RATE OR PROBABILITY mean :  $2.1E-2/d$  max:  $1.4E-1/d$  min:  $1.1E-2/d$   
 Source: NUREG 2815 (table C.1.) Ultimate source: expert opinion aggregation and IREP data  
 Comment: Failure to start is failure to start, accept load and run for 1/2 hour. Original time related value changed to demand related assuming monthly testing.

R Source category: generic

DGASR diesel generator emergency AC  
 Component boundary: detail n/a Operating mode: standby Operating environment: normal  
 Generic failure mode: fail to start Original failure mode: failure to start  
 FAILURE RATE OR PROBABILITY pt.est:  $1.7E-2/d$   
 Source: EPRI NP-2433(1982) (table S-1) Ultimate source: operating experience (plant or utility supplied data, 13 plants)  
 Comment: Failure per demand is based on 123.5 years of experience and 6910 diesel demands.

E Source category: generic

DGASE diesel generator emergency AC  
 Component boundary: detail n/a Operating mode: standby Operating environment: normal  
 Generic failure mode: fail to start Original failure mode: fails to start  
 FAILURE RATE OR PROBABILITY rec :  $1.6E-2/cy$  high:  $4.0E-1/cy$  low:  $3.0E-4/hr$  REPAIR TIME: 11.5 hours  
 Source: IEEE 500 (1984) pg.1218 Ultimate source: expert opinion aggregation and operating experience  
 Comment: Failure rate is composite value of IEEE 500 (1977) and several nuclear sources including NUREG 1362 (1980).


T Source category: generic

DGAST diesel generator emergency AC  
 Component boundary: DG, protection & control equipment, service systems Operating mode: standby Operating environment: normal  
 Generic failure mode: fail to start Original failure mode: failure to start  
 FAILURE RATE OR PROBABILITY mean :  $7.7E-3/d$  95%:  $2.9E-2/d$  REPAIR TIME: 20 hours  
 Source: Swedish Rel.data book, tbl.40 Ultimate source: plant operating experience (7 BWR plants), ATV reports, LERs  
 Comment: Operating experience: total pop. 20. No. of demands 2090. No. of failures 16.  $a=0.552$ ;  $b=67.7$   
 Critical failures reported on 6 plants.

N Source category: generic

DG4SN diesel generator emergency AC 4160 VAC  
 Component boundary: DG, all local systems and components needed for start & operation Operating mode: standby Operating environment: normal  
 Generic failure mode: fail to start Original failure mode: failure to start  
 FAILURE RATE OR PROBABILITY rec :  $2.9E-3/d$  high:  $1.4E-2/d$  low:  $4.0E-4/d$  REPAIR TIME: 3-8 hours  
 Source: NUREG 3831 (1985) (tbl.A1) Ultimate source: operating experience (plant records)  
 Comment: Operating experience: total pop. 14. No. of 2801. No. of failures 8.  
 Repair time is range of medians.

# IAEA RELIABILITY DATA BASE



Z Source category: updated

DGASZ diesel generator emergency AC  
Component boundary: detail n/a Operating mode: standby Operating environment: normal  
Generic failure mode: fail to start Original failure mode: failure to start on demand  
FAILURE RATE OR PROBABILITY mean :  $1.8E-2/d$   
Source: ZION NPP PSS (tbl.1.5.1-5) Ultimate source: generic data upgraded with plant operating experience  
Comment: Prior:mean NUREG 1362,DG fails to start, w/o command. montly test Distribution WASH 1400,DG fail to start.  
Operating experience 1693 demands, 30 failures.

Y Source category: plant specific

DGASY diesel generator emergency AC  
Component boundary: DG,control & protection equipment, service systems Operating mode: standby Operating environment: normal  
Generic failure mode: fail to start Original failure mode: failure to start  
FAILURE RATE OR PROBABILITY mean :  $1.2E-2/d$  REPAIR TIME: 8 hours  
Source: Swedish Rel.data book, tbl.40 Ultimate source: plant operating experience (Ringhals 2),ATV reports  
Comment: Operating experience:total pop.4. No.of demands 492. No.of failures 6.  
No failures recorded out of 164 operating hours.


H Source category: updated

DGASH diesel generator emergency AC  
Component boundary: detail n/a Operating mode: standby Operating environment: normal  
Generic failure mode: fail to start Original failure mode: failure to start on demand  
FAILURE RATE OR PROBABILITY mean :  $1.1E-2/d$  95%:  $1.5E-2/d$  5%:  $6.1E-3/d$   
Source: Old PWR Ultimate source: generic data updated with plant specific operating experience  
Comment: Generic mean  $2.1E-2/d$ . Operating experience 1068 demands, 11 failures.

A Source category: plant specific

DGASA diesel generator emergency AC  
Component boundary: detail n/a Operating mode: standby Operating environment: normal  
Generic failure mode: fail to start Original failure mode: fail to start  
FAILURE RATE OR PROBABILITY median:  $7.1E-3/d$  ERROR FACTOR: 4.1  
Source: NUREG 4550/Vol.3,tbl.1V.8-1 Ultimate source: Surry NPP operating experience  
Comment:

# IAEA RELIABILITY DATA BASE



N Source category: generic

DG4RN diesel generator emergency AC 4160 V AC  
Component boundary: DG,all local systems and components needed for start & operation Operating mode: standby Operating environment: normal  
Generic failure mode: fail to run Original failure mode: fail to run  
FAILURE RATE OR PROBABILITY rec : 6.5E-3/hr high: 2.3E-2/hr low: 2.4E-3/hr REPAIR TIME: 3-8 hours  
Source: NUREG 3831 (1985) (tbl.12) Ultimate source: operating experience (plant records)  
Comment: Failure rate is combined failure modes "fail to run" and "inproper operation" because that way it is comparable with other data sources.

T Source category: generic

DGART diesel generator emergency AC  
Component boundary: DG,control & protection equipment,service systems Operating mode: standby Operating environment: normal  
Generic failure mode: fail to run Original failure mode: spurious stop  
FAILURE RATE OR PROBABILITY mean : 5.5E-3/hr 95%: 2.4E-2/hr REPAIR TIME: 20 hours  
Source: Swedish Rel.data book, tbl.40 Ultimate source: plant operating experience (7 BWR plants),ATV reports,LEERS,  
Comment: Operating experience:total pop.20. Operational time 1440 hours No.of failures 8. a=0.338; b=60.8  
Critical failures reported on 5 plants.

G Source category: generic

DGARG diesel generator emergency AC  
Component boundary: DG,governor,fuel system,starting system,cooling,controls Operating mode: standby Operating environment: normal  
Generic failure mode: fail to run Original failure mode: failure to run  
FAILURE RATE OR PROBABILITY mean : 4.5E-3/hr ERROR FACTOR: 2  
Source: German Risk Study (pg.F3-86) Ultimate source: German plants operating experience  
Comment: Operating experience:35 units observed for 2.5 years.Exact time known for 11 units(avr.76 hr/y),50 hr/y considered for the rest.  
Tot.op.time:3740 hr.No.of failures 17.SHORT OPERATING TIME RATE.

W Source category: generic

DGARW diesel generator emergency AC  
Component boundary: complete diesel generator plant Operating mode: standby Operating environment: normal  
Generic failure mode: fail to run Original failure mode: failure to run given start  
FAILURE RATE OR PROBABILITY median: 3.0E-3/hr 95%: 3.0E-2/hr 5%: 3.0E-4/hr ERROR FACTOR: 10 REPAIR TIME: 21 hours  
Source: WASH 1400 (table 111 4-2) Ultimate source: nuclear and non-nuclear experience  
Comment: Repair time is mean maintenance duration. For plant with specific ation which limits the outage time to 24 hours, mean maintenance duration is 13 hours.

X Source category: generic

DGARX diesel generator emergency AC  
Component boundary: detail n/a Operating mode: standby Operating environment: normal  
Generic failure mode: fail to run Original failure mode: fail to run  
FAILURE RATE OR PROBABILITY mean : 3.0E-3/hr 80%: 9.0E-3/hr 20%: 1.0E-3/hr  
Source: VVER reliability data base Ultimate source: expert opinion  
Comment:

I Source category: generic

DGARI diesel generator emergency AC  
Component boundary: SEE failure to start, same source Operating mode: standby Operating environment: normal  
Generic failure mode: fail to run Original failure mode: failure to run given start  
FAILURE RATE OR PROBABILITY mean : 3.0E-3/hr ERROR FACTOR: 10  
Source: IREP NUREG 2728 (tb.5.1-1) Ultimate source: expert opinion  
Comment: Failure to run is failure to run more than 1/2 hour,given start.

B Source category: generic

DGARB diesel generator emergency AC  
 Component boundary: SEE IREP DG failure to start Operating mode: standby Operating environment: normal  
 Generic failure mode: fail to run Original failure mode: failure to run, given start  
 FAILURE RATE OR PROBABILITY mean :  $3.0E-3/hr$  max:  $2.0E-2/hr$  min:  $6.0E-5/hr$   
 Source: NUREG 2815 (table C.1.) Ultimate source: expert opinion aggregation and IREP data  
 Comment: Failure to run is failure to run for more than 1/2 hour, given start.  
 Failure rate is applicable to emergency condition.

U Source category: generic

DGARU diesel generator emergency AC  
 Component boundary: detail n/a Operating mode: standby Operating environment: normal  
 Generic failure mode: fail to run Original failure mode: failure to continue operation  
 FAILURE RATE OR PROBABILITY mean :  $3.0E-3/hr$   
 Source: Sizewell B (PWR/RX312 pg.13) Ultimate source: assessed from nuclear and industrial experience and data  
 Comment: Assessment based on W data item, WASH 1400 and 3 SRS data items, ( $3.0E-3/hr$ )( $1.3E-3/hr$  op.exp. $8.7E+6$ hours) ( $1.4E-3/hr$  applicable to average industrial use).


J Source category: generic

DGARJ diesel generator emergency AC  
 Component boundary: detail n/a Operating mode: standby Operating environment: normal  
 Generic failure mode: fail to run Original failure mode: failure to run  
 FAILURE RATE OR PROBABILITY mean :  $2.0E-3/hr$  ERROR FACTOR: 10  
 Source: NUREG 4550, Vol.1, tbl.VIII.1-2 Ultimate source: assessed from several nuclear data sources  
 Comment: ASEP used generic value from the Reliability of AC Power System Study (NUREG/CR-2989) which contain industry wide analysis.

E Source category: generic

DGARE diesel generator emergency AC  
 Component boundary: detail n/a Operating mode: standby Operating environment: normal  
 Generic failure mode: fail to run Original failure mode: fails while running  
 FAILURE RATE OR PROBABILITY rec :  $1.0E-4/hr$  high:  $8.8E-3/hr$  low:  $2.0E-5/hr$  REPAIR TIME: 11.5 hours  
 Source: IEEE 500 (1984) pg 1218 Ultimate source: expert opinion aggregation and operating experience  
 Comment: Failure rate is composite value of IEEE 500 (1977) and several nuclear sources including NUREG 1362 (1980).

# IAEA RELIABILITY DATA BASE





Z Source category: updated

DGARZ diesel generator emergency AC  
Component boundary: detail n/a Operating mode: standby Operating environment: normal  
Generic failure mode: fail to run Original failure mode: fail during operation  
FAILURE RATE OR PROBABILITY mean : 6.0E-3/hr  
Source: ZION NPP PSS (tbl.1.5.1-5) Ultimate source: generic data updated with plant specific operating experience  
Comment: Prior: mean NUREG 1362, DG does not continue to run,w/o command, montly testing.Distribution WASH 1400, DG failure to run  
Operating experience: operating time 1340 hours, 6 failures.


H Source category: updated

DGARH diesel generator emergency AC  
Component boundary: detail n/a Operating mode: standby Operating environment: normal  
Generic failure mode: fail to run Original failure mode: fail during first hour of operation  
FAILURE RATE OR PROBABILITY mean : 2.7E-3/hr 95%: 3.7E-3/hr 5%: 1.3E-3/hr REPAIR TIME: 6.8 hours  
Source: Old PWR Ultimate source: generic data updated with plant operating experience  
Comment: Generic mean 1.7E-2/hr. Operating experience 1177 hours of operation, 2 failures.

R Source category: plant specific

DGARR diesel generator emergency AC  
Component boundary: detail n/a Operating mode: standby Operating environment: normal  
Generic failure mode: fail to run Original failure mode: failure to continue to run  
FAILURE RATE OR PROBABILITY mean : 1.4E-3/hr 95%: 2.9E-3/hr 5%: 5.4E-4/hr  
Source: EPRI NP-2433(1982) (table 3-1) Ultimate source: operating experience(utility supplied data) Peach Bottom 2 & 3  
Comment: Failure rate is calculated for Peach Bottom 2 & 3 plants only. Total expereince 32.9 years. No.of failures 5.

# IAEA RELIABILITY DATA BASE



W Source category: generic

BTWFW battery (power system) wet cell  
Component boundary: detail n/a Operating mode: emergency load condition Operating environment: normal  
Generic failure mode: fail to function Original failure mode: failure to provide proper output  
FAILURE RATE OR PROBABILITY median:  $3.0E-6/hr$  95%:  $1.0E-5/hr$  5%:  $1.0E-6/hr$  ERROR FACTOR: 3  
Source: WASH 1400 (table III 4-2) Ultimate source: assessed from industrial, nuclear experience, expert opinion  
Comment: Batteries are constantly charged and their open circuit output voltage is monitored, so failures like shorts to ground or internally are detected quickly. Only significant failure mode is one listed

B Source category: generic

BTWFB battery (power system) wet cell  
Component boundary: detail n/a Operating mode: all Operating environment: normal  
Generic failure mode: fail to function Original failure mode: failure to provide proper output  
FAILURE RATE OR PROBABILITY mean:  $2.0E-6/hr$  max:  $1.0E-5/hr$  min:  $8.0E-7/hr$   
Source: NUREG 2815 (table C.1.) Ultimate source: expert judgement and IREP data  
Comment: Assumes out-of-specification cell replacement

T Source category: generic

BTAFB battery  
Component boundary: battery only Per demand value changed to per hour(1 year test) Operating mode: standby Operating environment: normal  
Generic failure mode: fail to function Original failure mode: failed effective output  
FAILURE RATE OR PROBABILITY mean:  $1.5E-6/hr$  95%:  $7.8E-6/hr$  REPAIR TIME: 2 hours  
Source: Swedish Rel.data book, tbl.41 Ultimate source: plant operating experience (7 BWR plants), ATV reports, LERs  
Comment: Demand failure rate is based on refueling outage testing interval Operating experience: Total pop.129.No of demands 531.Number of failures 7. a=0.0346; b=2.59

X Source category: generic

BTAFX battery general  
Component boundary: detail n/a Operating mode: all Operating environment: normal  
Generic failure mode: fail to function Original failure mode: fail to function  
FAILURE RATE OR PROBABILITY mean:  $1.0E-6/hr$  80%:  $3.0E-6/hr$  20%:  $1.0E-7/hr$   
Source: VVER reliability data base Ultimate source: expert opinion  
Comment:

I Source category: generic

BTWFI battery (power system) wet cell  
Component boundary: detail n/a Operating mode: all Operating environment: normal  
Generic failure mode: fail to function Original failure mode: failure to provide proper output  
FAILURE RATE OR PROBABILITY mean:  $1.0E-6/hr$  ERROR FACTOR: 3  
Source: IREP NUREG 2728 (tb.5.1-1) Ultimate source: expert opinion  
Comment: Assumes out-of-specification cell replacement


N Source category: generic

BTAFN battery  
 Component boundary: battery,container,terminal connections incl.1st breaker connect. Operating mode: all Operating environment: normal  
 Generic failure mode: fail to function Original failure mode: no output  
 FAILURE RATE OR PROBABILITY rec : 6.4E-7/hr high: 3.0E-6/hr low: 3.0E-8/hr REPAIR TIME: 4-7 hours  
 Source: NUREG 3831 (1985) (tbl.A6) Ultimate source: operating experience (plant records)  
 Comment: Operating experience: total pop. 51.Operating time 1.564.315hours No of failures 1. High and low chi-square estimates.  
 Repair times range of median

E Source category: generic

BTLFE battery lead acid  
 Component boundary: detail n/a Operating mode: all Operating environment: normal  
 Generic failure mode: fail to function Original failure mode: catastrophic (no output given challenge)  
 FAILURE RATE OR PROBABILITY rec : 2.0E-8/hr high: 3.0E-8/hr low: 0.0E-0/hr  
 Source: IEEE 500 (1984) pg.85 Ultimate source: expert opinion aggregation and operating experience  
 Comment: Failure rate is composite of several sources. Tot.failure rate of batteries is estimated to be 1.6E-6/oper.hr,but 99.6% of failures were discovered through testing,what gives 6E-9/hr emergency oper

# IAEA RELIABILITY DATA BASE



H Source category: updated

BTVFH battery 125 V  
Component boundary: detail n/a Operating mode: all Operating environment: normal  
Generic failure mode: fail to function Original failure mode: fail during operation  
FAILURE RATE OR PROBABILITY mean : 5.2E-7/hr 95%: 1.7E-6/hr 5%: 5.0E-8/hr REPAIR TIME: 5 hours  
Source: Old PWR Ultimate source: Generic data updated with plant operating experience  
Comment: Generic mean 7.5E-7/hr. Operating experience 4.1E+5 hours of operation, no failures.


O Source category: updated

BTAFO battery  
Component boundary: detail n/a Operating mode: all Operating environment: normal  
Generic failure mode: fail to function Original failure mode: operational failure  
FAILURE RATE OR PROBABILITY mean : 8.2E-8/hr 95%: 2.5E-7/hr 5%: 8.E-10/hr REPAIR TIME: 11.2 hours  
Source: Oconee NPP PRA (tbl.b-1.) Ultimate source: generic data updated with plant specific operating experience  
Comment: Prior:IEEE 500(1977)(pg104),rec=median; max=80% of distribution. Operating experience: 96.426 hours of operation, no failures.  
Repair time is mean of updated component maintenance duration.

Z Source category: updated

BTAfZ battery  
Component boundary: detail n/a Operating mode: all Operating environment: normal  
Generic failure mode: fail to function Original failure mode: fail during operation  
FAILURE RATE OR PROBABILITY mean : 7.6E-8/hr  
Source: ZION NPP PSS (tbl.1.5.1-5) Ultimate source: generic data updated with plant specific experience  
Comment: Prior:IEEE 500(1977)(pg.104) lead-acid batteries,stationary type Failure mode "catastrophic". Operating experience:2.0E+5 hours,  
no failures.

# IAEA RELIABILITY DATA BASE



N Source category: generic

BCSFN battery charger solid state general  
 Component boundary: charger, connecting breakers(feeder & output),protect.& controls Operating mode: operating Operating environment: normal  
 Generic failure mode: fail to function Original failure mode: no output  
 FAILURE RATE OR PROBABILITY rec : 5.5E-6/hr high: 1.8E-5/hr low: 1.4E-6/hr REPAIR TIME: 5-10 hours  
 Source: NUREG 3831 (1985) (tbl.A12) Ultimate source: operating experience (plant records)  
 Comment: Operating experience:total pop.70. Operating time 2.183.975 hours No.of failures 12.  
 Repair time is range of medians.

I Source category: generic

BCAFI battery charger  
 Component boundary: detail n/a Operating mode: all Operating environment: normal  
 Generic failure mode: fail to function Original failure mode: failure to operate  
 FAILURE RATE OR PROBABILITY mean : 1.0E-6/hr ERROR FACTOR: 3  
 Source: IREP NUREG 2728 (tb.5.1-1) Ultimate source: expert opinion  
 Comment:

X Source category: generic

BCAFX battery charger  
 Component boundary: detail n/a Operating mode: all Operating environment: normal  
 Generic failure mode: fail to function Original failure mode: fail to function  
 FAILURE RATE OR PROBABILITY mean : 1.0E-6/hr 80%: 5.0E-6/hr 20%: 3.3E-7/hr  
 Source: VVER reliability data base Ultimate source: expert opinion  
 Comment:

B Source category: generic


BCAFB battery charger  
 Component boundary: detail n/a Operating mode: all Operating environment: normal  
 Generic failure mode: fail to function Original failure mode: failure to operate  
 FAILURE RATE OR PROBABILITY mean : 6.0E-7/hr max: 4.0E-6/hr min: 3.0E-7/hr  
 Source: NUREG 2815 (table C.1.) Ultimate source: expert judgement and IREP data  
 Comment:

E Source category: generic

BCRFE battery charger rectifier  
 Component boundary: detail n/a Operating mode: all Operating environment: normal  
 Generic failure mode: fail to function Original failure mode: no output  
 FAILURE RATE OR PROBABILITY rec : 4.9E-7/hr high: 1.2E-5/hr low: 6.0E-8/hr  
 Source: IEEE 500 (1984) pg.66 Ultimate source: expert opinion aggregation and operating experience  
 Comment: Failure rate is composite of different types and voltage levels.



# IAEA RELIABILITY DATA BASE



O Source category: updated

BCSFO battery charger SCR type  
Component boundary: detail n/a Operating mode: all Operating environment: normal  
Generic failure mode: fail to function Original failure mode: operational failure  
FAILURE RATE OR PROBABILITY mean : 5.0E-6/hr 95%: 1.3E-5/hr 5%: 3.0E-7/hr REPAIR TIME: 10.1 hours  
Source: Oconee NPP PRA (tbl.b-1.) Ultimate source: generic data updated with plant specific operating experience  
Comment: Prior:IEEE 500 (1977)(pg93), rec=median; max=95% of distribution. Operating experience: 96.426 hours of operation, 1 failure.  
Repair time is mean of updated component maintenance duration.


H Source category: updated

BC1FH battery charger 120 V  
Component boundary: detail n/a Operating mode: all Operating environment: normal  
Generic failure mode: fail to function Original failure mode: fail during operation  
FAILURE RATE OR PROBABILITY mean : 6.7E-6/hr 95%: 1.3E-5/hr 5%: 1.7E-6/hr REPAIR TIME: 5.6 hours  
Source: Old PWR Ultimate source: Generic data updated with plant operating experience  
Comment: Generic mean 1.9E-5/hr. Operating experience 2E+5 hours of operation, 1 failure.

Z Source category: updated

BCAFZ battery charger  
Component boundary: detail n/a Operating mode: all Operating environment: normal  
Generic failure mode: fail to function Original failure mode: fail during operation  
FAILURE RATE OR PROBABILITY mean : 5.5E-7/hr  
Source: Zion NPP PSS (tbl.1.5.1-5) Ultimate source: generic data updated with plant specific experience  
Comment: Prior:IEEE 500(1977)(pg90) rectifiers,stationary type. Prior failure mode "all modes"  
Operating experience: 2.0E+5 hours of operation,no failures

# IAEA RELIABILITY DATA BASE



X Source category: generic

CBAFX bus  
 Component boundary: detail n/a Operating mode: all Operating environment: normal  
 Generic failure mode: fail to function Original failure mode: catastrophic  
 FAILURE RATE OR PROBABILITY mean : 5.0E-7/hr 80%: 1.5E-6/hr 20%: 1.6E-7/hr  
 Source: VVER reliability data base Ultimate source: expert opinion  
 Comment:

E1 Source category: generic

CBBFE bus bare outdoor switchgear  
 Component boundary: detail n/a Operating mode: all Operating environment: normal  
 Generic failure mode: fail to function Original failure mode: catastrophic  
 FAILURE RATE OR PROBABILITY rec : 2.3E-7/hr high: 2.0E-6/hr low: 4.0E-8/hr  
 Source: IEEE 500 (1984) pg.804 Ultimate source: expert opinion aggregation  
 Comment: Reference : IEEE 500 (1977) Failure mode "catastrophic" include open circuit, short line to line and short to ground.

E2 Source category: generic

CBIAE bus insulated switchgear bus 601-15 kV  
 Component boundary: detail n/a Operating mode: all Operating environment: normal  
 Generic failure mode: all modes Original failure mode: all modes  
 FAILURE RATE OR PROBABILITY rec : 1.9E-7/hr high: 3.0E-7/hr low: 1.1E-7/hr  
 Source: IEEE 500 (1984) pg.810 Ultimate source: expert opinion aggregation  
 Comment: Reference IEEE 493 (1980)

J Source category: generic

CBAAJ bus general  
 Component boundary: detail n/a Operating mode: all Operating environment: normal  
 Generic failure mode: all modes Original failure mode: hardware failure  
 FAILURE RATE OR PROBABILITY mean : 9.0E-5/d ERROR FACTOR: 5  
 Source: NUREG 4550, Vol.1. tbl.VIII.1-2 Ultimate source: assesed from several nuclear data sources  
 Comment: There is no specific failure mode assigned for this component in the source. ASEP used IEEE value of 1.3E-7/hr assuming monthly system test.

E3 Source category: generic

CBMFE bus metal entclosed  
 Component boundary: detail n/a Operating mode: all Operating environment: normal  
 Generic failure mode: fail to function Original failure mode: catastrophic  
 FAILURE RATE OR PROBABILITY rec : 8.0E-8/hr high: 4.0E-7/hr low: 0.0E-0/hr  
 Source: IEEE 500 (1984) pg.811 Ultimate source: expert opinion aggregation  
 Comment: Reference: IEEE 500 (1977) Failure mode "catastrophic" include open circuit, short line to line and short to ground.


B Source category: generic

CBAA8 bus  
Component boundary: detail n/a Operating mode: all Operating environment: normal  
Generic failure mode: all modes Original failure mode: all modes  
FAILURE RATE OR PROBABILITY mean : 3.0E-8/hr max: 2.0E-7/hr min: 6.E-10/hr  
Source: NUREG 2815 (table C.1.) Ultimate source: expert judgement and IREP data  
Comment:

I Source category: generic

CBAAI bus  
Component boundary: detail n/a Operating mode: all Operating environment: normal  
Generic failure mode: all modes Original failure mode: all modes  
FAILURE RATE OR PROBABILITY mean : 1.0E-8/hr ERROR FACTOR: 3  
Source: IREP NUREG 2728 (tb.5.1-1) Ultimate source: expert opinion  
Comment:

# IAEA RELIABILITY DATA BASE



01 Source category: updated

CBHFO bus high voltage, indoor voltage  $\geq 4$  kV  
 Component boundary: detail n/a Operating mode: all Operating environment: normal  
 Generic failure mode: fail to function Original failure mode: operational failure  
 FAILURE RATE OR PROBABILITY mean :  $6.2E-7/hr$  95%:  $1.5E-6/hr$  5%:  $3.1E-9/hr$  REPAIR TIME: 10.8 hours  
 Source: Oconee NPP PRA (tbl.b-1.) Ultimate source: generic data updated with plant specific operating experience  
 Comment: Prior:IEEE 500(1977)(pg.188),rec=median;max=80% of distribution Operating experience:  $4.34E+5$  hours of operation, no failures.  
 Repair time is mean of updated maintenance duration (4kV bus).

H1 Source category: updated

CB1FH bus 120 V DC  
 Component boundary: detail n/a Operating mode: all Operating environment: normal  
 Generic failure mode: fail to function Original failure mode: fail during operation  
 FAILURE RATE OR PROBABILITY mean :  $4.2E-7/hr$  95%:  $9.2E-7/hr$  5%:  $6.9E-8/hr$   
 Source: Old PWR Ultimate source: Generic data updated with plant operating experience  
 Comment: Generic mean  $5.0E-7/hr$ . Operating experience  $4.1E+5$  hours of operation, no failures.

O2 Source category: updated

CBDFO bus DC  
 Component boundary: detail n/a Operating mode: all Operating environment: normal  
 Generic failure mode: fail to function Original failure mode: operational failure  
 FAILURE RATE OR PROBABILITY mean :  $4.2E-7/hr$  95%:  $8.3E-7/hr$  5%:  $3.E-10/hr$  REPAIR TIME: 10.8 hours  
 Source: Oconee NPP PRA (tbl.b-1.) Ultimate source: generic data updated with plant specific operating experience  
 Comment: Prior:IEEE 500(1977)(pg.185),rec=median;max=80%distribution Operating experience:  $2.89E+5$  hours of operation, no failures.  
 Repair time is mean of updated maintenance duration(bus or panel)

H2 Source category: updated

CB6FH bus 6 kV  
 Component boundary: detail n/a Operating mode: all Operating environment: normal  
 Generic failure mode: fail to function Original failure mode: fail during operation  
 FAILURE RATE OR PROBABILITY mean :  $4.1E-7/hr$  95%:  $8.5E-7/hr$  5%:  $6.6E-8/hr$   
 Source: Old PWR Ultimate source: Generic data updated with plant operating experience  
 Comment: Generic mean  $5.0E-7/hr$ . Operating experience  $5.4E+5$  hours of operation, no failures.

H3 Source category: updated

CB3FH bus 380 v  
 Component boundary: detail n/a Operating mode: all Operating environment: normal  
 Generic failure mode: fail to function Original failure mode: fail during operation  
 FAILURE RATE OR PROBABILITY mean :  $3.7E-7/hr$  95%:  $7.5E-7/hr$  5%:  $6.3E-8/hr$   
 Source: Old PWR Ultimate source: Generic data updated with plant specific operating experience  
 Comment: Generic mean  $5.0E-7/hr$ . Operating experience  $9.5E+5$  hours of operation, no failures.

H4 Source category: updated


CB2FH bus 120 V AC , 220 V AC  
 Component boundary: detail n/a Operating mode: all Operating environment: normal  
 Generic failure mode: fail to function Original failure mode: fail during operation  
 FAILURE RATE OR PROBABILITY mean :  $3.4\text{E-}7/\text{hr}$  95%:  $6.8\text{E-}7/\text{hr}$  5%:  $6.3\text{E-}8/\text{hr}$   
 Source: Old PWR Ultimate source: Generic data updated with plant operating experience  
 Comment: Generic mean  $5.0\text{E-}7/\text{hr}$ . Operating experience  $1.4\text{E}+6$  hours of operation, no failures.

O3 Source category: updated

CBLFO bus low voltage indoor voltage  $\leq 600$  V  
 Component boundary: detail n/a Operating mode: all Operating environment: normal  
 Generic failure mode: fail to function Original failure mode: operational failure  
 FAILURE RATE OR PROBABILITY mean :  $1.8\text{E-}7/\text{hr}$  95%:  $8.3\text{E-}7/\text{hr}$  5%:  $1.8\text{E-}9/\text{hr}$   
 Source: Oconee NPP PRA (tbl.b-1.) Ultimate source: generic data updated with plant specific operating experience  
 Comment: Prior:IEEE 500 (1977)(pg.188),rec=median;max=80% of distribution Operating experience: $2.17\text{E}+6$  hours of operation, no failures.



# IAEA RELIABILITY DATA BASE



I Source category: generic

EIAFI inverter general  
Component boundary: detail n/a Operating mode: all Operating environment: normal  
Generic failure mode: fail to function Original failure mode: failure to operate  
FAILURE RATE OR PROBABILITY mean : 1.0E-4/hr ERROR FACTOR: 3  
Source: IREP NUREG 2728 (tb.5.1-1) Ultimate source: expert opinion  
Comment:

J Source category: generic

EIAAJ inverter general  
Component boundary: detail n/a Operating mode: all Operating environment: normal  
Generic failure mode: all modes Original failure mode: hardware failure  
FAILURE RATE OR PROBABILITY mean : 1.0E-4/hr ERROR FACTOR: 3  
Source: NUREG 4550, Vol.1,tbl.VIII.1-2 Ultimate source: assessed from several nuclear data sources  
Comment: There is no specific failure mode assigned for this component in the source. ASEP used IPRD (NUREG 3831) value of 1.0E-4/hr assuming montly system test.

B Source category: generic

EIAFB inverter general  
Component boundary: detail n/a Operating mode: all Operating environment: normal  
Generic failure mode: fail to function Original failure mode: failure to operate  
FAILURE RATE OR PROBABILITY mean : 6.0E-5/hr max: 4.0E-4/hr min: 3.0E-5/hr  
Source: NUREG 2815 (table C.1.) Ultimate source: expert judgement and IREP data  
Comment:

N Source category: generic

EISFN inverter solid state 120 volts AC  
Component boundary: inverter,transfer switch,rectifier,feeder breaker,prot.& control Operating mode: operating Operating environment: normal  
Generic failure mode: fail to function Original failure mode: no output  
FAILURE RATE OR PROBABILITY rec : 2.1E-5/hr high: 1.9E-4/hr low: 8.5E-6/hr REPAIR TIME: 4-8 hours  
Source: NUREG 3831 (1985) (tbl.A18) Ultimate source: operating experience (plant records)  
Comment: Operating experience:total pop.31. Operating time 985.505 hours No.of failures 21.  
Repair time is range of medians.

X Source category: generic

EIAFX inverter  
Component boundary: detail n/a Operating mode: all Operating environment: normal  
Generic failure mode: fail to function Original failure mode: fail to function  
FAILURE RATE OR PROBABILITY mean : 1.0E-5/hr 80%: 8.0E-5/hr 20%: 2.5E-6/hr  
Source: VVER reliability data base Ultimate source: expert opinion  
Comment:

T Source category: generic

EISFT inverter static  
Component boundary: inverter,reversing switch,associated cables, transformer,breaker Operating mode: operating Operating environment: normal  
Generic failure mode: fail to function Original failure mode: loss of effective output  
FAILURE RATE OR PROBABILITY mean : 5.2E-6/hr 95%: 2.6E-5/hr REPAIR TIME: 13 hours  
Source: Swedish Rel.data book, tbl.43 Ultimate source: plant operating experience (4 BWR plants), ATV reports, LERs  
Comment: Operating experience: Total pop.10. Operational time 38.5E+4. No.of failures 2. Only one critical failure; a=0.224; b=43100


E1 Source category: generic

E1XFE inverter static three phase  
Component boundary: detail n/a Operating mode: all Operating environment: normal  
Generic failure mode: fail to function Original failure mode: no output  
FAILURE RATE OR PROBABILITY rec : 3.0E-6/hr high: 3.0E-5/hr low: 1.9E-7/hr  
Source: IEEE 500 (1984) pg.277 Ultimate source: expert opinion aggregation and operating experience  
Comment: Reference IEEE 500 (1977)

E2 Source category: generic

E1ZFE inverter static single phase  
Component boundary: detail n/a Operating mode: all Operating environment: normal  
Generic failure mode: fail to function Original failure mode: no output  
FAILURE RATE OR PROBABILITY rec : 1.0E-6/hr high: 1.2E-5/hr low: 3.0E-7/hr  
Source: IEEE 500 (1984) pg.276 Ultimate source: expert opinion aggregation and operating experience  
Comment: Reference IEEE 500(1977)

# IAEA RELIABILITY DATA BASE



0 Source category: updated

EIIFO inverter instrument inverter  
Component boundary: detail n/a Operating mode: all Operating environment: normal  
Generic failure mode: fail to function Original failure mode: operational failure  
FAILURE RATE OR PROBABILITY mean :  $4.3E-5/hr$  95%:  $4.8E-5/hr$  5%:  $4.9E-6/hr$  REPAIR TIME:  
Source: Oconee NPP PRA (tbl.b-1.) Ultimate source: generic data updated with plant specific operating experience  
Comment: Not possible to identify prior source. Prior mean  $1.3E-4/hr$ . Oper exp:  $3.37E+5$  hours of operation, 9 failures.

Y Source category: plant specific


EISFY inverter static  
Component boundary: inverter, reversing switch, associated cables, transformer, breaker Operating mode: operating Operating environment: normal  
Generic failure mode: fail to function Original failure mode: loss of effective output  
FAILURE RATE OR PROBABILITY mean :  $1.2E-5/hr$  REPAIR TIME: 11 hours  
Source: Swedish Rel.data book, tbl.43 Ultimate source: plant operating experience (Ringhals 2 PWR )  
Comment: operating experience: Total pop. 4. Total operational time  $17.29E+4$  hours. No. of failures 2.

2 Source category: updated

EIAFZ inverter general  
Component boundary: detail n/a Operating mode: all Operating environment: normal  
Generic failure mode: fail to function Original failure mode: fail during operation  
FAILURE RATE OR PROBABILITY mean :  $1.1E-5/hr$   
Source: ZION NPP PSS (tbl.1.5.1-5) Ultimate source: generic data updated with plant operating experience  
Comment: Prior: WASH 1400, solid state devices, high power application failure mode "fails to function". Operating experience:  $3.04E+5$  hours of operation, 3 failures.

# IAEA RELIABILITY DATA BASE

Motor, fail to start, normal environment  
^ (generic sources)



G Source category: generic

MAASG motor general  
Component boundary: detail n/a Operating mode: all Operating environment: normal  
Generic failure mode: fail to start Original failure mode: fail to start  
FAILURE RATE OR PROBABILITY median:  $3.6E-4/d$  ERROR FACTOR: 8  
Source: German Risk Study (tb.F3,7-1) Ultimate source: generic data  
Comment: Failure rate is combination of number of generic data sources, including non nuclear. Original time related value changed to demand related assuming monthly testing.

W Source category: generic

MAASW motor general  
Component boundary: detail n/a Operating mode: all Operating environment: normal  
Generic failure mode: fail to start Original failure mode: failure to start  
FAILURE RATE OR PROBABILITY median:  $3.0E-4/d$  95%:  $1.0E-3/d$  5%:  $1.0E-4/d$  ERROR FACTOR: 3  
Source: WASH 1400 (table 111 4-2) Ultimate source: assessed from nuclear, industrial and military experience and data  
Comment: Demand probability is based on presence of proper input signal Applicable only to motors that function independently of pumps and valves


X Source category: generic

MAASX motor general  
Component boundary: detail n/a Operating mode: all Operating environment: normal  
Generic failure mode: fail to start Original failure mode: fail to start  
FAILURE RATE OR PROBABILITY mean :  $3.0E-4/d$  80%:  $6.0E-4/d$  20%:  $1.5E-4/d$   
Source: VVER reliability data base Ultimate source: expert opinion  
Comment:

E Source category: generic

MAWSE motor AC synchronous  
Component boundary: detail n/a Operating mode: all Operating environment: normal  
Generic failure mode: fail to start Original failure mode: fail to start  
FAILURE RATE OR PROBABILITY rec :  $2.0E-4/d$  high:  $2.2E-4/d$  low:  $1.4E-4/d$   
Source: IEEE 500 (1984) pg.241 Ultimate source: expert opinion aggregation and operating experience  
Comment: Number of starts in time not known. Original time related value changed to demand related assuming monthly testing.

# IAEA RELIABILITY DATA BASE





W Source category: generic

MAARW motor general  
 Component boundary: detail n/a Operating mode: all Operating environment: normal  
 Generic failure mode: fail to run Original failure mode: failure to run, given start  
 FAILURE RATE OR PROBABILITY median: 1.0E-5/hr 95%: 3.0E-5/hr 5%: 3.0E-6/hr ERROR FACTOR: 3  
 Source: WASH 1400 (table III 4-2) Ultimate source: assessed from nuclear, industrial and military experience and data  
 Comment: Applicable only to motors that function independently of pumps and valves.

X Source category: generic

MAARX motor general  
 Component boundary: detail n/a Operating mode: all Operating environment: normal  
 Generic failure mode: fail to run Original failure mode: fail to run  
 FAILURE RATE OR PROBABILITY mean : 5.0E-6/hr 80%: 2.5E-5/hr 20%: 1.0E-6/hr  
 Source: VVER reliability data base Ultimate source: expert opinion  
 Comment:

E1 Source category: generic

MACRE motor AC general  
 Component boundary: detail n/a Operating mode: all Operating environment: normal  
 Generic failure mode: fail to run Original failure mode: fail to run once started  
 FAILURE RATE OR PROBABILITY rec : 3.2E-6/hr high: 3.0E-3/hr low: 0.0E-0/hr REPAIR TIME: 1.8 hours  
 Source: IEEE 500 (1984) pg.220 Ultimate source: expert opinion aggregation and operating experience  
 Comment: Failure rate is composite of different types and voltage levels.

G Source category: generic

MAARC motor general  
 Component boundary: detail n/a Operating mode: all Operating environment: normal  
 Generic failure mode: fail to run Original failure mode: fail to run  
 FAILURE RATE OR PROBABILITY median: 2.0E-6/hr ERROR FACTOR: 8  
 Source: German Risk Study (tb.F3,7-1) Ultimate source: generic data  
 Comment: Failure rate is combination of number of generic data sources including non-nuclear.

E2 Source category: generic

MAIRE motor AC induction  
 Component boundary: detail n/a Operating mode: all Operating environment: normal  
 Generic failure mode: fail to run Original failure mode: fail to run once started  
 FAILURE RATE OR PROBABILITY rec : 1.2E-6/hr high: 1.6E-3/hr low: 1.0E-8/hr  
 Source: IEEE 500 (1984) pg.229 Ultimate source: expert opinion aggregation and operating experience  
 Comment: Failure rate is composite of different voltage and power levels.


S Source category: generic

MAARS motor general  
 Component boundary: detail n/a Operating mode: all Operating environment: normal  
 Generic failure mode: fail to run Original failure mode: fails to run given start  
 FAILURE RATE OR PROBABILITY mean :  $1.0E-6/hr$   
 Source: Shoreham PRA,GE data(tb.A.2-1) Ultimate source: evaluation of BWR operating experience  
 Comment:

E3 Source category: generic

MAWAE motor AC synchronous  
 Component boundary: detail n/a Operating mode: all Operating environment: normal  
 Generic failure mode: fail to run Original failure mode: fail to run once started  
 FAILURE RATE OR PROBABILITY rec :  $7.0E-7/hr$  high:  $8.4E-7/hr$  low:  $5.6E-7/hr$   
 Source: IEEE 500 (1984) pg.241 Ultimate source: expert opinion aggregation and operating experience  
 Comment:

# IAEA RELIABILITY DATA BASE



T Source category: generic

ERSFT rectifier static  
Component boundary: rectifier, fuse(380V side), tap. Operating mode: operating Operating environment: normal  
Generic failure mode: fail to function Original failure mode: loss of effective output  
FAILURE RATE OR PROBABILITY mean : 1.4E-6/hr 95%: 5.8E-6/hr REPAIR TIME: 16 hours  
Source: Swedish Rel.data book, tbl.42 Ultimate source: plant operating experience (7 BWR plants), ATV reports, LERS  
Comment: Critical failures are: burned connections, failed fans, unstable electronics. Op. experience: total pop. 140. Op. time 427E+4 hours.  
No. of failures 6. a=0.0324; b=23000 Critical failures at 3 plants

E1 Source category: generic

ERPFE rectifier precipitator rectifier  
Component boundary: detail n/a Operating mode: all Operating environment: normal  
Generic failure mode: fail to function Original failure mode: no output(catastrophic)  
FAILURE RATE OR PROBABILITY rec : 1.4E-6/hr high: 4.1E-6/hr low: 3.6E-7/hr  
Source: IEEE 500 (1984) pg.422 Ultimate source: expert opinion aggregation and operating experience  
Comment: Failure mode "no output" consist of: 1) automatic removal by protective circuitry; 2) manual removal; 3) open circuit.


E2 Source category: generic

EREFEE rectifier excitation rectifier  
Component boundary: detail n/a Operating mode: all Operating environment: normal  
Generic failure mode: fail to function Original failure mode: no output(catastrophic)  
FAILURE RATE OR PROBABILITY rec : 1.3E-6/hr high: 3.6E-6/hr low: 3.2E-7/hr  
Source: IEEE 500 (1984) pg.421 Ultimate source: expert opinion aggregation and operating experience  
Comment: Failure mode "no output" consist of: 1) automatic removal by protective circuitry; 2) manual removal; 3) open circuit

X Source category: generic

ERAFX rectifier  
Component boundary: detail n/a Operating mode: all Operating environment: normal  
Generic failure mode: fail to function Original failure mode: fail to function  
FAILURE RATE OR PROBABILITY mean : 1.0E-6/hr 80%: 6.0E-6/hr 20%: 5.0E-7/hr  
Source: VVER reliability data base Ultimate source: expert opinion  
Comment:

# IAEA RELIABILITY DATA BASE



B Source category: generic

RTADB relay time delay general  
Component boundary: detail n/a Operating mode: all Operating environment: normal  
Generic failure mode: fail to remain in position Original failure mode: premature transfer  
FAILURE RATE OR PROBABILITY mean : 1.0E-6/hr max: 5.0E-6/hr min: 2.0E-8/hr  
Source: NUREG 2815 (table C.1.) Ultimate source: expert judgement and IREP data  
Comment:

W Source category: generic

RWCDW relay general  
Component boundary: detail n/a Operating mode: normally closed Operating environment: normal  
Generic failure mode: fail to remain in position Original failure mode: failure of NC cnts by opening, given not energised  
FAILURE RATE OR PROBABILITY median: 1.0E-7/hr 95%: 3.0E-7/hr 5%: 3.0E-8/hr ERROR FACTOR: 3  
Source: WASH 1400 (table III 4-2) Ultimate source: assessed from nuclear experience  
Comment:

X Source category: generic

RWCDX relay general  
Component boundary: detail n/a Operating mode: all Operating environment: normal  
Generic failure mode: fail to remain in position Original failure mode: fail to remain in position  
FAILURE RATE OR PROBABILITY mean : 1.0E-7/hr 80%: 2.0E-6/hr 20%: 2.0E-8/hr  
Source: VVER reliability data base Ultimate source: expert opinion  
Comment:


E1 Source category: generic

RRADE relay protective all types  
Component boundary: detail n/a Operating mode: all Operating environment: normal  
Generic failure mode: fail to remain in position Original failure mode: spurious operation  
FAILURE RATE OR PROBABILITY rec : 3.0E-8/hr high: 2.4E-4/hr low: 0.0 REPAIR TIME: .55 hours  
Source: IEEE 500 (1984) pg.164 Ultimate source: expert opinion aggregation and operating experience  
Comment: Given value is composite of all types and voltage levels of protective relays. References IEEE 500 (1977) and IEEE 493 (1980)

E2 Source category: generic

RCLDE relay control all types  
Component boundary: detail n/a Operating mode: all Operating environment: normal  
Generic failure mode: fail to remain in position Original failure mode: spurious operation  
FAILURE RATE OR PROBABILITY rec : 4.0E-8/hr high: 2.5E-4/hr low: 1.0E-8/hr  
Source: IEEE 500 (1984) pg.183 Ultimate source: expert opinion aggregation and operating experience  
Comment: Given value is composite of AC and DC control relays and different voltage levels in both groups. Reference IEEE 500(1977)

# IAEA RELIABILITY DATA BASE



T1 Source category: generic

TM5FT transformer main transformer Voltage= 400kV,130kV  
 Component boundary: transformer,coolers,relay protection,supervision,monitors Operating mode: operating Operating environment: normal  
 Generic failure mode: fail to function Original failure mode: interruption  
 FAILURE RATE OR PROBABILITY mean : 3.5E-6/hr 95%: 1.8E-5/hr REPAIR TIME: 38 hours  
 Source: Swedish Rel.data book, tbl.45 Ultimate source: plant operating experience (7 BWR plants), ATV reports, LERs  
 Comment: Operating experience:total pop. 10.Operating time 28.8E+4 hours. No.of failures 1. Most frequent failures are cooling fan failures which are not critical failures of the transform.a=0.195;b=56200

T2 Source category: generic

TXAFT transformer station start and auxiliary transformer Voltage levels: 130/6 kV, 70/6 kV, 20/6 kV  
 Component boundary: transformer,coolers,relay protection,supervisions, monitors Operating mode: operating Operating environment: normal  
 Generic failure mode: fail to function Original failure mode: interruption  
 FAILURE RATE OR PROBABILITY mean : 2.0E-6/hr 95%: 1.1E-5/hr REPAIR TIME: 5 hours  
 Source: Swedish Rel.data book, tbl.46 Ultimate source: plant operating experience (7 BWR plants), ATV reports, LERs  
 Comment: Operating experience:total pop. 17.Operational time 51.2E+4 hours No.of failures 1.  
 a=0.101; b=51800

G Source category: generic

TAAFG transformer general  
 Component boundary: detail n/a Operating mode: all Operating environment: normal  
 Generic failure mode: fail to function Original failure mode: failure to operate  
 FAILURE RATE OR PROBABILITY median: 1.5E-6/hr ERROR FACTOR: 5  
 Source: German Risk Study (tb.F3,7-1) Ultimate source: generic data  
 Comment: In the table F3,7-1 failure mode is missing. Failure mode "failure to operate" was assumed on the bases of generic sources included."Failure to operate" include "open" and "short" circuit.

E1 Source category: generic

TS5FE transformer main power generator or unit transformer liquid filled, single phase (347-550 kV)  
 Component boundary: detail n/a Operating mode: all Operating environment: normal  
 Generic failure mode: fail to function Original failure mode: no output(catastrophic)  
 FAILURE RATE OR PROBABILITY rec : 1.2E-6/hr high: 1.9E-6/hr low: 5.3E-7/hr  
 Source: IEEE 500 (1984) pg.352 Ultimate source: expert opinion aggregation and operating experience  
 Comment: Failure mode "no output" include: 1) automatic removal by protec. circuitry; 2)manual removal; 3)open circuit.  
 #1) is order of magnitude higher than #2) and #3).

E2 Source category: generic

TM4FE transformer main power generator or unit transformer liquid filled, three phase (146-242 kV)  
 Component boundary: detail n/a Operating mode: all Operating environment: normal  
 Generic failure mode: fail to function Original failure mode: no output(catastrophic)  
 FAILURE RATE OR PROBABILITY rec : 1.1E-6/hr high: 1.5E-6/hr low: 5.0E-7/hr  
 Source: IEEE 500 (1984) pg.358 Ultimate source: expert opinion aggregation and operating experience  
 Comment: Failure mode "no output" include: 1) automatic removal; 2)manual removal; 3) open circuit.  
 Dominant contributor is #1) (more than order-of-magnitude)

T3 Source category: generic

TA6FT transformer general Voltage <= 6 kV  
 Component boundary: transformer,relay protection,coolers,supervision,monitors Operating mode: all Operating environment: normal  
 Generic failure mode: fail to function Original failure mode: interruption  
 FAILURE RATE OR PROBABILITY mean : 7.9E-7/hr 95%: 3.5E-6/hr REPAIR TIME: 10 hours  
 Source: Swedish Rel.data book, tbl.47 Ultimate source: plant operating experience (7 BWR plants),ATV reports, LERs  
 Comment: Operating experience: total pop. 129.Operational time 379E+4 hours No.of failures 3. Critical failures occurred at two plants only.  
 a=0.0345; b=43600



- E3 Source category: generic
- TM5FE transformer main power generator or unit transformer liquid filled, three phase (347-550 kV)  
 Component boundary: detail n/a Operating mode: all Operating environment: normal  
 Generic failure mode: fail to function Original failure mode: no output(catastrophic)  
 FAILURE RATE OR PROBABILITY rec : 7.4E-7/hr high: 1.4E-6/hr low: 4.3E-7/hr  
 Source: IEEE 500 (1984) pg.360 Ultimate source: expert opinion aggregation and operating experience  
 Comment: Failure mode "no output" include: 1) automatic removal; 2) manual removal; 3) open circuit.  
 #1) is order of magnitude higher than #2) and #3).
- E4 Source category: generic
- TMAFE transformer main power generator or unit transformer liquid filled, three phase all voltage levels  
 Component boundary: detail n/a Operating mode: all Operating environment: normal  
 Generic failure mode: fail to function Original failure mode: no output(catastrophic)  
 FAILURE RATE OR PROBABILITY rec : 5.8E-7/hr high: 1.6E-6/hr low: 1.0E-7/hr  
 Source: IEEE 500 (1984) pg.354 Ultimate source: expert opinion aggregation and operating experience  
 Comment: Given value is composite of all voltage levels. Failure mode include: 1) automatic; 2) manual removal; 3) open circuit  
 #1) is order of magnitude higher than #2) and #3).
- X Source category: generic
- TAAFX transformer general  
 Component boundary: detail n/a Operating mode: all Operating environment: normal  
 Generic failure mode: fail to function Original failure mode: fail to function  
 FAILURE RATE OR PROBABILITY mean : 6.0E-7/hr 80%: 3.0E-6/hr 20%: 1.5E-7/hr  
 Source: VVER reliability data base Ultimate source: expert opinion  
 Comment:
- E5 Source category: generic
- TETFE transformer station service including excitation dry type, three phase (all voltage levels)  
 Component boundary: detail n/a Operating mode: all Operating environment: normal  
 Generic failure mode: fail to function Original failure mode: no output(catastrophic)  
 FAILURE RATE OR PROBABILITY rec : 4.0E-7/hr high: 1.4E-6/hr low: 1.1E-7/hr  
 Source: IEEE 500 (1984) pg.330 Ultimate source: expert opinion aggregation and operating experience  
 Comment: Given value is composite of three different voltage levels Failure mode include: 1) automatic removal; 2) manual removal; 3) open circuit. Dominant contributor is #1).
- E6 Source category: generic
- TM2FE transformer main power generator or unit transformer liquid filled, three phase (2-30 kV)  
 Component boundary: detail n/a Operating mode: all Operating environment: normal  
 Generic failure mode: fail to function Original failure mode: no output(catastrophic)  
 FAILURE RATE OR PROBABILITY rec : 3.4E-7/hr high: 5.1E-7/hr low: 1.8E-7/hr  
 Source: IEEE 500 (1984) pg.355 Ultimate source: expert opinion aggregation and operating experience  
 Comment: Failure mode "no output" include: 1) automatic removal; 2) manual removal; 3) open circuit.  
 Dominant contributor is #1).
- E7 Source category: generic
- TS4FE transformer main power generator or unit transformer liquid filled, single phase (146-242 kV)  
 Component boundary: detail n/a Operating mode: all Operating environment: normal  
 Generic failure mode: fail to function Original failure mode: no output(catastrophic)  
 FAILURE RATE OR PROBABILITY rec : 3.2E-7/hr high: 6.2E-7/hr low: 2.5E-7/hr  
 Source: IEEE 500 (1984) pg.350 Ultimate source: expert opinion aggregation and operating experience  
 Comment: Failure mode "no output" include: 1) automatic removal by protect. circuitry 2) manual removal; 3) open circuit.  
 4) is order of magnitude higher than #2) and #3).

E8 Source category: generic

TSAFE transformer main power generator or unit transformer liquid filled, single phase (all voltage levels)  
 Component boundary: detail n/a Operating mode: all Operating environment: normal  
 Generic failure mode: fail to function Original failure mode: no output(catastrophic)  
 FAILURE RATE OR PROBABILITY rec : 2.8E-7/hr high: 1.8E-6/hr low: 3.0E-8/hr  
 Source: IEEE 500 (1984) pg.348 Ultimate source: expert opinion aggregation and operating experience  
 Comment: This is a composite value of all voltage levels of main, liquid filled single phase transformers. Failure mode include:1)autom. removal; 2>manual removal; 3)open circuit. #1) is dominant.

E9 Source category: generic

TESFE transformer station service including excitation dry type, single phase (all voltage levels)  
 Component boundary: detail n/a Operating mode: all Operating environment: normal  
 Generic failure mode: fail to function Original failure mode: no output(catastrophic)  
 FAILURE RATE OR PROBABILITY rec : 2.7E-7/hr high: 2.3E-6/hr low: 8.0E-8/hr  
 Source: IEEE 500 (1984) pg.326 Ultimate source: expert opinion aggregation and operating experience  
 Comment: Given value is composite of three different voltage levels. Failure mode include: 1)automatic removal; 2) manual removal; 3)open circuit. Dominant contributor is #1).

E10 Source category: generic

TS2FE transformer main power generator or unit transformer liquid filled, single phase (2-30 kV)  
 Component boundary: detail n/a Operating mode: all Operating environment: normal  
 Generic failure mode: fail to function Original failure mode: no output(catastrophic)  
 FAILURE RATE OR PROBABILITY rec : 2.2E-7/hr high: 3.9E-7/hr low: 9.5E-8/hr  
 Source: IEEE 500 (1984) pg.347 Ultimate source: expert opinion aggregation and operating experience  
 Comment: Failure mode includes no output due to:1) automatic removal by protective circuitry; 2>manual removal; 3) open circuit.


E11 Source category: generic

TEGFE transformer station service including excitation liquid filled, single phase (0-40 kV)  
 Component boundary: detail n/a Operating mode: all Operating environment: normal  
 Generic failure mode: fail to function Original failure mode: no output(catastrophic)  
 FAILURE RATE OR PROBABILITY rec : 2.2E-7/hr high: 1.1E-6/hr low: 8.6E-8/hr  
 Source: IEEE 500 (1984) pg.318 Ultimate source: expert opinion aggregation and operating experience  
 Comment: Given value is composite of three different voltage levels. Failure mode include: 1)automatic removal; 2>manual removal 3)open circuit. dominant contributor is #1).

E12 Source category: generic

TEHFE transformer station service including excitation liquid filled, three phase (0-40 kV)  
 Component boundary: detail n/a Operating mode: all Operating environment: normal  
 Generic failure mode: fail to function Original failure mode: no output(catastrophic)  
 FAILURE RATE OR PROBABILITY rec : 1.1E-7/hr high: 8.1E-7/hr low: 5.4E-8/hr  
 Source: IEEE 500 (1984) pg.322 Ultimate source: expert opinion aggregation and operating experience  
 Comment: Given value is composite of three different voltage levels. Failure mode include: 1)automatic removal; 2>manual removal; 3)open circuit. Dominant contributor is #1).

# IAEA RELIABILITY DATA BASE



H1 Source category: updated

TA2FH transformer 220/120 V  
 Component boundary: detail n/a Operating mode: all Operating environment: normal  
 Generic failure mode: fail to function Original failure mode: fail during operation  
 FAILURE RATE OR PROBABILITY mean : 2.5E-6/hr 95%: 5.2E-6/hr 5%: 5.1E-7/hr  
 Source: Old PWR Ultimate source: generic data updated with plant operating experience  
 Comment: Generic mean 1.6E-6/hr. Operating experience 5.4E+5 hours of operation, 2 failures.

Z Source category: updated

TABFZ transformer general  
 Component boundary: detail n/a Operating mode: all Operating environment: normal  
 Generic failure mode: fail to function Original failure mode: fail during operation  
 FAILURE RATE OR PROBABILITY mean : 1.7E-6/hr  
 Source: ZION NPP PSS (tbl.1.5.1-5) Ultimate source: generic data updated with plant specific experience  
 Comment: Prior:IEEE 500(1977)(pg.300) transformer 601V-15kV, prior failure mode="all modes"  
 Operating experience:3.0E+5 hours of operation,1 failure.

O1 Source category: updated

TM2FO transformer high voltage outdoor  
 Component boundary: detail n/a Operating mode: all Operating environment: normal  
 Generic failure mode: fail to function Original failure mode: operational failure  
 FAILURE RATE OR PROBABILITY mean : 1.4E-6/hr 95%: 3.5E-6/hr 5%: 1.5E-7/hr REPAIR TIME: 10.8 hours  
 Source: Oconee NPP PRA (tbl.b-1.) Ultimate source: generic data upgraded with plant operating experience  
 Comment: Prior:IEEE 500 (1977)(pg.315),rec=median;max=80%.FM"catastrophic" seems to include load side protection).Op.exp. 81.900 hours  
 of operation,no failures. Repair time is generic maintn.duration.

H2 Source category: updated

TA5FH transformer 50/6 kV  
 Component boundary: detail n/a Operating mode: all Operating environment: normal  
 Generic failure mode: fail to function Original failure mode: fail during operation  
 FAILURE RATE OR PROBABILITY mean : 1.3E-6/hr 95%: 2.5E-6/hr 5%: 2.8E-7/hr  
 Source: Old PWR Ultimate source: generic data updated with plant operating experience  
 Comment: Generic mean 1.6E-6/hr. Operating experience 1.4E+5 hours of operation, no failures.

H3 Source category: updated

TA8FH transformer 8 kV / 6 kV  
 Component boundary: detail n/a Operating mode: all Operating environment: normal  
 Generic failure mode: fail to function Original failure mode: fail during operation  
 FAILURE RATE OR PROBABILITY mean : 1.3E-6/hr 95%: 2.5E-6/hr 5%: 2.8E-7/hr  
 Source: Old PWR Ultimate source: generic data updated with plant operating experience  
 Comment: Generic mean 1.6E-6/hr. Operating experience 1.4E+5 hours of operation, no failures.

H4 Source category: updated

TA6FH transformer 6kV/380 V  
 Component boundary: detail n/a Operating mode: all Operating environment: normal  
 Generic failure mode: fail to function Original failure mode: fail during operation  
 FAILURE RATE OR PROBABILITY mean : 4.9E-7/hr 95%: 1.1E-6/hr 5%: 8.6E-8/hr  
 Source: Old PWR Ultimate source: generic data updated with plant specific operating experience  
 Comment: Generic mean 6.9E-7/hr. Operating expereince 8.2E+5 hours of operation, no failures.


02 Source category: updated

TADFO transformer dry (4 kV/600V)  
 Component boundary: detail n/a Operating mode: all Operating environment: normal  
 Generic failure mode: fail to function Original failure mode: operational failure  
 FAILURE RATE OR PROBABILITY mean : 4.8E-7/hr 95%: 1.2E-6/hr 5%: 2.1E-8/hr REPAIR TIME: 10.8 hours  
 Source: Oconee NPP PRA (tbl.b-1.) Ultimate source: generic data updated with plant specific operating experience  
 Comment: Prior:IEEE 500(1977)(pg.300), rec=median;max=80% of distribution Operating experience: 4.34E+5 hours of operation, no failures.  
 Repair time is mean generic maintenance duration.

03 Source category: updated

TAEFO transformer dry (600 V/208 V)  
 Component boundary: detail n/a Operating mode: all Operating environment: normal  
 Generic failure mode: fail to function Original failure mode: operational failure  
 FAILURE RATE OR PROBABILITY mean : 3.1E-7/hr 95%: 7.8E-7/hr 5%: 5.7E-9/hr REPAIR TIME: 10.8 hours  
 Source: Oconee NPP PRA (tbl.b-1.) Ultimate source: generic data updated with plant specific operational experience  
 Comment: Prior:IEEE 500 (1977) pg.299.rec=median; max=80% of distribution. Operating experience:8.2E+5 hours of operation, no failures.  
 Repair time is mean generic maintenance duration.

# IAEA RELIABILITY DATA BASE



W1 Source category: generic

SIAFW switch limit general  
 Component boundary: detail n/a Operating mode: all Operating environment: normal  
 Generic failure mode: fail to function Original failure mode: failure to operate  
 FAILURE RATE OR PROBABILITY median: 2.5E-5/hr 95%: 8.3E-5/hr 5%: 8.3E-6/hr ERROR FACTOR: 3  
 Source: WASH 1400 (table III 4-2) Ultimate source: assessed from nuclear, industrial and military experience and data  
 Comment: The data do not uniquely separate the causes of failure, hence failure modes are not necessary independent. Failure to operate includes failures of contacts.Org.demand rel.Assumen 1 demand/day

I1 Source category: generic

SQAFI switch torque general  
 Component boundary: detail n/a Operating mode: all Operating environment: normal  
 Generic failure mode: fail to function Original failure mode: failure to operate  
 FAILURE RATE OR PROBABILITY mean : 8.3E-6/hr ERROR FACTOR: 3  
 Source: IREP NUREG 2728 (tb.5.1-1) Ultimate source: expert opinion  
 Comment: Where torque switch is used as part of pump/valve, switch failure rate is included in pump/valve failure rate. Original demand related value changed to time related assuming 1 demand/day.

W2 Source category: generic

SQAFW switch torque general  
 Component boundary: detail n/a Operating mode: all Operating environment: normal  
 Generic failure mode: fail to function Original failure mode: failure to operate  
 FAILURE RATE OR PROBABILITY median: 8.3E-6/hr 95%: 2.5E-5/hr 5%: 2.5E-6/hr ERROR FACTOR: 3  
 Source: WASH 1400 (table III 4-2) Ultimate source: assessed from nuclear and military experience and data sources  
 Comment: Data do not uniquely separate the causes of failure,hence failure modes are not necessary independent. Failure to operate include failures of contacts.Org.value per demand.Assumed 1 demand/day.

I2 Source category: generic

SPAFI switch pressure general  
 Component boundary: detail n/a Operating mode: all Operating environment: normal  
 Generic failure mode: fail to function Original failure mode: failure to operate  
 FAILURE RATE OR PROBABILITY mean : 8.3E-6/hr : n/s ERROR FACTOR: 3  
 Source: IREP NUREG 2728 (tb.5.1-1) Ultimate source: expert opinion  
 Comment: Original demand related value changed to time related assuming one demand per day.

I3 Source category: generic

SIAFI switch limit general  
 Component boundary: detail n/a Operating mode: all Operating environment: normal  
 Generic failure mode: fail to function Original failure mode: failure to operate  
 FAILURE RATE OR PROBABILITY mean : 8.3E-6/hr ERROR FACTOR: 3  
 Source: IREP NUREG 2728 (tb.5.1-1) Ultimate source: expert opinion  
 Comment: Where limit switch is used as part of pump/valve,switch failure rate is included in pump/valve failure rate. Original demand related value changed to time related assuming 1 demand per day.

W3 Source category: generic

SPAFW switch pressure general  
 Component boundary: detail n/a Operating mode: all Operating environment: normal  
 Generic failure mode: fail to function Original failure mode: failure to operate  
 FAILURE RATE OR PROBABILITY median: 8.3E-6/hr 95%: 2.5E-5/hr 5%: 2.5E-6/hr ERROR FACTOR: 3  
 Source: WASH 1400 (table III 4-2) Ultimate source: assessed from nuclear, industrial and military experience and data  
 Comment: Data do not uniquely separate causes of failures, hence failure modes are not necessary independent. Failure to operate includes failure of contacts.Org.value demand.Assumed 1 dem./day.

X Source category: generic

SGAFX switch all types  
 Component boundary: detail n/a Operating mode: all Operating environment: normal  
 Generic failure mode: fail to function Original failure mode: fail to function  
 FAILURE RATE OR PROBABILITY mean : 8.0E-6/hr 80%: 2.4E-5/hr 20%: 8.0E-7/hr  
 Source: NUREG 2815 (table C.1.) Ultimate source: expert opinion  
 Comment:

B1 Source category: generic

SIAFB switch limit general  
 Component boundary: detail n/a Operating mode: all Operating environment: normal  
 Generic failure mode: fail to function Original failure mode: failure to operate  
 FAILURE RATE OR PROBABILITY mean : 6.0E-6/hr max: 4.0E-6/hr min: 8.0E-7/hr  
 Source: NUREG 2815 (table C.1.) Ultimate source: expert judgement and IREP data  
 Comment: Where limit switch is used as a part of pump/valve, switch failure rate is included in pump/valve rate

F1 Source category: generic

SPAFF switch pressure  
 Component boundary: detail n/a Operating mode: all Operating environment: normal  
 Generic failure mode: fail to function Original failure mode: failure to operate  
 FAILURE RATE OR PROBABILITY mean : 3.1E-6/hr 95%: 5.0E-6/hr 5%: 2.0E-6/hr ERROR FACTOR: 1.5  
 Source: HWR data Ultimate source: HWR operating experience  
 Comment: Operational data for this failure mode are not given, but probably included in "all modes".  
 (data source IEEE 500??)

S1 Source category: generic

STAFS switch temperature general  
 Component boundary: detail n/a Operating mode: all Operating environment: normal  
 Generic failure mode: fail to function Original failure mode: fails to operate  
 FAILURE RATE OR PROBABILITY mean : 2.3E-6/hr  
 Source: Shoreham PRA, GE data (tb.A.2-1) Ultimate source: evaluation of BWR operating experience  
 Comment:

F2 Source category: generic

SFAFF switch flow  
 Component boundary: detail n/a Operating mode: all Operating environment: normal  
 Generic failure mode: fail to function Original failure mode: fail to operate  
 FAILURE RATE OR PROBABILITY mean : 1.7E-6/hr REPAIR TIME: 4 hours  
 Source: HWR data Ultimate source: HWR assessment  
 Comment: Ultimate source of data is not clear. (IEEE data ??)

F3 Source category: generic

SLAFF switch level  
 Component boundary: detail n/a Operating mode: all Operating environment: normal  
 Generic failure mode: fail to function Original failure mode: fail to operate  
 FAILURE RATE OR PROBABILITY mean : 1.4E-6/hr REPAIR TIME: 4 hours  
 Source: HWR data Ultimate source: HWR assessment  
 Comment: Ultimate data source is not known. (IEEE data ??)



E1 Source category: generic

SFAFE switch flow general  
 Component boundary: detail n/a Operating mode: all Operating environment: normal  
 Generic failure mode: fail to function Original failure mode: no function with signal  
 FAILURE RATE OR PROBABILITY rec : 9.8E-7/hr high: 1.8E-6/hr low: 8.0E-8/hr REPAIR TIME: .6 hours  
 Source: IEEE 500 (1984) pg.578 Ultimate source: expert opinion aggregation and operating experience  
 Comment: Failure rate is composite and include some non-nuclear sources

F4 Source category: generic

STAFF switch temperature  
 Component boundary: detail n/a Operating mode: all Operating environment: normal  
 Generic failure mode: fail to function Original failure mode: failure to operate  
 FAILURE RATE OR PROBABILITY mean : 5.3E-7/hr  
 Source: HWR data Ultimate source: HWR assesment  
 Comment: Ultimate data source is not known. (data source IEEE 500 ??)

E2 Source category: generic

SPAFE switch pressure general  
 Component boundary: detail n/a Operating mode: all Operating environment: normal  
 Generic failure mode: fail to function Original failure mode: no function with signal  
 FAILURE RATE OR PROBABILITY rec : 4.0E-7/hr high: 1.9E-6/hr low: 1.0E-8/hr REPAIR TIME: .6 hours  
 Source: IEEE 500 (1984) pg.556 Ultimate source: expert opinion aggregation and operating experience  
 Comment: Value is composite and include some non-nuclear sources For this component failure rate per hour and per cycle is given.

S2 Source category: generic

SFAFS switch flow general  
 Component boundary: detail n/a Operating mode: all Operating environment: normal  
 Generic failure mode: fail to function Original failure mode: fails to operate  
 FAILURE RATE OR PROBABILITY mean : 2.6E-7/hr  
 Source: Shoreham PRA,GE data(tb.A.2-1) Ultimate source: evaluation of BWR operating experience  
 Comment:

B2 Source category: generic

SPAFB switch pressure  
 Component boundary: detail n/a Operating mode: all Operating environment: normal  
 Generic failure mode: fail to function Original failure mode: failure to operate  
 FAILURE RATE OR PROBABILITY mean : 2.0E-7/hr max: 1.0E-6/hr min: 8.0E-8/hr  
 Source: NUREG 2815 (table C.1.) Ultimate source: expert judgement and IREP data  
 Comment:

B3 Source category: generic

SQAFB


switch torque general  
 Component boundary: detail n/a Operating mode: all Operating environment: normal  
 Generic failure mode: fail to function Original failure mode: failure to operate  
 FAILURE RATE OR PROBABILITY mean : 2.0E-7/hr max: 1.0E-6/hr min: 6.0E-8/hr  
 Source: NUREG 2815 (table C.1.) Ultimate source: expert judgement and IREP data  
 Comment: Where torque switch is used as a part of pump/valve, switch failure rate is included in pump/valve rate

E3 Source category: generic

STAFE

switch temperature general  
 Component boundary: detail n/a Operating mode: all Operating environment: normal  
 Generic failure mode: fail to function Original failure mode: no function with signal  
 FAILURE RATE OR PROBABILITY rec : 2.0E-7/hr high: 3.9E-7/hr low: 5.0E-8/hr REPAIR TIME: .5 hours  
 Source: IEEE 500 (1984) pg.534 Ultimate source: expert opinion aggregation and operating experience  
 Comment: Given value is composite. For this component failure rate per hour and per cycle is given.

# IAEA RELIABILITY DATA BASE



T1 Source category: generic

LLFFT transmitter level general  
 Component boundary: level transmitter only Operating mode: all Operating environment: normal  
 Generic failure mode: fail to function Original failure mode: signal failure  
 FAILURE RATE OR PROBABILITY mean : 3.8E-6/hr 95%: 2.0E-5/hr REPAIR TIME: 2 hours  
 Source: Swedish Rel.data book, tbl.35 Ultimate source: plant operating experience( 5 BWR plants), ATV reports, LERs  
 Comment: Operating experience:total pop.72. Operational time 289E+4 hours No.of failures 11.  
 a=0.188; b=49500

T3 Source category: generic

LFFFT transmitter flow general  
 Component boundary: transmitter only Operating mode: all Operating environment: normal  
 Generic failure mode: fail to function Original failure mode: signal failure  
 FAILURE RATE OR PROBABILITY mean : 3.4E-6/hr 95%: 1.9E-5/hr REPAIR TIME: 3 hours  
 Source: Swedish Rel.data book, tbl.33 Ultimate source: plant operating experience (5 BWR plants),ATV reports, LERs  
 Comment: Operating experience: total pop.97. Operational time 358E+4 hours. No.of failures 12. a=0.101; b=30200  
 Critical failures reported on 5 plants.

T3 Source category: generic

LTTFT transmitter temperature general  
 Component boundary: detail n/a Operating mode: all Operating environment: normal  
 Generic failure mode: fail to function Original failure mode: signal failure  
 FAILURE RATE OR PROBABILITY mean : 2.8E-6/hr 95%: 1.5E-5/hr REPAIR TIME: 3 hours  
 Source: Swedish Rel.data book, tbl.37 Ultimate source: plant operating experience(6 BWR plants), ATV reports, LERs  
 Comment: Operating experience: total pop. 132. Operational time 289E+4 hours. No.of failures 8. a=0.0579; b=20900  
 Critical failures reported on 5 plants.

M Source category: generic

LADFM transmitter flow, level, pressure general  
 Component boundary: transmitter only Operating mode: operating Operating environment: normal  
 Generic failure mode: fail to function Original failure mode: inoperable  
 FAILURE RATE OR PROBABILITY mean : 1.9E-6/hr 95%: 2.3E-6/hr 5%: 1.6E-6/hr  
 Source: NUREG 1740 (1984) (table 18) Ultimate source: US plants LER reports evaluation  
 Comment: Overall rate, with command faults. W/o command faults 1.7E-6/hr. Only the flow transmitter for BWR.  
 PWR rate is almost two orders of magnitude higher than BWR.

T4 Source category: generic

LPPFT transmitter pressure general  
 Component boundary: pressure transmitter only Operating mode: all Operating environment: normal  
 Generic failure mode: fail to function Original failure mode: signal failure  
 FAILURE RATE OR PROBABILITY mean : 1.8E-6/hr 95%: 1.0E-5/hr REPAIR TIME: 2 hours  
 Source: Swedish Rel.data book, tbl.29 Ultimate source: plant operating experience (5 BWR plants), ATV reports, LERs  
 Comment: Operating experience:total pop.203.Operational time 820E+4 hours no.of failures 15.  
 a=0.0558; b=30500

X Source category: generic

LGAFX transmitter all types  
 Component boundary: detail n/a Operating mode: all Operating environment: normal  
 Generic failure mode: fail to function Original failure mode: fail to function  
 FAILURE RATE OR PROBABILITY mean : 2.0E-6/hr 80%: 8.0E-6/hr 20%: 7.0E-7/hr  
 Source: VVER reliability data base Ultimate source: expert opinion  
 Comment:

E1 Source category: generic

LFFFE transmitter flow general  
 Component boundary: detail n/a Operating mode: all Operating environment: normal  
 Generic failure mode: fail to function Original failure mode: catastrophic  
 FAILURE RATE OR PROBABILITY rec : 1.5E-6/hr high: 2.8E-6/hr low: 6.2E-7/hr  
 Source: IEEE 500 (1984) pg.577 Ultimate source: expert opinion aggregation  
 Comment: Reference IEEE 500 (1977) Failure mode "catastrophic" include: 1) zero or maximum output; 2) no change in output with change in input. Dominant #1).

E2 Source category: generic

LLLFE transmitter level general  
 Component boundary: detail n/a Operating mode: all Operating environment: normal  
 Generic failure mode: fail to function Original failure mode: catastrophic  
 FAILURE RATE OR PROBABILITY rec : 1.4E-6/hr high: 3.0E-6/hr low: 7.1E-7/hr  
 Source: IEEE 500 (1984) pg.588 Ultimate source: expert opinion aggregation  
 Comment: Reference IEEE 500 (1977) Failure mode "catastrophic" include: 1) zero or max. output; 2) no change in output with change in input. Both about equal.

T5 Source category: generic

LXRFT transmitter pressure difference general  
 Component boundary: pressure difference transmitter only Operating mode: all Operating environment: normal  
 Generic failure mode: fail to function Original failure mode: signal failure  
 FAILURE RATE OR PROBABILITY mean : 1.4E-6/hr 95%: 8.3E-6/hr REPAIR TIME: 3 hours  
 Source: Swedish Rel. data book, tbl.31 Ultimate source: plant operating experience (7 BWR plants), ATV reports, LERs  
 Comment: Operating experience: total pop 132. Operational time 558E+4 hours No. of failures 8. a=0.0942; b=66200  
 Critical failures reported on 4 plants

F Source category: generic

LADFF transmitter flow, level, pressure (DP cells)  
 Component boundary: detail n/a Operating mode: all Operating environment: normal  
 Generic failure mode: fail to function Original failure mode: no output  
 FAILURE RATE OR PROBABILITY mean : 1.2E-6/hr 95%: 1.6E-6/hr 5%: 9.0E-7/hr ERROR FACTOR: 1.3 REPAIR TIME: 3 hours  
 Source: HWR data Ultimate source: HWR operating experience  
 Comment: Operational data for this failure mode are not given, but probably included in "all modes". Catastrophic failures are this and "no chng in output with ch.." summed together mean=1.9E-6/hr.

E3 Source category: generic

LPPFE transmitter pressure general  
 Component boundary: detail n/a Operating mode: all Operating environment: normal  
 Generic failure mode: fail to function Original failure mode: catastrophic  
 FAILURE RATE OR PROBABILITY rec : 8.8E-7/hr high: 1.7E-6/hr low: 2.0E-7/hr  
 Source: IEEE 500 (1984) pg.552 Ultimate source: expert opinion aggregation  
 Comment: Reference IEEE 500 (1977) Failure mode "catastrophic" include: 1) zero or max output; 2) no change in output with change in input. About equal contribution.

E4 Source category: generic

LITFE transmitter temperature general  
 Component boundary: detail n/a Operating mode: all Operating environment: normal  
 Generic failure mode: fail to function Original failure mode: catastrophic  
 FAILURE RATE OR PROBABILITY rec : 3.7E-7/hr high: 3.3E-6/hr low: 1.9E-7/hr  
 Source: IEEE 500 (1984) pg.531 Ultimate source: expert opinion aggregation  
 Comment: Reference IEEE 500 (1977) Failure mode include: 1) zero or max. output 2) no change of output with change of input. Dominant contributor is #1).

Y1 Source category: plant specific

LPPFY transmitter pressure general  
Component boundary: pressure transmitter only Operating mode: all Operating environment: normal  
Generic failure mode: fail to function Original failure mode: signal failure  
FAILURE RATE OR PROBABILITY mean :  $2.5E-6/hr$  REPAIR TIME: 5 hours  
Source: Swedish Rel.data book, tbl.29 Ultimate source: plant operating experience (Ringhals 2 PWR)  
Comment: Operating experience:total pop.12.Operational time  $39.91E+4$  hours 1 failure

Y2 Source category: plant specific

LXRFY transmitter pressure difference general  
Component boundary: pressure difference transmitter only Operating mode: all Operating environment: normal  
Generic failure mode: fail to function Original failure mode: signal failure  
FAILURE RATE OR PROBABILITY mean :  $8.4E-7/hr$  REPAIR TIME: 2 hours  
Source: Swedish Rel.data book, tbl.31 Ultimate source: plant operating experience (Ringhals 2 PWR), ATV reports  
Comment: Operating experience:total pop.72.Operational time  $239.5E+4$  hours No.of failure 2.