

# ***Research reactor core conversion guidebook***

## ***Volume 1: Summary***



INTERNATIONAL ATOMIC ENERGY AGENCY

IAEA

RESEARCH REACTOR CORE CONVERSION GUIDEBOOK  
VOLUME 1: SUMMARY  
IAEA, VIENNA, 1992  
IAEA-TECDOC-643  
ISSN 1011-4289

Printed by the IAEA in Austria  
April 1992

PLEASE BE AWARE THAT  
ALL OF THE MISSING PAGES IN THIS DOCUMENT  
WERE ORIGINALLY BLANK

## FOREWORD

In view of the proliferation concerns caused by the use of highly enriched uranium (HEU) and in anticipation that the supply of HEU to research and test reactors will be more restricted in the future, this guidebook has been prepared to assist research reactor operators in addressing the safety and licensing issues for conversion of their reactor cores from the use of HEU fuel to the use of low enriched uranium (LEU) fuel.

Two previous guidebooks on research reactor core conversion have been published by the IAEA. The first guidebook (IAEA-TECDOC-233) addressed feasibility studies and fuel development potential for light-water-moderated research reactors and the second guidebook (IAEA-TECDOC-324) addressed these topics for heavy-water-moderated research reactors. This guidebook, in five volumes, addresses the effects of changes in the safety-related parameters of mixed cores and the converted core. It provides an information base which should enable the appropriate approvals processes for implementation of a specific conversion proposal, whether for a light or for a heavy water moderated research reactor, to be greatly facilitated.

This guidebook has been prepared at a number of Technical Committee Meetings and Consultants Meetings and coordinated by the Physics Section of the International Atomic Energy Agency, with contributions volunteered by different organizations. The IAEA is grateful for these contributions and thanks the experts from the various organizations for preparing the detailed investigations and for evaluating and summarizing the results.

## **EDITORIAL NOTE**

*In preparing this material for the press, staff of the International Atomic Energy Agency have mounted and paginated the original manuscripts as submitted by the authors and given some attention to the presentation.*

*The views expressed in the papers, the statements made and the general style adopted are the responsibility of the named authors. The views do not necessarily reflect those of the governments of the Member States or organizations under whose auspices the manuscripts were produced.*

*The use in this book of particular designations of countries or territories does not imply any judgement by the publisher, the IAEA, as to the legal status of such countries or territories, of their authorities and institutions or of the delimitation of their boundaries.*

*The mention of specific companies or of their products or brand names does not imply any endorsement or recommendation on the part of the IAEA.*

*Authors are themselves responsible for obtaining the necessary permission to reproduce copyright material from other sources.*

*This text was compiled before the unification of Germany in October 1990. Therefore the names German Democratic Republic and Federal Republic of Germany have been retained.*

## PREFACE

This guidebook has been prepared to assist research reactor operators in addressing the safety and licensing issues for conversion of their reactor cores from the use of highly enriched uranium (HEU) fuel to the use of low enriched uranium (LEU) fuel. It contains a wide variety of information on the analyses that are required to prepare an amendment to a Safety Report, examples of different analyses and licensing documents, the fuels and testing data that are available, and operation of the reactor facility.

Two types of core conversions are considered: (1) conversions where only the fuel and reactor core are changed and (2) conversions where other major modifications are made to accommodate the fuel change.

In most cases, reactor operators will probably choose to convert to LEU fuel without changes in fuel element dimensions or core configurations, thereby minimizing the changes in the safety-related parameters of the facility. Many facilities may operate with an interim core using both HEU and LEU fuel until an equilibrium core with LEU fuel is established. Studies in this guidebook provide assistance in determining the key safety principles and parameters with mixed cores.

The guidebook is organized into 5 volumes comprising this Summary Volume (Vol. 1) and four other Volumes of Appendices.

The guidebook addresses five principal topics as follows:

1. Licensing

Conversion of a reactor core from the use of HEU fuel to the use of LEU fuel will generally require either a license amendment or a new license. Within this range, there is a wide spectrum of possibilities depending on the reactor characteristics and on the national situation. Reference can be made to IAEA Safety Series No. 35 (1984 Edition) for a description of the technical information to be included in a full Safety Report.

An application for approval to change the reactor fuel can generally be expected to require only an amendment to the current Safety Report and/or Safety Specifications. The amendment need address only factors, whether directly associated with the reactor or with ancillary plant and operations, which are affected by the changes in fuel composition and/or core configuration and operational requirements. If, however, more stringent regulations or requirements have been introduced since the original license was granted, the change to LEU fuel may involve a repetition of the entire licensing procedure.

Chapter 1 of the Summary is intended to assist the reactor operator in preparing an amendment to the reactor Safety Report and/or Safety Specifications for submission to the licensing or other approving authority. The scope is restricted to only those parts of a Safety Report which are considered likely to be directly affected by core conversion.

## 2. Analysis

Chapters 2-6 of the Summary and Appendices A-F (Volume 2) contain example analyses and results showing the differences that can be expected in the core safety parameters and the radiological consequences of hypothetical accidents. Also discussed are methods for preventing loss-of-coolant accidents. There are seven examples of licensing documents related to core conversion and two examples of the methods for determining power limits for Safety Specifications.

## 3. Analytical verification

Chapters 7-8 of the Summary and Appendices G and H (Volume 3) contain the results of a safety-related benchmark problem and comparisons of calculated and measured data. Both of these approaches are very useful in ensuring that the calculational methods employed in the preparation of a Safety Report are accurate. As a first step, it is recommended that reactor operators/physicists use their own methods and codes to calculate this benchmark problem, and to compare the results of calculations with measurements in their own reactor or in one of the reactors for which measured data are provided in Appendix H.

## 4. Fuels

The information and test data on available reduced enrichment fuels are summarized in Chapters 9-11. Detailed data on the fuel materials, irradiation tests, and post-irradiation examinations (PIE) can be found in Appendices I and J of Volume 4. These were the last of the Guidebook Appendices to be finalized and can be considered to reflect topic status at about 1989/1990. Appendix K of Volume 4 contains detailed examples of fuel specifications and inspection procedures that should prove very useful when procuring new fuel.

## 5. Operations

Chapters 12-14 of the Summary and Appendices L-N (Volume 5) contain useful information and recommendations for startup procedures and experiments with reduced enrichment fuels, and discussions of the experiences of several reactor operators with mixed cores composed of different types of fuel. Also included is information on the transportation of fresh and spent fuel, spent fuel storage, and reprocessing.

Users of the Guidebook are requested to note carefully the following important observations:

i) Whilst it is acknowledged that the internationally recognized definition of 'HEU' embraces all uranium whose  $^{235}\text{U}$  isotopic composition is equal to or greater than 20 wt%, the following modified definitions have, for reasons of simplicity, been adopted in this publication only:

HEU - Highly Enriched Uranium ( $\geq 70$  wt%  $^{235}\text{U}$ )  
MEU - Medium Enriched Uranium (45 wt%  $^{235}\text{U}$ )  
LEU - Low Enriched Uranium (<20 wt%  $^{235}\text{U}$ );

ii) The scope of the guidebook is so extensive that contributions were necessarily prepared and coordinated over a very long period. Consequently, no single "current status" date is applicable to all component sections. This is not considered significantly adverse to application of the guidebook for its intended purposes. More recent, or supplementary information, particularly in relation to the topics of Volumes 3 and 5, is available, if required, through the published proceedings of the Annual International Meetings on Reduced Enrichment for Research and Test Reactors as listed in this Volume;

iii) The IAEA may be contacted, through official channels, to provide coordinating assistance between reactor organizations and those laboratories which have offered technical assistance for core conversion studies on specific reactors.



## TOPICS ADDRESSED IN THE GUIDEBOOK

<u>Topic</u>	<u>Volume 1 (Summary) Chapter</u>	<u>Detailed Information, Volume</u>	<u>Appendix</u>
<b>1. <u>LICENSING</u></b>			
Topics to be addressed in a Safety Report Amendment for Core Conversion	1	–	–
<b>2. <u>ANALYSIS</u></b>			
Safety Analyses for Generic 10 MW Reactor	2	2	A
Safety Analysis – Probabilistic Methods	2	2	B
Methods for Preventing LOCA	3	2	C
Radiological Consequence Analyses	4	2	D
Examples of Safety Report Amendments	5	2	E
Safety Specifications	6	2	F
<b>3. <u>ANALYTICAL VERIFICATION</u></b>			
Benchmark Calculations	7	3	G
Comparison of Calculations with Measurements	8	3	H
<b>4. <u>FUELS</u></b>			
Fuel Materials Data	9	4	I
Irradiation and Post-Irradiation-Examination (PIE) of Dispersion Fuels with High Uranium Density	10	4	J
Examples of Fuel Specifications and Inspection Procedures	11	4	K
<b>5. <u>OPERATIONS</u></b>			
Startup Experiments	12	5	L
Experience with Mixed and Full Core Operation	13	5	M
Transportation, Spent Fuel Storage, and Reprocessing	14	5	N

## CONTENTS

CHAPTER 1. TOPICS TO BE ADDRESSED IN A SAFETY REPORT AMENDMENT FOR CORE CONVERSION .....	11
---	----

### ANALYSIS

CHAPTER 2. SAFETY ANALYSES FOR GENERIC 10 MW REACTOR .....	29
CHAPTER 3. METHODS FOR PREVENTING LOCA .....	37
CHAPTER 4. RADIOLOGICAL CONSEQUENCE ANALYSES .....	44
CHAPTER 5. EXAMPLES OF SAFETY REPORTS AMENDMENTS .....	50
CHAPTER 6. SAFETY SPECIFICATIONS .....	52

### ANALYTICAL VERIFICATION

CHAPTER 7. BENCHMARK CALCULATIONS .....	55
CHAPTER 8. COMPARISON OF CALCULATIONS WITH MEASUREMENTS .....	80

### FUELS

CHAPTER 9. FUEL MATERIALS DATA .....	85
CHAPTER 10. IRRADIATION AND POST-IRRADIATION EXAMINATION (PIE) OF DISPERSION FUELS WITH HIGH URANIUM DENSITY .....	86
CHAPTER 11. EXAMPLES OF FUEL SPECIFICATIONS AND INSPECTION PROCEDURES .....	87

### OPERATIONS

CHAPTER 12. STARTUP EXPERIMENTS .....	91
CHAPTER 13. EXPERIENCE WITH MIXED AND FULL CORE OPERATION .....	92
CHAPTER 14. TRANSPORTATION, SPENT FUEL STORAGE AND REPROCESSING .....	93
Contents of volumes 2-5 (Appendices A-N) .....	95
List of Contributing Organizations .....	105
List of Participants .....	107
List of publications on international meetings since 1983 on reduced enrichment fuel for research and test reactors .....	113

## Chapter 1

### TOPICS TO BE ADDRESSED IN A SAFETY REPORT AMENDMENT FOR CORE CONVERSION

#### 1.1 INTRODUCTION

Conversion of a reactor core from the use of highly enriched uranium fuel to the use of low enriched uranium fuel will generally require either a license amendment or a new license. Within this range, there is a wide spectrum of possibilities. The actual requirements for core conversion depend on the reactor characteristics and on the national situation. Figure 1.1 shows two possible approaches, applicable in different circumstances.

In this regard, the facility operator would be required to submit an amendment to, or a revision of, the Safety Report. In either case, the report should contain technical information to demonstrate that the converted facility will retain satisfactory safety margins in all key parameters and conform with all required criteria for its continued operation without undue risk to public health and safety. This information should permit a determination of the adequacy of the evaluations; that is, assurance that all the necessary evaluations have been included and are correct.

In compiling the report, the various guidelines and relevant regulations should be taken into account. Different regulations and requirements exist in different countries, but attention is drawn to IAEA Safety Series No. 35, "Safe Operation of Research Reactors and Critical Assemblies - Code of Practice and Annexes" (1984 Edition).

This Guidebook addresses matters related only to those parts of a Safety Report which are considered likely to be directly affected by core conversion, and section 1.2 of this chapter is intended to assist the reactor operator in preparing a Safety Report amendment for submission to the licensing authority.

The format adopted in section 1.2 for discussion of the Safety Report follows exactly the topic nomenclature and numbering system of chapters and sections as used in Annex 'A' of IAEA Safety Series No. 35 (1984 Edition) but, in the case of sections, only those considered likely to require amendment because of core conversion are listed and discussed.

**Comments in bold type are used to indicate the scope of possible amendments.**

Section 1.3 of this chapter contains a brief description of the tasks which must be performed to prepare the information required for the Safety Report amendment. It is divided into two parts, with the first part covering the tasks related to analysis and planning and the second part covering the tasks related to the properties and qualification of the fuel.

Depending upon the extent of the modifications being made, amendments to the following supporting documents for the Safety Report may also be required:

- supplementary plans, drawings and descriptions of the plant and its components,

- information on the safeguards and physical security of the plant,
- safety specifications not included in the Safety Report,
- information on the environmental impact,
- information on the provisions for spent fuel disposal (including storage, transfer, reprocessing, burial or other).

Kind of Alteration	Core Conversion Only	Core Conversion with Modifications*
Possible Hardware Alterations	New fuel, new core including control rods, new reflector	Major modifications of systems and components in addition to new fuel including control rods, new reflector
Documents for Application	Amendment to Safety Report, revision of relevant chapters including fuel specification and fuel qualification	Completely revised Safety Report including fuel specification and fuel qualification
Licensing Procedure	<ul style="list-style-type: none"> <li>- Application for a license amendment</li> <li>- Examination of licensing documents by an expert body</li> <li>- Approval of Amendment to Safety Report</li> </ul>	<ul style="list-style-type: none"> <li>- Application for a new license</li> <li>- Examination of the documents by all relevant bodies</li> <li>- Approval of licensing documents by the authority</li> </ul>

\* These modifications may be required by (a) a wish to upgrade the facility, (b) special facility features which require modifications in order to implement the conversion, (c) inadequacy of current safety features, which would require modifications even without core conversion. Such inadequacy might be revealed by a review of the reactor safety considered appropriate in view of the national requirements, the age of the facility, the period of time since the previous review, the extent of changes to the facility since that review, the state of existing documentation and the operating license.

FIG. 1.1. Example of possible licensing steps.

## 1.2 CHAPTERS OF A SAFETY REPORT INDICATING THOSE LIKELY TO REQUIRE AMENDMENT FOR CORE CONVERSION

### 1. Introduction and General Description of Facility

The first chapter of the Safety Report should present an introduction to the report and a general description of the facility.

The general description need only indicate the extent of changes to the facility and the reasons for the changes. References should be given to relevant supporting documents, drawings, etc. for the modified plant. The legislative and other requirements relevant to the reactors should be identified.

### 2. Site Characteristics

Site characteristics are not expected to be affected by core conversion.

### 3. Safety Principles and General Design Criteria

This chapter of the Safety Report should identify, describe, and discuss the safety principles of the architectural and engineering design of the structures, components, equipment, and systems important to safety.

The safety principles, design criteria, and mechanical design methods are not expected to be affected by core conversion.

### 4. Buildings and Structures

Generally, there is no effect expected here for core conversion.

### 5. Reactor

In this chapter of the Safety Report, the applicant should provide an evaluation and supporting information to establish the capability of the reactor to perform its safety functions throughout its design lifetime with the new core under all normal operational modes (including both transient and steady state) and accident conditions. This chapter should also include information to support the analyses presented in Chapter 16, Safety Analyses, of Safety Series No. 35 (1984 Edition).

#### 5.1 Summary Description

A summary description of the mechanical, nuclear, and thermal and hydraulic designs of the various reactor components, including the fuel, reactor vessel internals, and reactivity control systems, should be given. The description should indicate the independent and interrelated performance and safety functions of each component. A summary table of the important design and performance characteristics should be included. A tabulation of analysis techniques used, load conditions considered and names of verified computer codes should be provided.

Directly affected by core conversion will be the density and enrichment of the uranium and, possibly, the chemical composition of the fuel meat. Also, in some cases, fuel element design, control rod design, and reflector element design will be affected.

## **5.2 Fuel System Design**

The design bases for the mechanical, chemical, and thermal design of the fuel system that can affect or limit the safe operation of the facility should be presented. The description of the fuel system mechanical design should include the following aspects: (a) mechanical design limits such as those for allowable stresses, deflection, cycling, and fatigue; (b) capacity for fuel fission gas inventory and pressure; (c) a listing of material properties; and (d) considerations for radiation damage, materials selection, and normal operational vibration.

The chemical design should consider all possible fuel/cladding/coolant interactions. The description of the thermal design should include such items as maximum fuel and cladding temperatures and fuel cladding integrity criteria. Details of fuel qualification should be included.

The selection of design bases, actual design description, design evaluation, and the proposed fuel testing and inspection plan should be discussed.

Detailed specifications on mechanical, chemical, and thermal design could be presented in additional reports. The Safety Report should only include principal details necessary for understanding nuclear design and safety analysis. Of special interest are experimentally verified limitations for the chosen fuel element design.

The technical description of the fuel elements will be changed owing to the lower enrichment and the probable higher fissile content of each fuel element. The physical properties of the fuel plates, e.g. heat capacity and thermal conductivity will be changed even if the geometrical shape and cladding thickness are preserved.

## **5.3 Nuclear Design**

The design bases, design description, and analysis for the nuclear design of the fuel and reactivity control systems should be provided and discussed, including nuclear and reactivity control limits such as excess reactivity, control rod insertions, fuel burnup, negative reactivity feedback, core design lifetime, fuel replacement philosophy, reactivity coefficients, stability criteria, maximum controlled reactivity insertion rates, control of power distribution, shutdown margins, stuck rod criteria, rod speeds, chemical and mechanical shim control, burnable poison requirements, and backup and emergency shutdown provisions.

A comparison of the old and new nuclear design should be made in addition to the required new calculations for presentation of the main changes to the licensing authorities. The main purpose for this comparison is to gain better understanding of the safety analysis.

Core conversion may require re-consideration of the fissile loading required in initial and subsequent cores and re-statement of reactivity values and shutdown reactivity, power peaking factors and burnup data for the various operational states during the life of the core. Reflector changes should be discussed because, in some cases, they may influence core-size, burnup, form-factors, etc. Plutonium produced in the fuel may also need to be considered, even though the quantities are expected to be small.

#### 5.4 Thermal and Hydraulic Design

The design bases, design description, and analysis for the thermal and hydraulic design of the reactor and core coolant system should be provided, including such items as maximum fuel and clad temperatures, critical heat flux ratio (at rated power, at design overpower, and during transients), flow velocities and distribution control, coolant and moderator voids, hydraulic stability, transient limits, fuel cladding integrity criteria, and fuel assembly integrity criteria.

There should be a discussion of the testing and verification techniques to be used to ensure that the planned thermal and hydraulic design characteristics of the core and the reactor coolant system have been provided and will remain within required limits throughout core lifetime.

If there are no changes in fuel element geometry, core-size or power peaking factors, only the thermal design needs discussion; otherwise, both thermal and hydraulic design should be discussed. A comparison with the old design is recommended.

#### 5.5 Reactor Materials

A list of the materials and their specifications for each component of the control rod system and for reactor internals which have undergone changes should be presented. The effects of changed irradiation conditions on the materials should be discussed if significant.

#### 5.6 Mechanical design of Reactivity Control Systems

Information should be presented to establish that the control rods (dimensions and materials) and the control rod drive system, which includes the essential ancillary equipment and systems, are designed and installed to provide the required functional performance and are properly isolated from other equipment. Additionally, information should be presented to establish the bases for assessing the combined functional performance of all the reactivity control systems (including insertion times) to mitigate the consequences of anticipated transients and postulated accidents.

If the control rod design has changed, information should be presented to establish that the control rod drive system, which includes the essential ancillary equipment and hydraulic systems, is still able to provide the required functional performance (including insertion times). Details of the testing programme and the results of the tests should be given.

### 6. Reactor Coolant System and Connected Systems

This chapter of the Safety Report should provide information regarding the reactor coolant system and systems connected to it. Evaluations, together with the necessary supporting material, should be submitted to show that the reactor coolant system is adequate to accomplish its objective and to maintain its integrity under conditions imposed by all foreseeable reactor behaviour, either normal or accident conditions. The information should permit a determination of the adequacy of the evaluations. Evaluations included in other chapters which have a bearing on the reactor coolant system should be referenced.

If the geometrical shape of the fuel elements is changed as in Section 5.4, the primary cooling circuit performance may be altered and a new set of normal operation characteristics could result. However, if there are no drastic changes in fuel element geometry or reduction of margins to the safety limits due to higher power peaking factors, no significant changes in the reactor coolant system will occur for the same nominal reactor power level.

## 7. Engineered Safety Features or Barriers

Engineered safety features may be provided to mitigate the consequences of postulated accidents in spite of the fact that these accidents are very unlikely. This chapter of the Safety Report should present information in sufficient detail to permit an adequate evaluation of the performance capability of these features. A listing of the information that should be included is contained in IAEA Safety Series No. 35 (1984 Edition), Annex A, p. 37.

Normally, the requirement for an Emergency Core Cooling System (ECCS) or the requirements to be met by an existing ECCS will not be affected by core conversion if there are only minor changes in the decay heat levels.

## 8. Instrumentation and Controls

This chapter of the Safety Report should provide information regarding the instrumentation and control systems, including the power regulating systems for reactor control, the reactor protection system, and other engineered safety systems instrumentation. The information provided should emphasize those instruments and associated equipment which constitute the reactor safety system.

If there are no significant changes in the nuclear and thermal/hydraulic characteristics of the core (Sections 5.3 and 5.4), it is not expected that core conversion will affect the nuclear instrumentation and control system other than possible re-calibration at initial start-up after conversion.

If there are significant changes in the nuclear and thermal/hydraulic characteristics of the core, new trip settings may have to be determined.

## 9. Electric Power

The electric power system is the source of power for the reactor coolant pumps and other auxiliaries during normal operation and for the safety system and engineered safety features during abnormal and accident conditions. The information in this chapter of the Safety Report should establish the functional adequacy of the safety-related electric power systems and ensure that these systems have adequate redundancy, independence, and testability in conformance with current criteria.

It is not expected that the electric power system will be affected by core conversion unless major plant changes are required.

## 10. Auxiliary Systems

This chapter of the Safety Report should provide information concerning the auxiliary systems included in the facility. Those systems that are essential for the safe shutdown of the reactor or the protection of the health and safety of the public should be identified. The description of each system,



the design bases for the system and for critical components, a safety evaluation demonstrating how the system satisfies the design bases, the testing and inspection to be performed to verify system capability and reliability, and the required instrumentation and controls should be provided.

It is not expected that auxiliary systems will be affected with the possible exception of fuel storage and handling facilities.

#### 10.1 Fuel Storage and Handling

Systems for storing fresh and spent fuel, for cooling and cleaning the spent fuel pool (if applicable), and for handling and, if necessary, cooling the fuel as it moves within the facility should be described in this section. Design bases, such as quantity of fuel to be stored and the means for maintaining a subcritical array, should be provided, along with an evaluation of each system's capability to protect against unsafe conditions.

It will be necessary to demonstrate that for LEU fuel, both the fresh and spent fuel storage meet criticality requirements. Also, spent fuel handling procedures will need to be re-assessed with respect to maximum allowable temperatures in the fuel and to the need for transport flask cooling.

### 11. Experimental Usage

In this chapter, the expected experimental use of the reactor should be discussed in relation to the experimental facilities described in previous chapters and correlated with the safety specifications for experiments found in Chapter 17 of the Safety Report.

Generally, it is not expected that the safety aspects of the experimental programme will be affected by core conversion.

### 12. Radioactive Waste Management

This chapter of the Safety Report should describe: (a) the capabilities of the plant to control, collect, handle, process, store, and dispose of liquid, gaseous, and solid wastes that may contain radioactive materials; (b) the instrumentation used to monitor the release of radioactive wastes; and (c) the management of spent fuel (see also Section 10.1).

The information should cover normal operation, including anticipated operational occurrences (refueling, purging, equipment downtime, maintenance, etc.).

It is expected that the only effect of core conversion will be to modify the source terms.

#### 12.1 Source Terms

The Safety Report should indicate the sources of radioactivity that serve as design bases for the various radioactive waste treatment systems for normal operation including anticipated operational occurrences and for design conditions.

The source terms used as the design bases for shielding and component failures should be provided.

Estimates of the release of radioactive materials (by radionuclide) from each source identified and the subsequent transport mechanism and release path should be provided. Identify planned operations, including experiments and anticipated operational occurrences, that may result in release of radioactive materials to the environment. Consider leakage rates and concentrations of radioactive materials for both expected and design conditions. The bases for all values used should be provided. Describe changes from previous designs that may affect the release of radioactive materials to the environment.

Changes in core material will require re-calculation of source terms arising from the fuel elements.

### 13. Radiological Protection

This chapter of the Safety Report should provide information on methods for radiological protection as required by the IAEA Code of Practice (Safety Series No. 35, 1984 Edition, Chapter 13, p. 16), including estimated occupational radiation exposures to operating and construction personnel and to the public during normal operation and anticipated operational occurrences. It should provide information on facility and equipment design, the planning and procedures programmes, and the techniques and practices employed by the applicant in meeting the standards for protection against radiation.

It is expected that the only effect would be on the radiation design features.

#### 13.3 Radiation Design Features

In this section, equipment and facility design features such as shielding, ventilation, and area and airborne radioactivity monitoring instrumentation which are intended to ensure that radiation exposures are within the specified requirements and as low as reasonably achievable (ALARA) should be described.

The radiation level outside water or concrete will only be marginally influenced by changes in core size or reflector. Therefore, the radiation level is not expected to be affected by core conversion unless major changes to the plant are required.

Depending upon the detailed reactor design, the activity in the primary circuit components may be very sensitive to delay times of coolant on exit from the core. If the coolant flow rate has been increased at all, the adequacy of the delay system may require reassessment.

### 14. Conduct of Operations

This chapter of the Safety Report should provide information relating to the preparations and plans for operation of the facility. Its purpose is to provide assurance that the applicant will establish and maintain a staff of adequate size and technical competence and the operating plans to be followed by the licensee are adequate to protect public health and safety.

The need to revise procedures and re-train staff should be considered if major changes to the plant are required.

## 14.6 Security

This section of the Safety Report should describe the plans for physical protection of the facility. It is a general practice in many countries to have these plans described in a separate document (see IAEA Safety Series No. 35, 1984 Edition, Code of Practice, Section 15, p. 19).

In the separate document, a distinction should be made between physical protection of the plant and of the fuel. The physical protection for the plant (fission product inventory, MCA) is not influenced by core conversion. The physical protection of the LEU fuel will be lower in some cases.

## 15. Commissioning or Test Programme for Core Conversion

This chapter of the Safety Report should provide information on the test programme for structures, systems, components, and design features for the facility. The information provided should address major phases of the test programme, including pre-operational tests, initial fuel loading and initial criticality, low-power tests, and power-ascension tests, if applicable.

Three possible methods for core conversion are recognized:

1. Gradual conversion over a number of refuelling cycles.
2. Complete core change at one shutdown.
3. Major plant changes.

The type of test programme necessary will be different in each case.

A start-up programme for verifying the calculations and for educating the reactor operators is necessary. Such a programme is required, especially if mixed cores are used, in order to assure that adequate thermal-hydraulic safety margins and shutdown margins are maintained.

Hydraulic and reactor physics tests on a new fuel element design must be performed prior to full-power operation. The performance of all reactor heat removal systems must be verified.

## 16. Safety Analyses

The evaluation of the safety of a research reactor should include analyses of the response of the reactor to postulated disturbances in process variables and to postulated malfunctions, failures of equipment, or operator errors. Such safety analyses provide a significant contribution to the selection of limiting conditions for operation, limiting safety system settings, and design specifications for components and systems from the standpoint of public health and safety.

The situations analysed should include anticipated operational occurrences, off-design transients that induce fuel failures, and postulated accidents of low probability (e.g., the sudden loss of integrity of a major component). The analyses should include an assessment of the consequences of an assumed fission product release that would result in potential hazards not exceeded by those from any accident considered credible.

Besides fuel element design, core design, and fuel reliability, the accident analysis for core conversion is most important. An adequate safety margin must be demonstrated and in some cases, only a marginal reduction of the existing margins could be accepted. In many cases the conversion of the fuel only may not require new licensing procedures for the conversion. The accident analysis must be discussed very carefully for the LEU fuel to ensure that current safety requirements are satisfied. If possible, the analyses for the LEU and HEU designs should be compared in order to have a clear final resume of all changes and the overall increase or decrease of the risk.

Reactivity transients, loss-of-coolant and loss-of-flow accidents must be reconsidered and may need to be reanalyzed owing to possible changes in fuel element design and the response of the fuel to accident conditions and possible changes in temperature feedback coefficients, absorber worths, and thermal-hydraulic characteristics. The probability of fission product release must be reevaluated.

The scope of the work depends on the magnitude of the changes to the core and the system.

Examples of representative accidents, the analysis of which may be affected by the change to LEU fuel, are listed in Table 1.1. Re-analysis of these accidents should take into account the changes in the reactor characteristics after conversion to LEU fuel. The nature and extent expected for some of these changes are summarized in Chapters 2 to 4 and are described in detail in Appendices A to D.

#### 17. Safety Specifications

Each Safety Report may contain or refer to Safety Specifications that set forth safety limits and safety system settings, limiting conditions for safe operation, surveillance requirements, and administrative and organizational requirements. These are imposed on facility operation for, among other purposes, the protection of the health and safety of the public. The safety specifications should be derived from and be consistent with the safety analysis in Chapter 16 of IAEA Safety Series No. 35.

Revisions must be made to the conditions referring to fuel element loading, temperature and cooling. The conditions on absorber worths may also need to be re-evaluated. Trip limits referring to the core thermal-hydraulics and reactor physics parameters may require revision.

#### 18. Quality Assurance

A quality assurance system and specifications for the new fuel, acceptable to the licensing body, should be agreed between the operator and the fuel fabricator.

In the case where modifications to the reactor are necessary, the quality assurance in the design, production and installation of the modified systems should be discussed.

#### 19. Decommissioning

In some Member States, there is a requirement to include in the Safety Report plans for decommissioning the reactor.

The scope of work depends on the magnitude of the changes to the core and system.

TABLE 1.1. EXAMPLES OF REPRESENTATIVE ACCIDENTS THAT MAY NEED TO BE RE-ANALYSED IN A SAFETY REPORT AMENDMENT FOR CORE CONVERSION\*

---

DECREASE IN HEAT REMOVAL BY THE REACTOR COOLING SYSTEM

- Primary pumps failure and flow coastdown
- Flow blockage to coolant channels

REACTIVITY INSERTIONS AND POWER DISTRIBUTION ANOMALIES

- Startup accident giving ramp insertion of reactivity
- Cold water insertion
- Control rod and control rod follower failure
- Fuel loading error
- Flooding or voiding of experimental beam ports, loops, or thimbles
- Failure or withdrawal of an in-core experiment
- H<sub>2</sub>O insertion in a D<sub>2</sub>O system or vice versa, or loss of H<sub>2</sub>O coolant where other moderation is used
- Criticality during fuel handling
- Control system runaway

CHANGES IN INVENTORY OR PRESSURE OF REACTOR COOLANT

- Whole core loss-of-coolant accident (LOCA)

RADIOACTIVE RELEASE FROM A SUBSYSTEM OR COMPONENT

- Local failure/melting of a few fuel plates or rods in core
  - Fuel element cladding failure in core
  - Fuel element failure during handling incident
- 

\* See also IAEA Safety Series No. 35 (1984 Edition), Annex A, p. 48.

### 1.3 SUMMARY OF REQUIRED TASKS

This section briefly describes the tasks that must be performed to provide the information required for a Safety Report amendment for core conversion. The tasks are listed in an order in which they could be logically performed and are divided into two parts. The first part (General Considerations) includes mostly the analytical and planning tasks described in Chapter 1 of this Volume. The second part (Fuel Considerations) includes tasks related to the properties and qualification of the fuels described in Volume 4 of this Guidebook.

## 1. General Considerations

### 1.1 General Design Features

Summary description of reactor design in comparison with the former reactor design.

### 1.2 General Design Rules

Statement of the main rules and regulations taken into account in designing modified systems and components.

### 1.3 Fuel Management

Summary description of the burnup cycle and the plutonium production. Statement of burnup data (discharge burnup of initial core, subsequent cores, fully-converted cores, and equilibrium core).

### 1.4 Power Distribution

Summary description and explanation of the selected fuel element arrangements and modifications; diagram of a representative power density distribution over the core cross-section with explanation, statement of the macroscopic power density distribution and the local power density peaks.

### 1.5 Reactivity Balance

Description of the compensation of excess reactivity. Description of the compensation of reactivity changes (e.g. burnable and Xenon poisoning). Statement of representative reactivity equivalents (e.g. for stuck control absorber) and of the maximum reactivity change rate.

Statement of reactivity values of the reactor, of shutdown reactivity for different operational states (cold, zero power, full power) and burnup states.

### 1.6 Reactivity Coefficients

Definition of the reactivity coefficients. Statement of the reactivity coefficients of the fuel temperature (Doppler coefficient), of the moderator temperature, moderator density and voids and power. Representation of the dependences (e.g. on operational state, burnup) in diagrams.

### 1.7 Reactor Protection System

Discussion of possible changes in the control rod design and worth, in the calibration of the linear control and safety channels, and in the trip safety settings.

### 1.8 Radiation and Shielding

Summary description of the radiation sources in the reactor core, i.e., gamma radiation and neutron radiation in different energy groups. Statement of the radiation flows in the individual shielding media and dose rates (neutrons, gamma) in radial and axial direction.

Statement of the concentrations of radioactive materials in the reactor coolant; statement of the equilibrium activities (reference values in stationary operation for planning and safety analyses) for the isotopes of the fission products (noble gases, iodine, solid matter) and of the activation products (gases, corrosion products).

#### 1.9 Thermohydraulic Design Principles

Statement of the parameters and limits considered in the design (e.g. critical heat flux ratio, thermohydraulic stability, power density in the fuel, power distribution in the reactor core).

#### 1.10 Hot-Channel Factors/Peaking Factors

Definition of the factors. Statement of the expected values and limits of acceptability.

#### 1.11 Critical Heat Flux Ratio

Definition of the critical heat flux ratio. Statement of its expected value in the hot channel under different operating conditions and the limits of acceptability including diagram and explanation.

Description of the determination of the critical heat flux ratio during regular operation.

#### 1.12 Reactor Cooling System

If modifications are necessary (e.g. due to increased core pressure drop), the following should be provided (1) a summary functional description of the individual components, (2) a statement of significant characteristics (e.g. pressure, temperature and throughput), (3) a summary description of the function and design of the recirculating pumps (e.g. speed, capacity, discharge flow), and (4) summary descriptions of material and certification tests and in-service inspections.

#### 1.13 Accident Analysis

Calculations (including e.g. assumptions, physical models and mathematical methods, description of the accident course and effects of the accident) of reactor behaviour during accidents identified in Table 1.1 of this chapter.

Further specification of the events to be considered (e.g. primary pumps failure, flow blockage, startup accident, different kinds of LOCA etc.) has to be considered on a case by case basis.

#### 1.14 Emergency Core Cooling System

If modifications are necessary to an existing ECCS, a description should be provided of the residual heat production, the functions and operation of the ECCS design (e.g. capacity redundancy, spatial separation of the system), and the test possibilities (e.g. functional tests at certain intervals during operation or during a refuelling operation).

### 1.15 Mixed Cores Operation

Where there will be a transitional period with mixed cores of HEU and LEU fuel, the scheme to be adopted for changing the core from HEU to LEU should be described. Safety aspects to be considered include power distribution and peaking, prediction of burnup, and reactivity effects including the worths of control absorbers. Where other aspects such as the hydraulic characteristics of the fuel have changed, the effects of these should also be considered.

### 1.16 Startup Procedures

Description of the pre-startup test, startup, zero power and power range tests including e.g. chemical and radiochemical measurements,, measurements of the radiation level, measurements of the shutdown reactivity and reactivity coefficients, power calibrations.

### 1.17 Operational Procedures

Summary description of changed operating measures if such changes are necessary due to the modifications. Procedures for startup, power operation and calibration, normal and emergency shutdown, decay heat removal, handling and emergency procedures will need revision to the extent that modifications have been necessary.

### 1.18 Handling and Storing of Fuel Elements

If modifications are needed, description should be provided of the storage provisions for both fresh and spent fuel elements, their position and their capacity. Criticality safety considerations should also be described and explained. Description should also be given of the provisions against crash of heavy loads (e.g. fuel element transport cask) and for spent elements, the provisions to detect and monitor leaks.

## 2. Fuel Considerations

### 2.1 Maximum Burnup Levels

Discuss the maximum burnup levels with the new fuel. Compare this data with that experienced for the present fuel.

### 2.2 Thermal Power Density

Discuss the maximum power density expected with the new fuel and compare with the present fuel.

### 2.3 Geometry

Discuss any geometry differences that may exist when using the new fuel both in standard fuel elements and in control elements.

### 2.4 Thermal Characteristics

Discuss the thermal conductivity of the fuel, the maximum fuel and clad temperatures, the maximum surface heat flux, the maximum coolant velocity, etc. expected using the new fuel and compare with the present fuel.



## 2.5 Manufacturing Data

Describe the manufacturing process of fuel and include all necessary data to support the conclusion that the fuel will perform safely.

## 2.6 Failure History

Discuss the average or projected rejection rate for the new fuel and any reactor failure history or estimates using the new fuel. Compare these values with statistical/historical data for the present fuel.

## 2.7 Fuel Swelling or Blistering

Discuss the degree of dimensional stability as a function of specific power, burnup, and fuel temperature. Those parameters considered to be design limits should be included as technical specifications and compared with similar values using the present fuel.

## 2.8 Corrosion Behaviour

Discuss corrosion rates for the fuel cladding under projected typical water chemistry conditions using the new fuel and compare with similar data for the present fuel. Include the basis for and any changes required in water chemistry and surveillance specifications.

## 2.9 Quality Assurance

Describe the quality assurance procedures to be followed in the design and production of the modified systems and components.

## **ANALYSIS**

## Chapter 2

### SAFETY ANALYSES FOR GENERIC 10 MW REACTOR

#### 2.1 INTRODUCTION

This summary is based on the work presented in Appendices A and B. Appendices A-1 and A-2 present the results of safety analyses performed by INTERATOM (FRG) and the Argonne National Laboratory (USA), respectively, for the generic 10 MW reactor based on replacement of the HEU plate-type fuel with LEU plate-type fuel. Appendix A-3 on the other hand presents the results of safety analyses performed by GA Technologies (USA) for replacement of the HEU plate-type fuel with TRIGA LEU rod-type fuel. Appendix B presents a methodology for probabilistic accident analysis contributed by GEC (UK) and the UKAEA-SRD (UK), although the information does not contain a comparative study of HEU and LEU fuels.

For the calculations in Appendix A, unlike the benchmark studies (Chapter 7), the contributors were free to select boundary conditions for the hypothetical accidents consistent with their own regulatory requirements. For comparison of methods of calculation, reference can be made to Chapter 7 and Appendix G.

#### 2.2 PLATE-TYPE FUELS

##### 2.2.1 Equilibrium Cores

In Appendices A-1 and A-2, the same HEU fuel element with 23 plates and 280 g  $^{235}\text{U}$  is studied. For the LEU core, both contributions examine the safety parameters of an equilibrium core and each core of a gradual transition from HEU to LEU fuel. One case uses an LEU fuel element with

20 plates, 1 mm thick fuel meat, and a fissile loading of 446 g and the other uses and LEU fuel element with 390 g  $^{235}\text{U}$  and the same geometry as the HEU element.




FIG. 2.1. 10 MW reactor core.

The 5 x 6 element core (Fig. 2.1) contains 23 MTR-type fuel elements and 5 control fuel elements. The core is reflected by graphite on two opposite faces and is surrounded by water. One flux trap is located near the center of the core and another near an edge.

The first step in the calculations was to compare the operating parameters and safety margins of the HEU and LEU equilibrium cores to ensure that these characteristics are satisfactory before beginning the HEU-to-LEU transition core analysis.

The data include cycle lengths, average  $^{235}\text{U}$  discharge burnups, nuclear power peaking factors, steady-state thermal-hydraulic safety margins, control rod worths, and shutdown margins.

The cycle lengths are considerably longer in the LEU cores than in the HEU core because the fissile loading of the LEU elements is much larger. The percentage of  $^{235}\text{U}$  burned in the discharged elements is about the same in the HEU and LEU cases. The thermal-hydraulic safety margins and the shutdown margins in all of the cores are shown to be entirely adequate to guarantee the safety of the facility.

### 2.2.2 Transient Analyses

The basic kinetics parameters that were computed for the HEU and LEU equilibrium cores are shown below:

	<u>HEU</u>	<u>LEU</u>
Prompt neutron generation time $\Lambda$ , ( $\mu\text{s}$ )	55	40-42
Effective delayed neutron fraction, $\beta_{\text{eff}}$	0.0076	0.0073

The reactivity feedback coefficients for the combined effects of moderator temperature and density are nearly the same in the HEU and LEU cores. However, the LEU cores have much larger Doppler coefficients and larger void coefficients as well. The latter two coefficients play an important role in distinguishing LEU fuel from HEU fuel in some of the transient analyses.

Two types of transients are analyzed in both Appendices A-1 and A-2. These are:

- Loss-of-flow transients
- Slow reactivity insertion transients

#### Loss-of-Flow-Transients

It was assumed that the reactor is operating at its maximum overpower level when the loss-of-flow occurred. The coastdown of the primary flow rate was approximated by an exponential function with a time constant of 1.0s. The trip setting was at 85% of the nominal flow, with a time delay of 200 ms before the shutdown reactivity insertion. The calculations were terminated at a relative flow rate of 15% because then the natural circulation flaps are assumed to open automatically causing a flow reversal.

The results of calculations taken from Appendix A-1 are shown in Table 2.1. Comparison of the HEU and LEU cases shows that the peak clad surface temperature, the coolant outlet temperature and the safety margin against flow instability are almost identical. The only exception is the peak temperature in the fuel meat, which is about  $20^{\circ}\text{C}$  higher for the LEU fuel because of the lower thermal conductivity of this fuel. Similar results were obtained in Appendix A-2, where the peak temperatures at the surface of the clad were  $114^{\circ}\text{C}$  and  $113^{\circ}\text{C}$  in the HEU and LEU cases, respectively.

All of the peak clad surface temperatures computed for this transient are far below the melting temperature of the cladding, which is about  $600^{\circ}\text{C}$  but depends on the specific composition of the alloy cladding material that is used.

TABLE 2.1. FAST LOSS-OF-FLOW TRANSIENT

FUEL	HEU	LEU
Initial Power, MW	11.5	11.5
Initial Flow Rate, m <sup>3</sup> /h	1000.0	1000.0
Time Constant for Flow Decay, s	1.0	1.0
Flow Trip Point, %	85.0	85.0
Time Delay, s	0.2	0.2
Power Level at Scram, %	107.4 (0.363)*	106.1 (0.363)
Peak Fuel Temperature, °C	144.1 (0.363)	167.4 (0.363)
Peak Clad Temperature, °C	141.1 (0.363)	141.9 (0.363)
Peak Outlet Temperature, °C	80.1 (0.42)	80.1 (0.42)
Min. Bubble Detachment Parameter, cm <sup>3</sup> K/Ws	75.4 (0.38)	77.3 (0.38)
At ~ 15% Relative Flow:		
Fuel Temperature, °C	66.7	67.5
Clad Temperature, °C	66.5	66.0
Outlet Temperature, °C	51.1	51.2

\* Quantities in parentheses indicate time (in seconds) at which values occur.

#### Slow Reactivity Insertion Transients

It was postulated that all control rods are withdrawn from the core with the nominal control rod drive speed (~0.21 cm/s) while the pumps are in operation. This slow reactivity insertion due to inadvertent control rod withdrawal may occur during reactor startup. Cases were analyzed for reactor powers in the startup range (~1 W) and in the power range (~10MW).

The specific assumptions for the ramp rates, trip settings, and time delays before shutdown reactivity insertion were slightly different in Appendices A-1 and A-2. For example, in Appendix A-1, the ramp reactivity insertion rates were assumed to be 0.189 \$/s in the HEU case and 0.198 \$/s in the LEU case. In Appendix A-2, the corresponding ramp rates were computed to be 0.16 \$/s in the HEU core and 0.14 \$/s in the LEU core. However, the conclusions in both Appendices are the same.

In Appendix A-1, the peak temperatures reached at the surface of the cladding were 130°C in the HEU core and 158°C in the LEU core if the inadvertent control rod withdrawal were to occur in the power range (see Table 2.2). In Appendix A-2, the corresponding values were 102°C and 101°C in the HEU and LEU cases, respectively. All of these values are far below the temperature needed to initiate melting of the cladding.

#### Fast Reactivity Insertion Transient

In Appendix A-2, results are also provided for the fast reactivity insertions necessary to initiate melting of the cladding. No initiating mechanisms for the reactivity insertions are postulated. Validation of the PARET code and the methods used can be found in Chapter 7 and Appendix G-1, where calculations are compared with measurements in the

TABLE 2.2. CONTROL ROD WITHDRAWAL ACCIDENT (POWER RANGE)

FUEL	HEU	LEU
Reactivity Insertion Rate, $\$/s$	0.189	0.198
Initial Power, MW	10.0	10.0
Trip Point, MW	11.5 (0.775)*	11.5 (0.765)
Flow Rate, $m^3/h$	1000.0	1000.0
Time Delay, s	0.2	0.2
Peak Power, MW	11.93 (0.975)	11.81 (0.965)
Time of Peak Power, Ws	$1.065 \cdot 10^7$	$1.051 \cdot 10^7$
Total Energy Release Beyond 11.5 MW, Ws	$2.338 \cdot 10^6$	$2.319 \cdot 10^6$
Peak Fuel Temperature, $^{\circ}C$	133.3 (0.975)	130.5 (0.965)
Peak Clad Temperature, $^{\circ}C$	130.0 (0.975)	158.4 (0.965)
Peak Outlet Temperature, $^{\circ}C$	52.9 (1.0)	52.8 (0.965)
Min. Bubble Detachment Parameter, $cm^3 K/Ws$	114.3 (0.975)	117.2 (0.965)

\* Quantities in parentheses indicate time (in seconds) at which values occur.

SPERT I series of experiments. Comparisons with the SPERT I experiments have been traditionally used in Safety Reports for research reactors in the U.S.

The calculations were done for step reactivity insertions and ramp reactivity insertions in 0.5s from a power level of 1 W with and without scram at 12 MW. A time delay of 21 ms was assumed before the shutdown reactivity insertion for the cases with scram. The results are shown in Table 2.3.

TABLE 2.3. SUMMARY OF LIMITING REACTIVITY INSERTIONS FROM A POWER LEVEL OF 1 W TO INITIATE MELTING OF 6061 ALLOY CLADDING AT A SURFACE TEMPERATURE OF  $582^{\circ}C$  FOR HEU AND LEU EQUILIBRIUM CORES

<u>Scram</u>	<u>Limiting Reactivity Insertion, <math>\\$</math></u>	
	<u>HEU</u>	<u>LEU</u>
	<u>Step Insertions, <math>\\$</math></u>	
Yes	2.3	2.9
No	2.3	2.9
	<u>Ramp Insertions, <math>\\$/0.5s</math></u>	
Yes	3.3	8.1
No	2.8	7.9

All of the limiting reactivity insertions are larger in the LEU equilibrium core because of its significant prompt Doppler coefficient and larger void coefficient. Results are also shown in Appendix A-2 for

the limiting reactivity insertions for the HEU and LEU cores as a function of the prompt neutron generation time and as a function of the thermal conductivity of the fuel meat.

### 2.2.3 HEU-to-LEU Transition Cores

Most research reactor operators are planning to convert their cores from HEU to LEU fuel by gradually replacing their HEU elements with LEU elements. Over the years, many reactors have been safely operated with numerous mixed cores composed of elements with different geometries, different fissile loadings, different enrichments, or a combination of these. The same principles and safety considerations apply to the current conversions from HEU to LEU fuel.

The most important safety parameters in plate-type reactors are the shutdown margin, the margin to onset of nucleate boiling (ONB), and the margin to onset of an excursive flow instability. Generally, ONB will occur before an excursive flow instability. The larger the difference in the fissile content of the HEU and LEU elements, the more care must be exercised.

Since the HEU elements in Appendices A-1 and A-2 contain 280 g  $^{235}\text{U}$  and the LEU elements contain either 446 g or 390 g  $^{235}\text{U}$ , nuclear power peaking will be larger in mixed cores of these elements than in the individual equilibrium cores and the thermal-hydraulic safety margins will be smaller as a result. Reactors which currently operate near the limits of their heat removal systems need to carefully examine the nuclear power peaking in mixed cores if the increase in the fissile content of the LEU replacement elements is as large as those considered here. Shutdown margins will also be smaller in both the mixed cores and in the LEU equilibrium core because the neutron spectrum is harder in the much more highly loaded LEU elements.

Before beginning the neutronics calculations, it is prudent to determine the maximum total nuclear power peaking factor that will yield an acceptable margin to ONB. Since the calculations for the mixed cores are performed sequentially, the adequacy of the margin to ONB and the limiting shutdown margin must be checked after each cycle. If one choice of LEU element positions does not satisfy the safety criteria, others must be tried until a successful solution is found.

Appendices A-1 and A-2 present detailed results for the key operational and safety parameters for each step of a gradual transition from HEU to LEU fuel. In Appendix A-1, either five or six HEU elements are replaced per cycle and the cycle length increases each cycle along with the  $^{235}\text{U}$  content of the core. The conversion from HEU to LEU fuel is completed at the beginning of the 5th cycle, i.e. after a transition phase of 351 full power days of operation.

Appendix A-2 presents transition core results based on replacement of two HEU elements per cycle. The conversion was completed at the beginning of the 14th cycle after 324 full power days of operation. Only two cycle lengths were used in this analysis. Eight of the first nine mixed cores were run using the cycle length of the HEU equilibrium core and the remaining five cycles were run using the cycle length of the LEU equilibrium core. The core was operated for a longer time during the 14th cycle in order to run down the excess reactivity to a value near that expected for the LEU equilibrium core and the maximize the burnup in two LEU elements that need to be replaced for the next cycle.

Appendices A-1 and A-2 should be consulted for detailed data. All of the safety criteria are shown to be fully satisfactory in each case.

### 2.3 ROD-TYPE FUEL

Appendix A-3 presents safety analysis results for a 10 MW TRIGA-LEU reactor which uses GA's 16-rod UZrH fuel (45 wt% U) cluster. Figures 2.2 and 2.3 show the general layouts of the core and the fuel cluster.

The 6x6 core arrangement contains 30 fuel clusters, either 4 or 5 control rods and either 1 or 2 water-filled flux traps. The coolant and reflector are light water. When fresh, each LEU fuel cluster contains 877 g  $^{235}\text{U}$  and about 0.8 wt% erbium which serves as a burnable absorber. The desired average  $^{235}\text{U}$  burnup in fuel clusters discharged from the core is >40%. New fuel clusters are introduced in to the center of the core when they are needed.

Data are provided describing the nuclear design characteristics of the core, power peaking, the prompt negative temperature coefficient, and the heat transfer analysis.

Two accident scenarios are analyzed and discussed.

#### Loss-of-Flow Accident


When the reactor is shut down from power under normal operation, the main coolant pumps will continue to be operated for a short time until the fuel temperature declines to a near-ambient value. Should the pumps fail or be shut off because of an emergency during full-power operation, the reactor would scram on a loss-of-flow signal. Experiments conducted on other force-flow-cooled TRIGA reactors show that the flow coast-down takes several seconds and then the flow reverses direction to the natural convection mode very quickly and smoothly, with essentially no interruption in the fuel temperature decay rate. Thus, the afterheat from the shut-down reactor will be removed by natural convection following pump failure or emergency shutdown. Data on a flow coastdown in a 14 MW TRIGA reactor are provided that confirm this conclusion.

#### Reactivity Accident

In this hypothetical startup accident, the entire rod bank was assumed to withdraw from the full-in position at the normal rate of 10 cm/min constant velocity until a scram occurs. A variety of conditions were also assumed that ensure that the results of the calculations are conservative. These include: (1) flow characteristics representative of natural convection flow induced by removal of accident-generated heat, (2) a fuel temperature scram at a temperature about 40°C above the normal operation temperature of 640°C, (3) a redundant power scram at 12 MW, (4) a 0.2s delay between reaching the scram point and initiation of scram rod movement, (5) the maximum-worth rod does not scram, and (6) the period scram does not operate.

The calculational results show that the peak power reaches about 11.6 MW, but that the reactivity insertion is slow enough that sizeable fuel temperatures are generated before the reactivity insertion is completed. Since the peak power does not exceed the assumed scram point, the ramp continues until the fuel temperature at the thermocouple reaches 680°C. Although there would be bulk boiling in the channel,





NOTE: ALL DIMENSIONS ARE IN CENTIMETERS

FIG. 2.2. Core arrangements and typical dimensions for 10 MW TRIGA geometry.




FIG. 2.3. General layout of 16-rod fuel cluster.

the fuel temperature remains low enough to preclude damage because a temperature scram would limit the fuel temperature to about 700°C. This is about 240°C below the fuel temperature safety limit (when fuel and clad are at the same temperature) of 940°C.

## 2.4 PROBABILISTIC METHODS FOR ACCIDENT ANALYSIS

Appendices B-1, B-2, and B-3, although not referring in any way to the differences between HEU and LEU, are presented as a guide to probabilistic safety analysis methods.

The use of Probabilistic Risk Assessment (PRA) is recommended for power reactors by several leading licensing authorities (such as the USNRC, the UKNII and some other European authorities), as a supplement to the more traditional, deterministic approaches.

There are in general no mandatory requirements for such studies, and for research reactors the use of PRA techniques (in licensing) has not been widely applied.

The demands on both applicant and licensing authority in terms of total effort and the level of skill are substantial. The decision to use PRA in the licensing process should not be made lightly, particularly when resources and previous experience are limited and perhaps only one research reactor is involved.

Even for a single research reactor, the effort required for a full PRA based treatment can be comparable to that for a major power reactor (see Appendix B-1) while the benefits may be relatively small.

Nevertheless, the value of limited application of probabilistic assessment methods at appropriate stages of design and operation can be substantial in the context of evaluating design options, design changes, and testing and maintenance strategies.

Appendix B-1 gives a brief general review of the background related to the use of PRA in design and licensing and discusses briefly the requirements for a comprehensive PRA approach to safety assessment and review for licensing purposes. For detailed guidance to these requirements and modelling methods, reference to NUREG CR-2300 is recommended.

Appendices B-2 and B-3 provide illustrative examples of how, with relatively modest effort, supplementary quantitative ideas about system performance can be generated during redesign and/or re-licensing of a reactor.

Appendix B-2 exemplifies a study which would be suitable at an early design stage, or as a brief comparative review at a later evolutionary stage of design. It demonstrates how useful feedback about the design concept of a system can be obtained.

Appendix B-3 demonstrates how a rather more detailed approach to the study of the performance of a system may be set within the general context of an overall risk-based scheme. A still more detailed analysis than that presented in this example would be required for a complete, in-depth study.

### Chapter 3

## METHODS FOR PREVENTING LOCA

A complete loss-of-coolant accident (LOCA) in some higher power reactors can result in partial melting of the fuel from decay heat and release of fission products into the reactor building. For reactors operating even at relatively low power, the consequences of a complete LOCA must be examined. Even at low powers, the loss of biological shielding from the water must be considered.

In nearly all research reactors a partial uncovering of the fuel (e.g. by leakage through horizontal beam tubes) may be possible and this must be studied separately. In some reactors operating initially at powers of a few MW, a partial LOCA could result in boiling at the immersed part of the fuel. Conduction and steam cooling may be adequate to prevent melting.

The probability of a LOCA is normally reduced to very small values by engineered safety features such as:

1. Elevation of primary pipework (in pool or pool wall) above the core.
2. Elevation of pool system pipework (in pool or pool wall) above the core.
3. Antisiphon devices.
4. Valves on reactor vessel above and below core to admit pool water for natural convection cooling.
5. Emergency spray system from water storage tanks.
6. Pool-liner continued through beam tube.
7. Beam tubes sealed and terminated outside core box walls.
8. Sealed protective covers on beam tube ends in pool walls.
9. Slide-valves in pool walls at beam tube penetrations.
10. Beam tube shutters (released automatically).
11. Passive flap valves in beam tubes.

The engineered safety features appropriate to a particular reactor are dependent on its design. In each case a careful study will be necessary for every sequence of events that could lead to a loss-of-coolant, the effect of engineered safety features, and the adequacy of any heat removal system that is required to keep the reactor in a safe state until fission product decay reduces heating to an acceptable level.

Special attention should be given to the fact that some measures taken against LOCA could, by malfunction, interrupt the coolant flow rate. From this, a meltdown on operation could result. For example, automatic butterfly valves in the main pipe need careful design of the automatic control system.

Where the features protecting against LOCA may be less satisfactory, provision of an emergency core cooling system (ECCS) should be given additional consideration. The effect of earthquakes, of a magnitude appropriate to the site geological conditions, should be considered.

New designs should make the probability of a LOCA as low as possible.

Appendix C considers the protective measures taken in several reactors of very different designs: two light water swimming-pool-type reactors (DEMOKRITOS and SAPHIR), a light water tank-type reactor (HFR-Petten), and two heavy water tank-type reactors (DIDO and PLUTO).

Appendix C-1 describes the engineered safety features against LOCA for the DEMOKRITOS reactor, which is a swimming-pool-type reactor originally operated at 1 MW, when no special features were provided against LOCA. Following uprating to 5 MW, one safety concern was a LOCA due to rupture of either a pipe of the primary cooling system or of an experimental beam tube. Several alternative methods of protection were considered, but the solution that was chosen was installation of automatic valves in the primary pipework and sealed protective covers on the beam tube ends. Further consideration is now being given to provision of an anti-syphon device (Fig. 3.1).

Appendix C-2 describes the engineered safety features against LOCA for another swimming-pool-type reactor, SAPHIR, in which the power was increased from 5 MW to 10 MW in 1983. In SAPHIR, the pipework layout is elevated above the core and an anti-syphon arrangement is provided above the core level such that a complete LOCA cannot occur (Fig. 3.2). In order to prevent a partial LOCA from a beam tube failure, three measures have been taken: each collimator is sealed by an aluminum cover, each collimator is provided with a set of shutters against radiation that can be closed by actuation of an electric motor, and a slide-valve that can be manually actuated by a hydraulic system is installed in the pool wall of each beam tube end (Fig. 3.3).

Appendix C-3 describes the protective measures taken against both a total or partial LOCA in the 45 MW Petten HFR tank-type design. The reactor core with its adjacent devices is contained in a closed vessel at low pressure which is immersed in a pool. The protective measures against a complete uncovering of the core are a high elevation and U-type design (with a vacuum break anti-syphon system) of the primary cooling pipes (Fig. 3.4). For emergency cooling, manually activated valves are provided on the reactor vessel, above and below the core, to admit pool water for natural convection cooling in the event of loss of primary cooling.

In the original design, beam tubes above and below the core centerline were welded on the vessel and core box walls to prevent leakage from the vessel through the tubes. The improvements (Fig. 3.5) made to protect against partial uncovering of the core in the new vessel designed for 60 MW are: (1) the beam tube ends are not welded to the reactor vessel but are sealed and terminated at about 5 mm from the core box walls, (2) an aluminum protective cover is bolted at the external pool wall side of each beam tube as a second barrier to leakage of pool water through the tube, and (3) the beam tube bellows are removed, thus improving the integrity of the tubes.

Appendix C-4 deals with the heavy water tank-type reactors DIDO and PLUTO. The original spray system was replaced following power uprating from 10 MW to 25 MW. Probabilistic studies (c.f. Appendix B-3 of this Guidebook) showed that there was risk of failure of the smaller pipes of the primary system or, more serious, of the bosses where these small pipes joined the large primary pipework. The chosen solution was to isolate the primary

pipework from the reactor tank by rapidly closing powered valves. Water from the sump is then returned through a cooler to the tank, and will overflow back to the sump. An additional backup light water injection system is provided, which also gives protection against seismic events. The reactor design and the system which has been installed are illustrated in Figs. 3.6 and 3.7.




FIG. 3.1. Proposed modification of the DEMOKRITOS reactor to incorporate an anti-siphon device to the existing system.




FIG. 3.2. Pool longitudinal section for the SAPHIR reactor.




FIG. 3.3. Radial beam tube with shutter plug in the SAPHIR reactor.




FIG. 3.4. Cross-section through HFR Petten reactor vessel and pool walls.




FIG. 3.5. Schematic horizontal cross-section through HFR Petten reactor vessel and beam tubes: (a) original design; (b) improved design.






FIG 3 6 D<sub>2</sub>O system for the DIDO and PLUTO reactors




FIG. 3 7. Diagrammatic arrangement of the emergency cooling system for the DIDO and PLUTO reactors.

## Chapter 4

### RADIOLOGICAL CONSEQUENCE ANALYSES

A common approach in Safety Reports for research and test reactors is to assume that a hypothetical accident results in the release of some portion of the inventory of radioactive materials from the fuel to the containment/reactor building and, eventually, in the release of a portion of these materials to the atmosphere. The consequences to the surrounding population are usually evaluated in terms of estimated radiological doses from the materials released. The conversion of a research reactor from a highly enriched core to one of lower enrichment will generally require a review of the impact of the conversion on these previously determined radiological consequences. In most cases this impact will be relatively small.

The main factors which should be considered in performing the radiological consequence assessment include the following:

1. Core fission product and actinide inventory.
2. Fraction of the core involved in the postulated event.
3. Fractional release from the fuel elements involved in the postulated event.
4. Reactor design features affecting the release from the fuel to the containment/building.
5. Passive chemical and physical factors within the containment/building which can influence the quantity of material available for release.
6. Containment/building design features influencing the material available for release to the atmosphere.
7. Radioactive decay factors.
8. Atmospheric dispersion factors including the effect of site topography.
9. Demography of the site surroundings.
10. Estimation of individual and population exposures and risks.

Numerous methods are available for evaluating these factors. Simple hand calculations based on fission product yield table inventories, conservative fission product fractional release data, and non-site specific atmospheric dispersion data may be adequate in many cases. However a more detailed evaluation of the above factors using a sophisticated computer code will often result in substantial reductions in the dose estimates. Table 4.1, reproduced from Appendix D-1, shows a comparison of the doses calculated by the two techniques for the generic 10 MW reactor discussed in Chapter 2 and Appendix A.

Appendix D includes radiological consequence methods and calculations relevant to conversion from a highly enriched core to lower enrichment for several different types of research reactors and according to various national practices. Practices used in the United States, the United Kingdom, Greece, Canada, and the Federal Republic of Germany are described in the appendices.

TABLE 4.1. COMPARISON OF DOSES WITH INVENTORIES FROM ORIGEN CODE VERSUS YIELD TABLES

Case	Time	Dose at 500 m Site Boundary, rem*				
		Inhalation			Whole Body	
		Bone	Lung	Thyroid	Internal (Inhalation)	External (Immersion)
100 FPD	2 h	0.1384	0.1987	4.419	1.549-02	5.305-02
ORIGEN	30 d	1.305	1.600	26.38	0.1171	0.1812
300 FPD	2 h	0.3121	0.2726	4.305	2.217-02	5.117-02
ORIGEN	30 d	3.065	2.338	25.74	0.1849	0.1770
Cumulative Yields	2 h	1.712	0.4859	4.463	5.230-02	5.730-02
Infinite	30 d	17.47	4.541	26.70	0.4943	0.2030
Cumulative Yields	2 h	0.1373	0.1999	4.463	1.567-02	5.718-02
100 d	30 d	1.309	1.632	26.70	0.1195	0.2015

\*Using peak element, 0.44342 MW, in 10 MW HEU generic reactor with a 1.0%/d leak rate and the release of 100% of Noble gases, 25% of halogens, and 1% of all other to containment.

Appendix D-1 describes a model for estimating the radiological consequences from a hypothetical accident in HEU and LEU fuelled research and test reactors based on U.S. Nuclear Regulatory Commission requirements. The method incorporates fission product inventories and dose conversion data to calculate doses. The model accounts for containment/building leakage, decay of fission products, and the dispersion of airborne material by diffusion factors based on release height, wind velocity, atmospheric stability, and diffusion parameters.

This analysis shows that the LEU fuel gives essentially the same doses as HEU fuel. Table 4.2 gives a comparison of doses for LEU and HEU fuel for the generic 10 MW reactor at a 500 m site boundary. The analysis also shows that the plutonium buildup in the LEU fuel does not significantly increase the radiological consequences. Table 4.3 shows the plutonium buildup within the fuel irradiation time. Figure 4.1 shows the variation in isotopic contribution to bone dose with irradiation time and burnup for LEU fuel. While the fractional contribution to bone dose from the plutonium isotopes increases with time, the bone dose is substantially below that for the thyroid.

TABLE 4.2. DOSES AT 500 m SITE BOUNDARY FOR  
10 MW GENERIC REACTOR 100 FPD PEAK ELEMENT  
WITH HEU AND LEU FUEL\*

	HEU	LEU
<u>Bone Dose, rem</u>		
2 h	1.384-1	1.504-1
30 d	1.305	1.425
<u>Lung Dose, rem</u>		
2 h	1.987-1	2.031-1
30 d	1.600	1.634
<u>Thyroid Dose, rem</u>		
2 h	4.419	4.519
30 d	26.38	26.98
<u>Whole Body (internal), rem</u>		
2 h	1.549-2	1.604-2
30 d	1.171-1	1.217-1
<u>Whole Body (external), rem</u>		
2 h	5.305-2	5.461-2
30 d	1.812-1	1.874-1
<u>Burnup, MWD</u>	44.34	45.11

\*Assuming 100% of noble gases, 25% of halogens,  
and 1% of other are available for release from  
the containment, and a leakage rate from the  
containment of 1%/day (using Regulatory Guide  
1.4 X/Q values).

TABLE 4.3. 10 MW LEU GENERIC REACTOR — PLUTONIUM BUILDUP AND DOSE

Irrad. Time, d	Atom % Burnup <sup>235</sup> U	390 g <sup>235</sup> U LEU Peak Power (0.4511 MW) Element						
		Mass, g				Dose, rem at 2 h (30 d)		
		Pu-238	Pu-239	Pu-240	Pu-241	Bone	Lung	Thyroid
100	14	—	3.61	0.18	0.02	0.150 (1.42)	0.203 (1.63)	4.52 (27.0)
200	28	0.01	6.71	0.66	0.14	0.233 (2.25)	0.250 (2.10)	4.53 (27.1)
300	41	0.04	9.19	1.36	0.46	0.319 (3.14)	0.278 (2.37)	4.48 (26.8)
400	54	0.10	11.0	2.20	1.03	0.440 (4.37)	0.300 (2.60)	4.48 (26.8)
500	66	0.23	12.3	3.802	1.84	0.613 (6.15)	0.319 (2.80)	4.43 (26.7)




FIG. 4.1. Variation in isotopic contribution to bone dose with irradiation time for LEU fuel.

Appendix D-2 describes methods used by the Safety and Reliability Directorate of the UKAEA for conducting a radiological consequence analysis. For the assessment of accidental releases of radioactive material to the atmosphere, it would be normal in the UK to use the Tirion of Weerie suites of computer codes. These contain models of all the important physical processes between the release from the containment and the dose commitment to the individual. Tirion is a Gaussian Plume constant weather code containing the following models: Release Model, Dispersion Model, Dry Deposition, Radioactive Decay, Building Wakes, Lift-Off, Plume-Rise, Plume-Breakup, Inversion Lids, Inhalation Dose, External Radiation Dose, Consequence of Absorbed Doses, Number of Casualties, and Deposited Activity.

This appendix also discusses a simpler and quicker method of obtaining public dose by the use of pre-prepared solutions to the diffusion equation plus dose conversion factors. An example of this type of simple calculation is given where a child thyroid dose of 127 mrem is calculated for a 10 Ci, 2 hour, I-131 release from a 50 m high stack at a distance of 500 m under worst weather conditions.

Appendix D-3 describes a model for calculating radiological consequences appropriate for the Democritos research reactor in Athens, Greece. The model covers all steps of the chain: Source Term, Air Concentration of Radioactivity, and Adsorbed Dose, and is purposely simple for use when additional computer codes are not available. In addition to describing simple methods for calculating the source term and the release rates for radioactive effluents, this appendix gives simple formulae for calculating the radiological dose from all relevant exposure pathways.

The pathways considered are the external whole body dose due to submersion in the exhaust air plume, the external whole body dose due to the activity deposited on the ground, the internal irradiation originating from radionuclides inhaled with the air, resulting in both critical organ and whole body doses, external beta radiation from the exhaust air plume and the internal irradiation due to consumption of contaminated food. In order to determine the total dose of the whole body or of a certain critical organ, the contributions of all relevant radionuclides via the exposure pathways have to be summed for the individual receptor.

Appendix D-4 describes some of the factors to be considered in a radiological consequence analysis for a high power Canadian Research Reactor. The methods of determining the inventory of fission products and some of the factors affecting the fission product release including the chemical behaviour of the radioiodines is considered. Atmospheric dispersion factors including meteorological conditions, stack heights, ground contours, and building wake effects are also described. Simple formulae are given for calculating whole body external doses for gamma radiation from a cloud of noble gas fission products. Correction factors are given to account for the finite size of the noble gas plume when calculating both the individual dose on the plume centreline and the dose to a population distributed below the plume centreline.

Appendix D-5 describes a fundamental calculational model, used by Interatom, Germany for the determination of the radiological effects, inside and outside a research reactor, after hypothetical accidents with release of high amounts of fission products from the core. The reference reactor for the model is a pool type (light water) reactor and conservative calculational methods are used to solve the problem. Some modifications may be necessary for other types of research reactors.

The processes modelled include: fission product inventory, transport processes and fractional release to the containment (source-term), radioactive decay and time-dependent release of radioactivity to the environment, atmospheric dispersion, near and distant field radiological exposures and integrated doses.

In Appendix D-6, GA Technologies Inc. presents methods and sample calculations for a radiological consequence analysis for U-ZrH fuel failure in a TRIGA reactor. The analysis summarizes the calculations in tabular form for four failure modes: single-rod failure in air and three 16-rod cluster failures in water using both experimentally based fission product release fractions and conservative design basis release fractions. Fission product inventories and release fractions, building release and downwind doses are described and compared to design basis dose criteria.

One of the critical parameters in any radiological consequence analysis is the assumed fractional release of fission products from the fuel to the reactor building. Several of the appendices give typical values which are used in their jurisdictions and these are summarized in Table 4.4. For noble gases, it is common to assume a release fraction of 1.0. Radioiodine release fractions used in safety analyses vary widely depending on the degree of conservatism used and the type of accident being considered. For example, it is common practice in some jurisdictions to assume an effective radioiodine release fraction of 0.25 from the portion of the fuel that has failed. On the other hand, for a release under water, most of the radioiodine will remain in the liquid phase and values ranging from  $10^{-2}$  to  $10^{-4}$  are commonly used. A similar situation exists for particulates where a release fraction of 0.01 is commonly assumed. In one case this is modified to  $10^{-5}$  due to the presence of the pool water.

TABLE 4.4. FISSION PRODUCT RELEASE FRACTIONS — FUEL TO REACTOR BUILDING  
(FRACTION OF CORE INVENTORY)

	ANL (App. D-1)	GAEC (App. D-3)	INTERATOM (App. D-5)	CA (a) (App. D-6)
Noble Gas	1.0	1.0	1.0	1.0
Radioiodines				
From Fuel to Pool			0.25	$0.25 \times 6.3 \times 10^{-4}$ (c)
From Pool to Building				
Elemental			$10^{-4}$	$10^{-2}$ (90%)
Organic			$10^{-2}$	1.0 (10%)
Total to Building				
Elemental			$2.5 \times 10^{-5}$	
Organic			$2.5 \times 10^{-3}$	
Total				0.25 (d)
	0.25 (b)	0.25		$2.725 \times 10^{-2}$ (e)
				$1.72 \times 10^{-5}$ (c)
Particulates	0.01	0.01	$10^{-5}$	

(a) Values given are fraction of gap inventory.

(b) Assumed 50% release from fuel and 50% of that available in the building.

(c) Experimental release value.

(d) Release in air.

(e) Design basis release value.

## Chapter 5

### EXAMPLES OF SAFETY REPORT AMENDMENTS

Appendix E contains several documents intended to illustrate what work has been required, or is expected to be required, in preparing a Safety Report amendment for a licensing authority in order to obtain a license for core conversion.

The documents present a spectrum of reactor types from critical facilities to research reactors with power levels between 2 MW and 70 MW. The changes which are addressed range from the testing of prototype elements, to full core replacement. One reactor required changes to associated plant as well.

In most cases, the documents are summaries indicating the work required. That for the FNR (Appendix E-3) is the actual Safety Report amendment, and that for GRR-1 (Appendix E-6) is an illustration of the format set out in this Guidebook (and also IAEA Safety Series No. 35, 1984 Edition) using GRR-1 as an example. Most of these documents describe changes which have already been approved and, in some cases, successfully implemented.

In all cases, reactor physics parameters were recalculated with the new fuel. In the case of reactors of significant thermal powers, power distributions were recalculated and the effects on thermal-hydraulic behaviour considered. Fuel material and cladding behaviour was discussed in detail, including fuel failure, reference being made to experimental investigation and fuel testing programmes. Where other significant changes had been made, their effects were also considered. In some cases the opportunity was taken to incorporate recently developed requirements into the safety analysis. In some cases it was also necessary to re-evaluate fission product inventories, fission product releases and radiological consequences.

It will be seen from the variations between the documents presented that core conversion to MEU or LEU can encompass a wide range, from changes to the fuel material only to changes to the core and some associated plant changes. The extent of the Safety Report amendments required varies from case to case over a similarly wide range.

Table 5.1 gives an overview of Appendices E-1 to E-7 in order to help the reader to find adequate examples for his individual requirements.



TABLE 5.1. CHARACTERISTICS AND CONVERSION STATUS OF REACTORS WITH EXAMPLE SAR AMENDMENTS IN APPENDIX E

Appendix	Reactor	Country	Power, MW	Fuel Conversion						Core Alteration	Design Change	Start of Operation	Comment
				From			To						
				Enr., %	Chem. Comp.	U Dens. g/cm <sup>3</sup>	Enr., %	Chem. Comp.	U Dens. g/cm <sup>3</sup>				
E-1	KUCA*	Japan	< 10 <sup>-4</sup>	93	Alloy	0.75	45	UAl <sub>x</sub>	1.7	Full	No	5/81	RERTR Demonstration
E-2	JMTRC*	Japan	< 10 <sup>-4</sup>	93	Alloy	0.75	45	UAl <sub>x</sub>	1.7	Full	No	9/83	RERTR Demonstration
E-3	FNR	USA	2	93	UAl <sub>x</sub>	0.44	20	UAl <sub>x</sub>	1.7-1.8	Full	No	12/81	RERTR Demonstration
E-4	OSIRIS	France	70	93	UAl <sub>x</sub>	1.0	7	UO <sub>2</sub>	9.5	Full	Yes	12/79	Normal Operation
E-5	DIDO PLUTO	UK	25.5	70	Alloy	0.65	20	U <sub>3</sub> O <sub>8</sub>	2.3	Full	No		Feasibility Study
E-6	GRR-1	Greece	5	93	UAl <sub>x</sub>	0.6	20	U <sub>3</sub> O <sub>8</sub>	2.2	Full	No		Example SAR
E-7	FRG-2	FRG	15	93	UAl <sub>x</sub>	0.44	45	UAl <sub>x</sub>	1.5	Partial	No	2/82	Fuel Test
							20	U <sub>3</sub> O <sub>8</sub>	3.1	Partial	No	9/83	Fuel Test
							20	U <sub>3</sub> Si <sub>2</sub>	3.7	Partial	No	4/84	Fuel Test

\* Critical facility.

## Chapter 6

### SAFETY SPECIFICATIONS

Appendix F contains two contributions dealing with determination of the power limits of a reactor facility with reduced enrichment fuel compared with highly enriched fuel.

Generally, there will be a strong incentive to retain the primary circuit without modifications. Core conversion requires an increase of uranium content which is sometimes realized not only by increasing the uranium density in the fuel meat but also by increasing the fuel meat volume (and thus the thickness of the fuel plates). The consequences of such geometrical changes have to be investigated thoroughly, whether or not any other changes are made to the primary circuit.

In Appendix F-1, a general procedure is described for determination of the new power limits.

In Appendix F-2, the consequences of core conversion are investigated in a specific reactor (HFR at Petten) for three specific types of LEU elements. LEU elements with 15, 16 and 18 relatively thick plates are compared with the 23 plate HEU elements normally used. The existing primary circuit is retained as a boundary condition.

The limiting power is determined by the bubble detachment criterion. For the cases studied, the loss in heated area (fewer plates) is more than 50% compensated by an increase in coolant velocity in the elements. This occurs because the total flow in this type of reactor is influenced only weakly by the reduced flow area of the LEU fuel elements considered.

## **ANALYTICAL VERIFICATION**

## Chapter 7

### BENCHMARK CALCULATIONS

#### 7.1 INTRODUCTION

A safety-related benchmark problem for an idealized light-water, pool-type reactor was specified in order to compare calculational methods used in various research centres and institutions. The specifications of this problem are given in Appendix G-0 and the detailed results contributed by five organizations (ANL, INTERATOM, JAERI, EIR, and JEN) are provided in Appendices G-1 through G-5. The reactor and loading specifications are identical to those of the 10 MW neutronics benchmark problem defined in IAEA-TECDOC-233 (August 1980) except for the central flux trap.

For heavy-water-moderated research reactors, a separate benchmark problem for both the neutronics and safety-related parameters was defined and a summary and the detailed results contributed by five organizations (ANL, HARWELL, AAEC, JAERI, and RISØ) were provided in IAEA-TECDOC-324 (January 1985). In the interest of completeness, selected transient calculations contributed by the AAEC for a reactor very similar to the heavy water benchmark reactor are provided in Appendix G-6.

Since the purpose of the benchmark problems is to compare calculational methods, the reactor configurations were idealized and simplified. Thus, these calculations may not correspond to realistic reactor conditions, and only limited conclusions about actual reactor performance and safety should be drawn from them, even though some results are very similar to the results of the generic studies for light water reactors and the specific studies for heavy water reactors.

The main parameters which have been calculated for the light-water reactor benchmark problem with HEU and LEU fuels are:

- Prompt neutron generation times
- Delayed neutron fractions
- Isothermal temperature and void reactivity coefficients
- Radial and local power peaking factors
- Control rod reactivity worths
- Power and temperature responses to loss of flow
- Power and temperature responses to ramp reactivity insertions

In the following sections, the main results of the calculations are summarized and compared.

## 7.2 RESULTS OF STATIC CALCULATIONS

### 7.2.1 Basic Kinetic Parameters

The results of the calculations of the basic kinetic parameters, namely prompt neutron generation time ( $\Lambda$ ) and delayed neutron fraction ( $\beta_{\text{eff}}$ ) are presented in Table 7.1.

The values show about a 23% shorter generation time  $\Lambda$  and a 3-5% lower  $\beta_{\text{eff}}$  value for the LEU case compared to the HEU case. This is mainly due to the harder neutron spectrum in the LEU case.

TABLE 7.1. BASIC KINETIC PARAMETERS

Parameter	Fuel	ANL	INTERATOM	JAERI	EIR	JEN
$\Lambda$	HEU	56.0	54.5	57.6	58.8	51.1
( $\mu\text{s}$ )	LEU	43.7	42.2	44.4	44.8	38.0
$\beta_{\text{eff}}$	HEU	0.761	0.762	0.744	0.778	0.736
(%)	LEU	0.728	0.732	0.722	0.736	0.713

### 7.2.2 Isothermal Reactivity Coefficients

Table 7.2 shows the average values of the temperature coefficients of reactivity for the HEU and LEU cases over the temperature ranges 20-38°C, 38-50°C, and 50-100°C for change of water temperature only, change of water density only, and change of fuel temperature only. Least-squares fits of the data in Appendices G-1 to G-5 were performed to obtain the values shown in Table 7.2 for those cases in which calculations were not done at the specified points. Also shown in this table is whole-core void coefficient of reactivity for a change in water density from 0.958 - 0.90 g/cm<sup>3</sup>. Figure 7.1 gives as an example the calculated isothermal reactivity differences as functions of temperature and uranium enrichment.

The dependence of these coefficients on the enrichment of the fuel are described below:

- The density component of the water reactivity coefficient increases and the temperature component decreases when changing from HEU to LEU fuel. When the water temperature and density coefficients are combined, the values for the LEU core are smaller by ~9% over the temperature range 38-50°C and smaller by ~5% over the temperature range 50-100%.

It should be mentioned that the water density coefficient is nearly linear over the density range 0.998-0.958 g/cm<sup>3</sup> (20-100°C). When plotted against temperature, the reactivity loss due to decreasing water density is non-linear because the dependence of water density on water temperature is non-linear. The data at the

TABLE 7.2. ISOTHERMAL REACTIVITY COEFFICIENTS

Effect	Fuel	ANL	INTER- ATOM	JAERI	EIR	JEN
Temperature Range: 20-38°C ( $-\Delta\rho/^\circ\text{C} \times 10^5$ )						
Water Temp. Only: $\alpha_{T_w}$	HEU	11.9	10.4	9.6	12.0	9.0
	LEU	8.2	7.9	9.6	8.5	7.1
Water Density Only: $\alpha_{D_w}$	HEU	7.1	6.8	5.7	7.3	12.0
	LEU	8.3	7.9	6.3	8.5	13.6
$\alpha_{T_w} + \alpha_{D_w}$	HEU	19.0	17.2	15.3	19.3	21.0
	LEU	16.5	15.8	15.9	17.0	20.7
Fuel Temp. Only: $\alpha_{T_f}$	HEU	0.058	0.045	0.113	0.02	0.020
	LEU	2.63	2.19	1.94	2.37	3.15
Temperature Range: 38-50°C ( $-\Delta\rho/^\circ\text{C} \times 10^5$ )						
Water Temp. Only: $\alpha_{T_w}$	HEU	11.9	10.8	10.3	11.6	8.7
	LEU	8.1	7.7	9.2	8.2	6.8
Water Density Only: $\alpha_{D_w}$	HEU	10.4	10.0	7.9	10.4	17.5
	LEU	12.3	11.2	9.7	11.7	19.6
$\alpha_{T_w} + \alpha_{D_w}$	HEU	22.3	20.8	18.2	22.0	26.2
	LEU	20.4	18.9	18.9	19.9	26.4
Fuel Temp. Only: $\alpha_{T_f}$	HEU	0.055	0.044	0.104	0.02	0.020
	LEU	2.58	2.17	1.92	2.16	3.08
Temperature Range: 50-100°C ( $-\Delta\rho/^\circ\text{C} \times 10^5$ )						
Water Temp. Only: $\alpha_{T_w}$	HEU	11.6	11.4	11.8	11.2	8.0
	LEU	7.8	7.5	8.2	7.8	6.2
Water Density Only: $\alpha_{D_w}$	HEU	15.7	14.5	12.0	15.9	26.7
	LEU	18.6	17.1	14.3	18.1	29.8
$\alpha_{T_w} + \alpha_{D_w}$	HEU	27.3	25.9	23.8	27.1	34.7
	LEU	26.4	24.6	22.5	25.9	36.0
Fuel Temp. Only: $\alpha_{T_f}$	HEU	0.034	0.042	0.087	0.02	0.019
	LEU	2.52	2.12	1.89	2.19	2.94
Water Density Range: 0.958-0.90 g/cm <sup>3</sup> ( $-\Delta\rho/\Delta\rho_w$ )						
Voids or Water Density: $\alpha_v$	HEU	0.296	0.278	0.222	0.300	0.466
	LEU	0.344	0.316	0.232	0.337	0.513
Water Density Range: 0.998-0.958 g/cm <sup>3</sup> ( $-\Delta\rho/\Delta\rho_w$ )						
	HEU	0.258	0.239	0.199	0.261	0.442
	LEU	0.305	0.280	0.237	0.299	0.490







FIG. 7.1. Isothermal reactivity feedback data corresponding to changes in water temperature only, water density only, fuel temperature only, and water void fraction only for the HEU, MEU and LEU cores.

bottom of Table 7.2 show that the water density coefficient is more negative in the LEU core than in the HEU core by about 15-20% over the density range 0.998-0.958 g/cm<sup>3</sup>.

- A safety benefit in changing from HEU to LEU fuel is the significant increase in the fuel temperature coefficient due to the Doppler effect. This coefficient is almost zero in HEU fuel. The reactivity feedback due to the Doppler effect is virtually instantaneous as the temperature of the LEU fuel meat increases, while the reactivity feedback due to increasing water temperature and decreasing water density is delayed because heat generated in the fuel meat must be first transferred to the cladding and then to the water. The Doppler component also has more weight than the water component because temperature differences from nominal conditions are generally larger in the fuel meat than in the water.
- The whole-core void coefficient is more negative by about 10-15% for LEU fuel than for the HEU fuel over the water density range 0.958-0.90 g/cm<sup>3</sup>. This increased void coefficient in the LEU case is very significant in the analyses of certain extreme hypothetical accidents.

The changes in the kinetic parameters and reactivity feedback coefficients discussed above are not meaningful by themselves, but have significance only when they are combined in the analyses of transients and operational reactivity swings. The results of these analyses are discussed in sections which follow.

### 7.2.3 Power Defect of Reactivity

For reactor operation, the power defect of reactivity (or the cold-to-hot reactivity swing) is an important parameter, defined as the total of all reactivity effects induced by bringing the reactor (at full flow) from cold zero-power conditions to normal operating conditions. That is:

$$\Delta\rho_{\text{power}} = (\alpha T_w + \alpha D_w) \overline{\Delta T_w} + \alpha T_f \overline{\Delta T_f}$$

where  $\alpha T_w$ ,  $\alpha D_w$ , and  $\alpha T_f$  are the temperature coefficients of reactivity defined in Table 7.2 and  $\Delta T_w$  and  $\Delta T_f$  are the mean temperature differences in the water and in the fuel from cold zero-power conditions to normal operating conditions. Some steady-state thermal-hydraulic data calculated for the average channel in the 10 MW benchmark core with HEU to LEU fuels are shown in Table 7.3.

TABLE 7.3. STEADY-STATE THERMAL-HYDRAULIC DATA FOR THE AVERAGE CHANNEL IN THE BENCHMARK CORE

Fuel	Inlet Temp., °C	Flow Rate, m <sup>3</sup> /h	Mean Water Temp., °C	$\overline{\Delta T_w}$ , °C	Mean Fuel Temp., °C	$\overline{\Delta T_f}$ , °C	Water Outlet Temp., °C	Peak Fuel Temp., °C
HEU	38	1000	42.5	4.5	54.7	16.7	47.1	61.7
LEU	38	1000	42.5	4.5	54.9	16.9	47.1	62.0
HEU	20	1000	24.5	4.5	39.3	19.3	29.1	47.6
HEU	20	800	25.8	5.8	43.3	23.3	31.5	53.3



For the HEU and LEU cases in Table 7.3 with an inlet temperature of 38°C and a flow rate of 1000 m<sup>3</sup>/h, the mean temperature differences between zero power and full power would be about 4.5°C in the water and about 16.8°C in the fuel meat.

Table 7.4 shows the water, fuel, and total reactivity differences between zero and full power computed using the isothermal reactivity coefficients in Table 7.2 for the temperature range 38-50°C. The difference in the power defect of reactivity between the HEU and LEU cores in this example is about 4-6 cents.

TABLE 7.4. POWER DEFECT OF REACTIVITY:  $\Delta\rho \times 10^3$   
 $\overline{\Delta T_w} = 4.5^\circ\text{C}$ ;  $\overline{\Delta T_f} = 16.8^\circ\text{C}$

Effect	Fuel	ANL	INTER- ATOM	JAERI	EIR.	JEN
Water Temp.	HEU	1.004	0.936	0.819	0.990	1.179
+ Density	LEU	0.918	0.851	0.851	0.900	1.188
Fuel Temp.	HEU	0.009	0.007	0.018	0.003	0.003
	LEU	0.433	0.365	0.323	0.363	0.517
$\Delta\rho_{\text{power}}$	HEU	1.013	0.943	0.837	0.993	1.182
	LEU	1.351	1.216	1.174	1.263	1.705
$\beta_{\text{eff}}, \%$	HEU	0.761	0.762	0.744	0.778	0.736
	LEU	0.728	0.732	0.722	0.736	0.713
$\Delta\rho_{\text{power}}, \text{¢}$	HEU	13.3	12.4	11.3	12.8	16.1
	LEU	18.6	16.6	16.3	17.2	23.9

#### 7.2.4 Power Peaking Factors

The results of the specified 2D calculations of the radial and local power peaking factors when selected fuel elements in the HEU and LEU BOC cores (with equilibrium fission product concentrations) were replaced with elements having fresh fuel are shown in Table 7.5. The radial power peaking factor is defined as the ratio of the average midplane power in a specific element to the average midplane power in the core. The local power peaking factor is defined as the ratio of the maximum midplane power to the average midplane power in the specified element that was substituted.

The parameter which is most significant in Table 7.5 is the product of the radial and local factors. For the HEU core with HEU element substitutions and the LEU core with LEU element substitutions, the limiting radial x local power peaking factors (in CFE-1 or SFE-1) calculated by each contributor are about the same in both cores, though there are some significant differences.

For an initial mixed core (one LEU element in a HEU core) the radial x local peaking factors are larger than in the HEU core by about 16-20% because the fissile content of the LEU elements is larger by a factor of 1.39.

TABLE 7.5. POWER PEAKING FACTORS

Core	Fresh Element	Element Substituted	ANL	INTER- ATOM	EIR	JEN
<u>Radial</u>						
HEU Core	HEU in	none	1.02	1.05	1.08	1.02
	HEU Core	CFE-1	1.36	1.32	1.12	1.33
		SFE-1	1.11	1.14	1.18	1.14
	LEU in	CFE-1	1.49	1.48	1.28	1.47
	HEU Core	SFE-1	1.21	1.26	1.28	1.25
	<hr/>					
LEU Core	LEU in	none	1.02	1.04	1.06	0.99
	LEU Core	CFE-1	1.31	1.26	1.10	1.29
		SFE-1	1.10	1.12	1.15	1.14
<hr/>						
<u>Local</u>						
HEU Core	HEU in	none	1.44	1.37	1.36	1.45
	HEU Core	CFE-1	1.34	1.25	1.18	1.26
		SFE-1	1.43	1.38	1.39	1.39
	LEU in	CFE-1	1.45	1.35	1.22	1.34
	HEU Core	SFE-1	1.55	1.44	1.48	1.50
	<hr/>					
LEU Core	LEU in	none	1.56	1.52	1.85	1.58
	LEU Core	CFE-1	1.33	1.24	1.12	1.24
		SFE-1	1.55	1.48	1.85	1.51
<hr/>						
<u>Radial × Local</u>						
HEU Core	HEU in	none	1.46	1.44	1.47	1.48
	HEU Core	CFE-1	1.81	1.66	1.32	1.67
		SFE-1	1.59	1.57	1.64	1.59
	LEU in	CFE-1	2.16	1.99	1.57	1.97
	HEU Core	SFE-1	1.87	1.82	1.90	1.88
	<hr/>					
LEU Core	LEU in	none	1.58	1.57	1.97	1.56
	LEU Core	CFE-1	1.75	1.56	1.23	1.60
		SFE-1	1.71	1.66	2.13	1.72

It should be noted that the local peaking factors were computed in a different manner by each of the contributors. Individual appendices should be consulted for descriptions of the methods used. In order to calculate the maximum peaking factors, care should be taken to choose a small enough mesh width and extrapolate to the peak power value or to modify computer codes to edit power densities based on flux values of the edges of mesh intervals rather than at the centers of mesh intervals. The latter approach yields peak power densities that are reasonably independent of the mesh width.

Axial power peaking due to partially withdrawn control absorbers is also of interest. In many light water moderated MTRs, the axial peaking factor is 1.30 - 1.35 with the control absorbers fully-withdrawn. Three dimensional calculations of the BOC benchmark cores with the absorbers at different bank positions show that the peak axial power density is obtained when the absorbers are 50% withdrawn and that the peak is located at a height of about 20 cm from the bottom of the active core. Axial power density profiles in SFE-1 and CFE-1 are shown in Fig. 7.2 for this case. Table 7.6 lists the peak values of the power density with the absorbers 50% withdrawn and 100% withdrawn.

TABLE 7.6. PEAK POWER DENSITIES (W/cm<sup>3</sup>) IN CFE-1 AND SFE-1 FOR HEU AND LEU BOL CORES WITH CONTROL RODS WITHDRAWN 50% AND 100%

Control Rod Position	CFE-1			SFE-1		
	HEU	LEU	LEU/HEU	HEU	LEU	LEU/HEU
50% Out	258	249	0.97	277	289	1.04
100% Out	222	218	0.98	238	252	1.06
Ratio $\frac{50\% \text{ Out}}{100\% \text{ Out}}$	1.16	1.14		1.16	1.15	

The peak power densities in all four cases are about 15% larger with the rods 50% withdrawn rather than 100% withdrawn. Thus, an axial peaking factor of 1.50 - 1.55 is appropriate in 2D calculations to account for the axial power bulge with the control absorbers 50% withdrawn.

#### 7.2.5 Control Rod Worths

The results of the calculations of control rod worths are shown in Table 7.7 for the HEU and LEU cores with fresh fuel and in Table 7.8 for the specified HEU and LEU BOC cores. An excellent agreement between the different methods is observed.

With LEU fuel, the effectiveness of the control rods (measured in \$) decreases by about 5-8% for the fresh fuel core and by about 10-15% for burned fuel in the BOC benchmark core.

The results of calculations (see Appendix G-1) with a 3D model of the HEU and LEU BOC cores with different control rod bank positions are shown in Fig. 7.3. The total reactivity worth in dollars is about 11% smaller in the LEU case, but the shape of the curves is very similar. The HEU and LEU cores would be critical with the rods withdrawn about 64% and 68% respectively.




FIG. 7.2. HEU and LEU BOL cores: CFE-1 and SFE-1 axial power densities at midplane power peak with the four control rods 50% withdrawn.

Outside of the specified benchmark problem, calculations were also done (see Appendix G-2) to compare the relative effectiveness of fork-type and oval-type absorber designs. The fork-type absorber blades consisted of AgInCd-alloy with steel cladding and the oval-type absorbers consisted of natural boron carbide ( $B_4C$ ) with a layer of cadmium. The fresh HEU fuel elements had 23 plates with a fissile content of 180 g. Models for the control fuel elements were typical of those that are used with the two absorber designs. The core was modeled as an infinite array with a repeating unit of five fuel elements and one control element. The total reactivity worth of the oval-type absorbers was computed to be 9.9%  $\delta k/k$ , an increase of about 36% in shutdown efficiency for the fork-type absorber.

TABLE 7.7. CONTROL ROD WORTHS FOR FRESH FUEL CORES ( $\Delta\rho$ )

	Absorber	ANL		INTERATOM	
		Monte Carlo %, \$	Diffusion % \$	% \$	% \$
HEU Core	Ag-In-Cd	13.43 $\pm$ 0.38 17.65 $\pm$ 0.50	13.0 17.1	13.3 17.5	
	B <sub>4</sub> C	16.82 $\pm$ 0.38 22.11 $\pm$ 0.50	17.0 22.4	17.2 22.6	
	Hf	12.70 $\pm$ 0.36 16.70 $\pm$ 0.47	12.6 16.6		
LEU Core	Ag-In-Cd	11.24 $\pm$ 0.38 15.45 $\pm$ 0.52	11.5 15.9	11.7 16.0	
	B <sub>4</sub> C	14.95 $\pm$ 0.40 20.55 $\pm$ 0.55	15.4 21.2	15.3 20.9	
	Hf	11.07 $\pm$ 0.36 15.22 $\pm$ 0.49	11.2 15.4		
Difference HEU-LEU	Ag-In-Cd	2.19 $\pm$ 0.54 2.20 $\pm$ 0.72	1.5 1.2	1.6 1.5	
	B <sub>4</sub> C	1.87 $\pm$ 0.55 1.56 $\pm$ 0.74	1.6 1.2	1.9 1.7	
	Hf	1.63 $\pm$ 0.51 1.48 $\pm$ 0.68	1.4 1.2		

TABLE 7.8. CONTROL ROD WORTHS FOR BOC CORES ( $\Delta\rho$ )

	Absorber	ANL (Diffusion)		INTERATOM		JAERI	
		% \$	% \$	% \$	% \$	% \$	% \$
HEU Core	Ag-In-Cd	17.0 22.4	16.9 22.2	17.5 23.5			
	B <sub>4</sub> C	21.7 28.6	21.3 28.0	23.1 31.0			
	Hf	16.4 21.6					
LEU Core	Ag-In-Cd	14.5 19.9	14.2 19.4	13.9 19.3			
	B <sub>4</sub> C	18.9 26.0	18.3 25.0	19.0 26.4			
	Hf	14.0 19.2					
Difference HEU-LEU	Ag-In-Cd	2.5 2.5	2.7 2.8	3.6 4.2			
	B <sub>4</sub> C	2.8 2.6	3.0 3.0	4.1 4.6			
	Hf	2.4 2.4					




FIG. 7.3. Reactivity versus rod position for HEU and LEU BOL benchmark cores.

#### 7.2.6 Decay Heat Power

Calculated values of decay heat power versus time after shutdown (see Appendix G-2) are shown in Fig. 7.4 for the HEU and LEU cores with 10 MW initial power. For short shutdown times, the deviation between the two curves is small. For long times, the deviation can be as much as 40%, but the magnitude of the decay heat power is quite small.

### 7.3 RESULTS OF TRANSIENT CALCULATIONS

Analyses of the behaviour of the HEU and LEU benchmark cores were performed for the four specified transients:

- Fast loss-of-flow transient
- Slow loss-of-flow transient
- Slow reactivity insertion transient
- Fast reactivity insertion transient




FIG. 7.4. Decay heat versus shutdown time for HEU and LEU benchmark cores.

Outside the problem specifications, calculations were also performed for the 1.5/0.5s fast reactivity insertion transient to determine (1) the sensitivity of the results to uncertainties in the kinetics parameters and thermal conductivity, and (2) the effect of removing the specified scram.

In addition, the behaviour of the HEU benchmark core for reactivity insertions leading to clad melting was compared with results for two SPERT I experimental cores (B-24/32 and D-12/25), and reactivity insertion limits for clad melting as a function of ramp duration were determined for both the HEU and LEU benchmark cores.

In the calculational models, the core was represented by two channels: one representing the average thermal-hydraulic behaviour of the core and the other representing the hottest channel. The axial source distributions in both channels were represented using a number of regions, a chopped cosine shape, and the power peaking and engineering hot channel factors that were specified.

### 7.3.1 Loss-of-flow Transients

Fast and slow loss-of-flow transients for the HEU and LEU cores were modeled with exponential flow decay and time constants of 1.0s and 25.0s, respectively. The transients were initiated from a power of 12 MW with a flow trip point at 85% nominal flow and a 200 ms time delay before beginning a shutdown reactivity insertion of  $-\$10$  in 0.5s.

The results that were obtained are compared in Tables 7.9 and 7.10. Figures 7.5 and 7.6 show typical examples of the variation with time of the fuel centerline temperature, the clad surface temperature, and the coolant outlet temperature. The results show that there are almost no differences between the HEU and LEU cases. The peak surface clad temperature is far below the melting temperature of the cladding and flow instability parameter,  $\eta$ , is much larger than its limiting value.

TABLE 7.9. FAST LOSS-OF-FLOW TRANSIENT, 1.0 s TIME CONSTANT, EXPONENTIAL DECAY, INITIAL POWER: 12 MW, FLOW TRIP POINT: 85% OF NOMINAL FLOW

	Core	ANL	INTERATOM	JAERI	JEN
Power Level at Scram, MW	HEU	11.9	11.5	11.7	11.8
	LEU	11.9	11.4	11.7	11.7
Peak Fuel Center-Line Temp., °C	HEU	89.2	91.0	99.4	94.5
	LEU	90.3	91.9	98.7	95.4
Peak Clad Surface Temp., °C	HEU	87.5	89.5	98.4	94.0
	LEU	87.5	89.3	97.1	93.9
Peak Coolant Outlet Temp., °C	HEU	60.3	56.5	58.4	59.4
	LEU	60.3	56.4	58.1	59.3
Minimum $\eta$ , cm <sup>3</sup> K/Ws	HEU	234	257		268
	LEU	235	258		262

TABLE 7.10. SLOW LOSS-OF-FLOW TRANSIENT, 25.0 s TIME CONSTANT, EXPONENTIAL DECAY, INITIAL POWER: 12 MW, FLOW TRIP POINT: 85% OF NOMINAL FLOW

	Core	ANL	INTERATOM	JAERI	JEN
Power Level at Scram, MW	HEU	11.6	11.6	11.6	11.8
	LEU	11.6	11.5	11.6	11.7
Peak Fuel Center-Line Temp., °C	HEU	85.8	87.4	97.4	91.2
	LEU	86.8	88.2	97.7	91.9
Peak Clad Surface Temp., °C	HEU	83.9	85.8	96.4	90.7
	LEU	83.7	85.5	96.1	90.3
Peak Coolant Outlet Temp., °C	HEU	58.9	55.6	57.7	58.3
	LEU	58.8	55.4	57.5	58.1
Minimum $\eta$ , cm <sup>3</sup> K/Ws	HEU	270	293		301
	LEU	271	295		304






FIG. 7.5. Transient responses of HEU and LEU benchmark cores to a fast loss-of-coolant flow with a decay time of 1.0 s.




FIG. 7.6. Transient responses of HEU and LEU benchmark cores to a slow loss-of-coolant flow with a decay time of 25.0 s.

### 7.3.2 Slow Reactivity Insertion Transient

The slow reactivity insertion transient was initiated by ramp rates of  $\$0.10/\text{s}$  in the HEU core and  $\$0.09/\text{s}$  in the LEU core starting with the reactor critical at an initial power of 1 W and full flow. The safety system trip point was 12 MW with a time delay of 25 ms before beginning a shutdown reactivity insertion of  $-\$10$  in 0.5s.

The results are listed in Table 7.11 and an example of the power profiles and the temperature profiles at the clad surface, fuel centerline, and coolant outlet are shown in Fig. 7.7. The minimum periods, peak powers, and peak temperatures in the fuel, cladding, and at the coolant outlet are in very good agreement, but there are differences among contributors in the energy release to peak power.

The HEU transient reaches the 12 MW trip point about one second earlier and has a higher peak power than the LEU case because the reactivity feedback is smaller. The LEU case has a much broader burst shape because the strong prompt feedback from the Doppler component plays a significant role. Thus, even though the peak power in the LEU case just exceeds the trip point, the energy released to the time of peak power is larger and the peak temperature at the surge of the cladding is about  $78^{\circ}\text{C}$  instead of about  $69^{\circ}\text{C}$  in the HEU case. However, both peak cladding temperatures are well below the melting temperature of the cladding. The energy released beyond 12 MW is significantly larger in the HEU case.

### 7.3.3 Fast Reactivity Insertion Transients

The fast reactivity transients were initiated by ramp insertions of  $\$1.5/0.5\text{s}$  in the HEU core and  $\$1.35/0.5\text{s}$  in the LEU core starting with the reactor critical at an initial power of 1 W and full flow. As for the slow reactivity insertion transient, the safety system trip point was 12 MW with a time delay of 25 ms before beginning a shutdown reactivity insertion of  $-\$10$  in 0.5s.

The results for the HEU and LEU cases with  $\$1.5/0.5\text{s}$  are compared in Table 7.12 and examples of the power and temperature profiles are shown in Fig. 7.8. Overall, the data are in very good agreement.

Since the LEU core has a shorter prompt neutron generation time and thus a smaller minimum period, the peak power is reached slightly earlier. The power burst for the LEU core is slightly narrower than in the HEU core, and even though the peak power is slightly higher for the LEU case, the energy release is lower. The prompt Doppler feedback from the LEU fuel does not play a significant role in these fast transients with scram.

The peak fuel centerline temperature is about  $13\text{--}16^{\circ}\text{C}$  higher in the LEU core, mainly due to the smaller specified thermal conductivity of the LEU fuel meat. The peak clad surface temperature is a few degrees higher and the peak coolant outlet temperature is about the same or a few degrees lower in the LEU case. A brief period of localized nucleate boiling was predicted for the hot channel in both cores. Overall, there are no significant differences between the HEU and LEU results for this transient.

TABLE 7.11. SLOW REACTIVITY INSERTION TRANSIENT  
Ramps of 0.10  $\$/s$  for HEU, 0.09  $\$/s$  for LEU  
Initial power: 1 W; flow rate 1000 m<sup>3</sup>/h  
Trip point: 12 MW; Time delay: 25 ms

	Core	ANL	INTERATOM	JAERI	JEN
Minimum Period, s	HEU	0.10	0.10	0.10	0.10
	LEU	0.11	0.11	0.11	0.11
Peak Power, MW	HEU	14.1	14.4	13.8	14.9
	LEU	12.4	12.2	12.4	13.0
Energy Release to Peak Power, MJ	HEU	1.74	1.53	1.75	1.63
	LEU	4.55	5.94	4.69	2.10
Peak Fuel Center- Line Temp., °C	HEU	70.6	70.5	70.5	69.9
	LEU	80.6	80.8	81.2	73.2
Peak Clad Surface Temp., °C	HEU	69.0	69.2	69.2	69.5
	LEU	77.7	78.1	78.5	71.9
Peak Coolant Outlet Temp., °C	HEU	48.1	45.2	47.7	47.5
	LEU	53.9	51.1	52.8	48.8
Energy Released Beyond 12 MW, kJ	HEU		50		76
	LEU		2		19
Minimum $\eta$ , cm <sup>3</sup> K/Ws	HEU		483		537
	LEU		374		502
(t=20 sec) P, kW	HEU	5		6	7
	LEU	15		15	9
E, MJ	HEU	2.29		2.35	2.20
	LEU	5.30		5.48	2.66




FIG. 7.7. Transient responses of the HEU and LEU benchmark cores to a slow reactivity insertion.

TABLE 7.12. FAST REACTIVITY INSERTION TRANSIENT  
Ramp of 1.5  $\beta$ /0.5 s for HEU and LEU cores  
Initial power: 1 W; Flow rate: 1000 m<sup>3</sup>/h  
Trip point: 12 MW; Time delay: 25 ms

	Core	ANL	INTERATOM	JAERI	JEN
Minimum Period, ms	HEU	15	14	15	14.5
	LEU	12	12	12	13.5
Peak Power, MW	HEU	132	135	115	133
	LEU	148	144	144	116
Energy Release to Peak Power, MJ	HEU	3.26	3.14	2.86	3.47
	LEU	2.95	2.83	2.95	2.62
Peak Fuel Center- line Temp., °C	HEU	171	173	155	167
	LEU	183	186	171	166
Peak Clad Surface Temp., °C	HEU	156	160	147	162
	LEU	157	168	149	157
Peak Coolant Outlet Temp., °C	HEU	84	71	62	109
	LEU	82	63	63	80
Minimum $\eta$ , cm <sup>3</sup> K/Ws	HEU		34		36
	LEU		46		58




FIG. 7.8. Transient responses of the HEU and LEU benchmark cores to a fast reactivity insertion.

#### 7.3.4 Sensitivity of Results to Variations in Thermal Conductivity and Kinetics Parameters

In this section, the influence of variations in the thermal conductivity of the LEU fuel meat and in some of the kinetics parameters of the HEU core is considered for the \$1.5/0.5s fast reactivity insertion transient. Detailed results provided in Appendix G-1 are shown in Table 7.13. Only the parameter indicated was changed in each case.

The thermal conductivity of the LEU fuel meat in the LEU BOC core was varied from the 0.5 W/cmK value in the benchmark specifications to a maximum of 1.5 W/cmK. As expected, the largest change occurred in the peak fuel temperature. The smallest change occurred in the peak temperature at the surface of the cladding. In changing the thermal conductivity from 0.5 to 1.5 W/cmK, for example, the peak fuel temperature decreased by 6.3% from 183°C to 172°C and the peak clad temperature increased by only 0.3%. Thus, uncertainties in the thermal conductivity would not have a significant impact on the LEU benchmark conclusions.

The effect of variations in the kinetics parameters  $\Lambda$  and  $\beta$  were addressed by changing the base values by 10% in the HEU BOC core. The magnitude of the changes in the results are larger for a 10% decrease in  $\Lambda$  than for a 10% increase in  $\Lambda$ . Since the inverse period for a super-prompt-critical step insertion is proportional to  $\beta/\Lambda$ , increasing  $\beta$  is approximately equivalent to decreasing  $\Lambda$  by the same amount.

Changing the reactivity feedback of the moderator (water temperature and density) in the HEU core by  $\pm 10\%$  changes the peak fuel temperature by  $+ 0.4\%$  and the peak temperature at the surface of the cladding by  $+ 0.2\%$ . Again, the conclusions of the benchmark studies would not be affected by these changes.

TABLE 7.13. SENSITIVITY OF RESULTS FOR THE \$1.50/0.5 s FAST REACTIVITY INSERTION TRANSIENT TO VARIATIONS IN THERMAL CONDUCTIVITY, KINETICS PARAMETERS, AND MODERATOR FEEDBACK COEFFICIENT

Parameter	BOC Core	Change in Parameter	Peak Power	Energy Release to Peak Power	Peak Fuel Temp.	Peak Clad Temp.	Peak Coolant Outlet Temp.
Relative Changes, %							
Thermal Conductivity, W/cmK	LEU	0.5+1.0	+1.0		-4.7	+0.2	+0.7
		0.5+1.5	+1.3		-6.3	+0.3	+0.9
Prompt Neutron Gen. Time	HEU	+10%	-19.0	-11.3	-5.1	-2.2	-10.3
		-10%	+27.8	+21.2	+6.6	+2.7	+13.3
$\beta_{eff}$	HEU	+10%	+24.3	+19.1	+5.7	+2.4	+11.6
Moderator Feedback Coefficient	HEU	+10%	-1.4	-1.2	-0.4	-0.2	-1.3
		-10%	+1.4	+4.2	+0.4	+0.2	+1.4

### 7.3.5 Self-Limited Transients

Although the transients specified for the benchmark cores do not include self-limiting cases, it is of interest to some reactor operators to consider cases where the specified scram is removed. Table 7.14 taken from Appendix G-1 provides a comparison of both the HEU and LEU benchmark cores for both protected and unprotected transients of \$1.50/0.5s. Differences in the prompt neutron generation time ( $\Lambda$ ) and the Doppler coefficient are largely responsible for the observed differences in the results.

In the cases with scram, the influence of the larger Doppler coefficient for the LEU core is overshadowed by the negative reactivity from the insertion of control rods. The smaller  $\Lambda$  for the LEU core yields a shorter initial period and a faster rise in power. Consequently, the LEU case with scram shows a slightly higher peak power than the HEU case. However, the peak temperatures reached at the clad surface are very similar in both cases.

In the unprotected (self-limited) transients, the influence of the large Doppler feedback in the LEU core is apparent. All of the values recorded are substantially lower for this LEU case. The larger void/density coefficient with LEU also contributes to the differences shown. The maximum clad surface temperature in all cases is substantially below the melting point of the clad.

TABLE 7.14. SELF-LIMITED TRANSIENTS: \$1.50/0.5 s CASES WITH AND WITHOUT SCRAM FOR HEU AND LEU CORES

Case		Period, ms	$\hat{P}$ , MW ( $t_m$ , s)	$E_{t_m}$ , MWs	$\hat{T}_{clad}$ , °C	
					at $t_m$	Max. ( $t$ , s)
HEU	With Specified Scram	14.5	132 (0.656)	3.26	131	156 (0.672)
	Self-limited	14.5	371 (0.667)	7.30	220	308 (0.685)
LEU	With Specified Scram	11.9	148 (0.613)	2.95	126	157 (0.628)
	Self-limited	11.9	283 (0.622)	5.56	181	263 (0.642)

#### Reactivity Coefficients and Parameters

	$\Lambda$ , $\mu$ s	$\beta_{eff}$	Coolant Temperature \$/°C	Void/density, \$/% Void	Doppler, \$/°C
HEU	55.96	7.607-3	1.537-2	0.3257	3.6-5
LEU	43.74	7.275-3	1.082-2	0.4047	3.31-3



### 7.3.6 Clad Temperature Limits Compared with SPERT I Experiments

Appendix G-1 contains a comparison of measurements and calculations for two HEU SPERT I experimental cores (B-24/32 and D-12/25) in order to validate the PARET/ANL code for transient calculations in which the temperature of the cladding reaches its melting point. The code was then used to predict the reactivity insertions (as a function of ramp duration) that would lead to clad melting in the LEU benchmark cores.

Figure 7.9 shows the measured and calculated data for the SPERT I D-12/25 core (12 plates per element, 25 elements). The D-12/25 core included destructive tests which indicated extensive plate melting for inverse periods greater than  $\sim 166 \text{ s}^{-1}$  ( $\sim \$2.36$  insertion). Also shown in Fig. 7.9 are results for the step reactivity insertion ( $\sim \$2.35$ ) that would lead to clad melting in the HEU benchmark core. The agreement with experiment is remarkably good even though the D-12/25 core and the HEU benchmark core have somewhat different characteristics. This similarity of behaviour was also noted in the diverse cores considered in the SPERT I series of experiments. The damage line in Fig. 7.9 ( $\sim 140 \text{ s}^{-1}$ ) shows the threshold for clad damage from thermal stress.




FIG. 7.9. Comparison of PARET calculations with measurements in the SPERT I D-12/25 core.

Figure 7.10 provides a comparison of the HEU and LEU benchmark cores showing the clad melting threshold for reactivity insertions over a range of ramp durations from a step to 0.75 s. The areas above the curves indicate where clad melting would be expected. Also shown in this figure is the corresponding maximum net reactivity inserted (the difference between the external reactivity inserted and the reactivity from feedback). This maximum generally occurs at the same time in the transient as the minimum period.

The curves in Fig. 7.10 show clearly that the LEU core can tolerate a larger reactivity insertion before clad melting than the HEU core. The maximum step insertion is  $\sim \$2.80$  for the LEU core compared to  $\sim \$2.35$  for the HEU core. The ramp insertions of short duration are equivalent to a step insertion since the entire ramp is inserted before the power, temperatures, and feedback have increased substantially, and




FIG. 7.10. Reactivity insertion limits for clad melting in the HEU and LEU benchmark cores.

the limiting reactivity insertion remains constant. For ramps of longer duration, the feedback reactivity limits the net reactivity and turns over the transient before the maximum of the ramp is reached. A limiting ramp rate (constant slope) is reached, and a constant maximum net reactivity is observed for each case. The limiting ramp rate for the LEU core ( $\sim 14.8$   $\$/s$ ) is more than twice that for the HEU core ( $\sim 6.4$   $\$/s$ ). The LEU core also shows an earlier transition from the limiting step portion of the curve to the limiting ramp rate range.

In order to quantify the effect of differences in the HEU and LEU feedback coefficients on the limiting reactivity insertions, the LEU case with a 0.5s ramp duration was redone first with zero Doppler coefficient and second with zero Doppler coefficient and the HEU void coefficient. The results show that about 67% of the difference between the HEU and LEU reactivity insertion limits is due to the LEU Doppler coefficient and that about 28% of the difference is due to the larger void coefficient in the LEU core. The remaining 5% difference can be attributed to differences in other parameters such as  $\Lambda$  and  $\beta_{eff}$ . The benefits of a prompt Doppler coefficient with LEU fuel are clearly demonstrated by these results.

#### 7.3.7 Self-limiting Transients in Heavy Water Moderated Research Reactors

The methods and models for reactivity transient calculations developed at the AAEC's Lucas Heights Research Laboratories, Sydney, are briefly described in Appendix G-6. They were validated for application to HIFAR by comparison with experimental transient data from the very similar SPERT II BD22/24 heavy water moderated core. Experimental and calculated transient parameters for this core are compared in Fig. 7.11.

By use of relatively minor modifications of the model, transient parameters for HIFAR under zero, low power and operating coolant flow modes were calculated and are given in Appendix G-6. It can be expected that very similar results would apply to the 10 MW benchmark reactor discussed in IAEA-TECDOC-324, because it so closely resembles HIFAR.

Although the data presented are solely for HEU fuelling, they demonstrate, particularly in Fig. 7.11, that there are validated methods of transient estimation for heavy water moderated research reactors, comparable to those available for light water moderated research reactors.




FIG. 7.11. Comparison between measured and calculated transient parameters — SPERT II BD 22/24.

## Chapter 8

### COMPARISON OF CALCULATIONS WITH MEASUREMENTS

In implementing core conversion, several institutions have completed experiments using LEU or MEU fuel to confirm the accuracy of neutronic calculations, mostly made using the methods reported in IAEA-TECDOC-233. Details of a number of such experimental programmes and their comparison with calculations are given in Appendix H.

The studies reported in Appendix H embrace both full-core conversion configurations and mixed HEU/LEU or HEU/MEU transition cores. The range of parameters examined is wide, and includes critical mass, neutron fluxes, control rod reactivity worths, fuel, void and temperature coefficients of reactivity etc.

Overall, the studies indicate a very satisfactory measure of agreement between experimental data and results calculated using the principal methods and models discussed in IAEA-TECDOC-233 and IAEA-TECDOC-324. In only a few instances was a sufficient discrepancy for some parameter found to suggest that more than some fine-tuning of the particular calculational methods and models used might be desirable.

Appendix H-1 addresses measurements made in the CEA's ISIS reactor at Saclay. A minimum compact core and a simulated OSIRIS reactor core were studied, using 'Caramel' fuel elements of 4.75, 5.62 and 7.00 wt%  $^{235}\text{U}$  enrichment. Generally good agreement between experiment and calculation was found for the parameters measured, except for some neutron fluxes which, in several experimental locations, showed discrepancies of up to some 20%.

Appendix H-2 is in seven parts. Measurements of a comprehensive range of reactor parameters in several MEU and HEU plate-type cores in the Kyoto University Critical Assembly (KUCA) are described. Some associated analyses were carried out with both the JAERI SRAC code system and the entirely independent Argonne National Laboratory (ANL) system. Very good agreement was found between experiment and the results from either code system.

Appendix H-3 compares experiment and calculation for a range of reactor parameters measured in a corresponding HEU and MEU plate-type cores in the Japan Materials Testing Reactor Critical Facility (JMTRC). The calculations were in very satisfactory agreement with the measured results.

Appendix H-4 concerns measurements made in the entirely LEU ( $\text{UAl}_x\text{-Al}$ ) plate-type core of the 2 MW Ford Nuclear Reactor (FNR) at the University of Michigan (UM). In H-4.1, experimental results are compared with the results of UM and ANL calculations. In H-4.2, the experimental data are compared with results calculated using the JAERI/SRAC code system. With the exception of some thermal flux distributions, for which significant discrepancies between measurements and calculations were found, the comparisons of experimental and calculated results showed very satisfactory agreement.

Appendix H-5 addresses full and mixed transition-core data arising from the conversion of the 30 MW Oak Ridge Reactor (ORR) from HEU to LEU ( $U_3Si_2-Al$ ) fuel. In H-5.1, primarily reactivity-related parameters and in H-5.2, flux distributions are compared with calculations using ANL codes. With the exception of shim-rod differential reactivity worths in mixed cores, for which some very large unexplained discrepancies were found, agreement between measurements and calculations was very satisfactory.

Appendix H-6 addresses reactivity and power distribution measurements, in mixed HEU/MEU & LEU plate-type cores in the ORNL Pool Critical Assembly (PCA), precursory to the full-core conversion of the 2 MW University of Michigan Ford Nuclear Reactor (FNR). Comparison of results with calculations using the ANL code system showed a pattern virtually identical to that found for the data of Appendix H-5, including the large discrepancies for some differential shim-rod worths in mixed cores.

Appendix H-7 reports the comparison of measured and calculated core reactivity changes in a 4x4 array HEU core of the EIS 'Saphir' reactor when each standard HEU fuel element was exchanged in turn with a single MEU element. Very satisfactory agreement (average C/E = 1.065) between experiment and calculation was found.

Appendix H-8 addresses reactivity and neutron flux distribution measurements made in the 10 MW Risoe DR-3 reactor during the irradiation of 3 MEU and then 3 LEU fuel elements to normal (50-60%) burnup in otherwise HEU-fuelled cores. No clear conclusions can be drawn in respect of detailed comparison of measurements and calculations, but it appears that changes in core reactivity and in general fast/thermal flux ratios as a result of the fuel substitution were satisfactorily predicted.

Appendix H-9 compares pulsed neutron measurements of the reactivity change, when one or two fuel plates of the CNEA's RA-3 HEU-fuelled reactor are replaced by cadmium plates, with calculations. Very good agreement was obtained. Control rod worths in realistic HEU and LEU core configurations for RA-3 were then calculated using the same methods and models.

Appendix H-10 compares criticality measurements and calculations for HEU and LEU cores in the CChEN reactor "La Reina". Excellent agreement was found for the HEU core, but a rather large difference ( $\sim 0.5\% \Delta k/k$ ) between measurement and calculation was found for the MEU core.

## **FUELS**

## Chapter 9

### FUEL MATERIALS DATA

Development of fuel materials, which offer the possibility of much higher uranium density than those generally used in the HEU fuelled research reactors, was a key technical component in making effective conversion of many research reactors to LEU feasible.

The very substantial development programmes mounted showed quite early that the HEU research reactor fuel materials already in use could be successfully fabricated at considerably higher uranium densities than had previously been used or considered practicable. These materials included those for plate-reactor type fuel elements (U-Al alloy and the  $UAl_x$ -Al,  $U_3O_8$ -Al dispersions) and for TRIGA reactor rods (U-ZrH<sub>x</sub>). Their suitability for reactor use was subsequently validated by extensive irradiation testing and post-irradiation examinations of sample 'coupons' (miniplates) and full size plates, rods and elements. For the plate-type fuels a maximum practicable uranium density of about  $3.1g\ U\ cm^{-3}$ , by using  $U_3O_8$ -Al dispersion material, was thus established.

Since it was recognized that still higher uranium densities would be required for effective conversion of many plate type reactors, the properties of a wide range of other possibly suitable, new dispersion-type fuels were being studied in parallel with the above programme. Of these, the dispersions of the various uranium silicides in aluminum and, in particular  $U_3Si_2$ -Al, showed greatest promise.

Although development work is continuing on  $U_3Si$ -Al and some other materials which, if successful, will allow still higher uranium densities to be achieved,  $U_3Si_2$ -Al at densities up to  $4.8g\ U\ cm^{-3}$  is already now established as a fully qualified material for routine use in research reactor fuel elements. It can be reliably produced and fabricated into fuel elements and has very satisfactory all-round properties including excellent irradiation stability. Its performance has been proven by extensive, well documented development and testing programmes, and it seems likely to become by far the most widely used fuel material for LEU plate-type fuel elements.

Appendix I provides a compilation of important information on the properties of U-Al alloy and aluminide, oxide, and silicide dispersion fuel materials (I-1). Properties of cladding and structural materials (I-2), the corrosion resistance of aluminum alloy claddings (I-3), exothermic reactions in dispersion fuels (I-4) and the structural stability of MTR fuel elements (I-5) are also extensively reported. I-6 provides information on the design, development, and qualification of LEU (8%) 'Caramel' fuel and I-7 on the development, testing, and general specifications of uranium-zirconium hydride TRIGA-LEU fuel.

Appendix I thus represents an invaluable source of data for safety assessments and the preparation of documentation for submission to licensing authorities in support of core conversion proposals.



## Chapter 10

### IRRADIATION AND POST-IRRADIATION EXAMINATION (PIE) OF DISPERSION FUELS WITH HIGH URANIUM DENSITY

Appendix J reports on the programmes, results and analysis of the irradiation testing and post irradiation examinations (PIEs) of the dispersion-type fuel materials discussed in Chapter 9 and Appendix I. It draws upon a large volume of publications arising from a major, coordinated research, development, testing and demonstration programme which extended over more than a decade in a number of countries.

Appendix J-1 reviews irradiation experiences and PIE data from several sources on  $\text{UAl}_x\text{-Al}$  and  $\text{U}_3\text{O}_8\text{-Al}$  HEU dispersion fuels.

Appendix J-1.1 addresses experiences with full-size plate-type HEU elements, of up to  $1.7 \text{ g U cm}^{-3}$  for  $\text{UAl}_x\text{-Al}$  and  $1.2 \text{ g U cm}^{-3}$  for  $\text{U}_3\text{O}_8\text{-Al}$ , accumulated in a number of USDOE research reactors over many years.

Appendix J-1.2 provides a statistical analysis of swelling and blistering data from HEU  $\text{UAl}_x\text{-Al}$  full-size elements at up to  $1.7\text{gUcm}^{-3}$  and mini-plates up to  $2.6\text{gUcm}^{-3}$ .

Appendix J-1.3 gives results of tests on full-size  $\text{UAl}_3\text{-Al}$  fuel plates with  $1.3$  and  $1.7\text{gUcm}^{-3}$  and  $\text{U}_3\text{O}_8\text{-Al}$  plates with  $1.7\text{gUcm}^{-3}$ , irradiated in the CEA's OSIRIS reactor.

Appendix J-2 summarizes some suggested basic testing and demonstration requirements that a reactor operator would regard as an essential minimum prior to acceptance of any new fuel for routine reactor operation.

Appendix J-3 reviews the philosophy and procedures adopted by the USDOE's RERTR programme for PIE of mini-plates and full-size fuel elements using LEU at high uranium densities.

Appendix J-4 provides extensive data on the irradiation and PIE of dispersion-type fuels, of many enrichments, a wide range of dispersed-phase compositions and uranium densities up to  $8\text{gUcm}^{-3}$ . The data were derived from irradiations of both mini-plates and full-size elements and include burnup performance, swelling, blister threshold temperatures, fission product release temperatures and metallurgical assessments and analyses.

The work programmes were carried out in at least seven different countries and associated with an even greater number of reactors. The diversity of irradiation conditions and laboratory procedures represented in the data may be considered an additional "added-value" in the context of its general applicability.

Appendix J-5 reviews and adds to data on the high temperature release of fission products from irradiated  $\text{U-Al}$  alloy and dispersion-type (including  $\text{UAl}_x\text{-Al}$ ,  $\text{U}_3\text{O}_8\text{-Al}$ ,  $\text{U}_3\text{Si}_2\text{-Al}$  and  $\text{U}_3\text{Si-Al}$ ) fuels. It should prove of considerable benefit in preparing revised safety assessments for conversion proposals. Users should note that corresponding information for  $\text{U-ZrH}_x$  TRIGA reactor fuel is included in Appendix I-7.1.

## Chapter 11

### EXAMPLES OF FUEL SPECIFICATIONS AND INSPECTION PROCEDURES

Manufacturing and Inspection Specifications for research reactor fuel elements have important economic implications. Unnecessary restrictive tolerances may increase manufacturing costs both directly and by raising the element rejection rate; they may also require more complex and costly inspection of equipment and procedures to ensure compliance. On the other hand, inappropriate lax specifications with respect to the fuel's intended application may allow lower production costs but result in an unsatisfactory fuel which may give rise to costly failures and reactor down-time and prejudice reactor safety. It is also true that standardization of manufacturing specifications and inspection requirements to the fullest feasible extent should result in lower overall production costs.

Appendix-K provides a very broad spectrum of information and discussion of fuel element specifications, inspection procedures and related topics. It should prove a valuable source of guidance, to intended purchasers of LEU plate-type fuel elements, in determining their specification needs.

Appendix K-1 is an important contribution towards a goal of defining generally applicable "Standard" specification and inspection requirements for LEU, dispersion-fuel, plate-type elements. It presents the interim views of an IAEA Consultants' Group comprising both reactor operators and fuel manufacturers.

The group recognized the potential of standardized specification to limit the inherent increases in fuel costs associated with LEU conversion. In the light of long term experience for HEU plate-type fuel elements, it concluded that care was required to ensure that overly restrictive requirements were not carried over and perpetuated for LEU fuel.

Recommendations are offered in respect of a number of specification topics. The final report of the Consultants' group is now available as IAEA-TECDOC-467 but changes from Appendix K-1 are only of a minor nature.

Appendices K-2 to K-8 provide detailed illustrative examples, from a number of countries, of specifications and inspection procedures for several types of fuel elements and fuel materials. Details of some associated inspection schemes are also given in some instances.

Appendix K-9 discusses methods of determining the cladding thickness of production dispersion-type fuel elements. Minimum cladding thickness is a very important acceptance criterion for such elements.

## **OPERATIONS**

## Chapter 12

### STARTUP EXPERIMENTS

Appendix L contains information related to startup procedures and experiments when a reactor facility is converted from a highly enriched uranium core to one of lower enrichment.

The startup procedures and experiments for LEU and HEU cores do not differ in principle. The experiments and measurements necessary in a particular conversion situation would depend on the following:

- The scope and results of the nuclear and thermohydraulic calculations carried out
- The scope and results of the dynamic and safety related calculations carried out
- Whether there are significant differences between the HEU and LEU core designs
- Whether operation will include mixed (HEU + LEU) cores or only a full LEU core
- Whether there are significant changes in fuel element design
- Whether there are significant changes in control rod or control systems design.

The Appendix offers some recommendations for experiments which might be considered necessary or desirable. Additional information can be found in IAEA-TECDOC-304, "Core Instrumentation and Pre-Operational Procedures for Core Conversion HEU to LEU" (1984). It should be noted further that startup programmes would normally be submitted to the appropriate regulatory authority for independent review.

## Chapter 13

### EXPERIENCE WITH MIXED AND FULL CORE OPERATION

Appendix M comprises reviews of practical core conversion experiences from several different countries and reactors. Appendices M-1 to M-4 cover operating experience with cores of mixed fuel element enrichments and/or geometries, and Appendices M-5 and M-6 relate to full core conversions to LEU and MEU respectively.

Appendix M-1 reviews experience over more than 20 years in AECL's NRX and NRU reactors, involving operation of a wide range of cores with mixed fuel element geometries, enrichments and materials.

Appendix M-2 records experience with a number of mixed-core configurations of differing MTR plate-type fuel elements in the 8 MW ASTRA reactor. Some measured reactivity and neutron flux data are given together with comparisons of calculated and experimental thermal-hydraulic parameters.

Appendix M-3 presents the results of an extensive range of reactor physics parameter measurements in the Kyoto University Critical Assembly, KUCA. Mixed HEU/MEU fuelled configurations of two, individually sub-critical, light water moderated cylindrical cores, coupled by a heavy water reflector, were studied.

Appendix M-4 presents the results of comprehensive mixed-core reactor physics measurements made through the transition phases of conversion of the 30 MW Oak Ridge Reactor, ORR, from a full HEU to a full LEU core.

Appendix M-5 compares core performance characteristics in the HEU and fully converted LEU cores of the 2 MW University of Michigan Ford Nuclear Reactor (FNR). It is concluded that no significant operational impacts resulted from the conversion.

Appendix M-6 reviews lead-in fuel element testing and critical experiments for the conversion of the Japan Materials Testing Reactor (JMTR) from HEU to MEU fuelling. Calculated and measured values of an extensive range of reactor physics parameters for the HEU and MEU full cores are presented and compared.

## Chapter 14

### TRANSPORTATION, SPENT FUEL STORAGE, AND REPROCESSING

This chapter summarizes the Appendix-N contributions on transportation of fresh and spent fuel elements, spent fuel storage, and reprocessing. This information does not directly influence the core conversion procedure. However, some considerations may influence the choice of fuel parameters such as the fuel element  $^{235}\text{U}$  loading, which, in turn, influence the licensing procedure.

Information relating to some aspects of transportation of fresh and irradiated research reactor fuel is given in Appendix N-1 and N-2 respectively.

The transportation of fresh fuel elements requires a license. The IAEA recommendations on physical protection of nuclear material are contained in INFCIRC/274 but more stringent requirements are imposed in many countries. Transport companies have developed a range of different casks, some of which are described in Appendix N-1. As fresh fuel transport poses a far less complex problem than irradiated fuel transport, the casks are relatively simple and inexpensive.

The transportation of spent fuel elements also requires a license. Since the casks are necessarily complex and very expensive, the reactor operator should carefully consider such limiting conditions as decay heat, maximum  $^{235}\text{U}$  loading, mass, etc. to optimize the economics of the transport operation. Some available casks are described in Appendix N-2. It is often economical to cut the end boxes from the fuel elements and return only the fuelled portions of the fuel element to the reprocessing plant since reprocessing charges depend on the total delivered mass of the aluminum plus uranium.

The subcriticality of spent fuel storage configurations requires reconfirmation for the new fuel. Example calculations for several storage rack configurations with various HEU and LEU  $^{235}\text{U}$  loadings are provided in Appendix N-3.

The U.S. Department of Energy (USDOE) regularly reviews its policies and pricing in respect of acceptance of spent research reactor fuel elements for reprocessing and promulgates the updated status by publication in the Federal Register. Appendix N-4 provides a typical Federal Register extract for illustrative purposes only. Users of the guidebook should always ensure that they are aware of the policies, etc. actually current at the requisite time.

**CONTENTS OF VOLUMES 2-5  
(Appendices A-N)**

**VOLUME 2: ANALYSIS  
(Appendices A-F)**

**APPENDIX A. SAFETY ANALYSES FOR GENERIC 10 MW REACTOR**

- A-1. INTERATOM: Safety analyses for the IAEA generic 10 MW reactor
- A-2. ANL: Safety analyses for HEU and LEU equilibrium cores and HEU-LEU transition core for the IAEA generic 10 MW reactor  
J.E. Matos, K.E. Freese
- A-3. GA: Typical safety analyses for UZrH fuel - 10 MW core

**APPENDIX B. SAFETY ANALYSIS - PROBABILISTIC METHODS**

- B-1. AAEC: Probabilistic methods in safety analysis and licensing  
T.J. Moss, D.B. McCulloch
- B-2. GEC: Safety analysis - Probabilistic methods  
C. Baglin
- B-3. SRD-UKAEA: Application of probabilistic analysis techniques to a typical 10 MW MTR  
F.R. Allen

**APPENDIX C. METHODS FOR PREVENTING LOCA**

- C-1. GAEC/P.L. AUAS: Engineered safety features against LOCA for the 'Democritos' reactor  
N.G. Chrysochoides, J.N. Anoussis, C.A. Mitsonias, C.N. Papastergiou
- C-2. EIR: Engineered safety features against LOCA for the SAPHIR reactor  
H. Winkler
- C-3. ECN/JRC-Petten: Engineered safety features against LOCA for the High Flux Reactor - Petten  
N.G. Chrysochoides, A. Tas
- C-4. HARWELL: ECCS used in DIDO and PLUTO  
R. Panter

**APPENDIX D. RADIOLOGICAL CONSEQUENCE ANALYSES**

- D-1. ANL: Radiological consequence analysis  
W.L. Woodruff, D.K. Warinner, J.E. Matos
- D-2. GEC/SRD-UKAEA: Radiological consequence analysis  
C. Baglin, F.R. Allen
- D-3. GAEC: Estimation of radiological doses from research reactor accidents  
J.N. Anoussis, N.G. Chrysochoides
- D-4. CRNL: Radiological consequence analysis for a high power Canadian research reactor  
D.J. Axford
- D-5. INTERATOM: Fundamental calculational model for the determination of the radiological effects, inside and outside a research reactor, after hypothetical accidents, with release of high amounts of fission products from the core
- D-6. GA: Radiological consequence analysis for UZrH fuel

## **APPENDIX E. EXAMPLES OF SAFETY REPORT AMENDMENTS**

- E-1. KURRI: Safety review of KUCA conversion from HEU to MEU fuel  
K. Kanda, Y. Nakagome, M. Hayashi
- E-2. JAERI: Safety analysis of JMTRC core conversion from HEU to MEU fuel  
R.Oyamada, T. Niibo, Y. Nagaoka
- E-3. FNR: Safety analysis - Utilization of low enrichment uranium (LEU) fuel  
in the Ford Nuclear Reactor
- E-4. CEA: Modifications required by the OSIRIS core conversion
- E-5. HARWELL: The possible use of cermet fuel in the DIDO and PLUTO  
heavy-water research reactors  
T.D.A. Kennedy
- E-6. GAEC: Core conversion effects to the safety analysis of research reactors  
J.N. Anoussis, N.G. Chrysochoides, C.N. Papastergiou
- E-7. GKSS: Summary - SAR amendments for testing prototype fuel elements in the  
FRG-2 reactor  
W. Krull

## **APPENDIX F. SAFETY SPECIFICATIONS**

- F-1. GEC/ECN: Determination of power limits for technical specifications  
C. Baglin, A. Tas
- F-2. ECN: Nominal power limits of the HFR for LEU elements with a reduced  
number of thicker fuel plates  
A. Tas



**VOLUME 3: ANALYTICAL VERIFICATION  
(Appendices G and H)**

**APPENDIX G. BENCHMARK CALCULATIONS**

- G-0. Specifications for the safety-related benchmark problem
- G-1. ANL: Safety-related benchmark calculations for MTR-type reactors with HEU, MEU and LEU fuels  
J.E. Matos, E.M. Pennington, K.E. Freese, W.L. Woodruff
- G-2. INTERATOM: Benchmark calculations
- G-3. JAERI: IAEA safety-related benchmark calculations  
Y. Naito, M. Kurosawa, Y. Komuro, R. Oyamada, Y. Nagaoka
- G-4. EIR: Safety-related benchmark calculations for MTR reactors  
H. Amato, H. Winkler, J. Zeis
- G-5. JEN: Calculations for the safety-related benchmark problem
- G-6. AAEC: Self-limiting transients in heavy water moderated reactors  
J.W. Connolly, B.V. Harrington, D.B. McCulloch

**APPENDIX H. COMPARISON OF CALCULATIONS WITH MEASUREMENTS**

- H-1. CEA: Critical experiments in the ISIS reactor with the Caramel fuel element
- H-2. Kyoto University Critical Assembly (KUCA) critical experiments using MEU fuel
  - H-2.1. KURRI: KUCA critical experiments using medium enriched uranium fuel  
K. Kanda, S. Shiroya, M. Hayashi, K. Kobayashi, Y. Nakagome, T. Shibata
  - H-2.2. KURRI/ANL: Analysis of the KUCA MEU experiments using the ANL code system  
S. Shiroya, M. Hayashi, K. Kanda, T. Shibata, W.L. Woodruff, J.E. Matos
  - H-2.3. JAERI: Analysis of KUCA MEU cores by the JAERI SRAC code system  
T. Mori, K. Tsuchihashi
  - H-2.4. KURRI: Measurements of neutron flux distributions in a medium enriched uranium core  
S. Shiroya, H. Fukui, Y. Senda, M. Hayashi, K. Kobayashi
  - H-2.5. KURRI: Effect of reducing fuel enrichment on the void reactivity
    - Part I. Experimental study  
H. Fukui, K. Mishima, S. Shiroya, M. Hayashi, K. Kanda, Y. Senda
    - Part II. Analytical study  
Y. Senda, S. Shiroya, M. Hayashi, K. Kanda
  - H-2.6. KURRI: Study on temperature coefficients of MEU and HEU cores in the KUCA  
K. Kanda, S. Shiroya, M. Mori, M. Hayashi, T. Shibata
  - H-2.7. KURRI: Study on temperature coefficient of reactivity in KUCA light-water moderated and reflected core - Effect of M/F ratio and core shape on this quantity  
K. Kanda, S. Shiroya, M. Mori, T. Shibata
- H-3. JAERI: Critical experiments of the JMTRC MEU cores: Part I  
Y. Nagaoka, K. Takeda, S. Shimakawa, S. Koike, R. Oyamada  
Critical experiments of the JMTRC MEU cores: Part II  
S. Shimakawa, Y. Nagaoka, S. Koike, K. Takeda, B. Komukai, R. Oyamada
- H-4. Comparison of calculations with measurements
  - H-4.1. FNR/ANL: Comparison of calculations with measurements in the FNR full-core LEU demonstration reactor
  - H-4.2. JAERI: Analysis of critical experiments of FNR LEU cores  
K. Arigane, K. Tsuchihashi

- H-5. Comparison of calculations with measurements in the ORR whole-core LEU demonstration reactor
  - H-5.1. ANL: Analytical support for the ORR whole-core LEU  $U_3Si_2$ -Al fuel demonstration
    - M.M. Bretscher
  - H-5.2. ANL/ORNL: Comparison of calculated and measured irradiated wire data for HEU and mixed HEU/LEU cores in the ORR
    - R.J. Cornella, M.M. Bretscher, R.W. Hobbs
- H-6. ANL/ORNL: Measurements and analysis of critical assemblies for research reactors with mixed enrichments
  - J.R. Deen, J.L. Snelgrove, R.W. Hobbs
- H-7. EIR: Comparison of calculations and measurements of MEU fuel in the SAPHIR reactor
  - H. Winkler, J. Zeis
- H-8. RISØ: Comparisons between calculated and measured flux and reactivity in HEU, MEU and LEU fuel elements in DR-3 at Risø
  - K. Haack
- H-9. CNEA: Part I. Comparison of calculations with measurements of control rod worths in the HEU RA-2 reactor;
  - A. Gómez, A. M. Lerner, J. Testoni, R. WaldmanPart II. Uses of the method of computing control rod worths in the RA-3 reactor with HEU and LEU fuels
  - A.M. Lerner, J. Testoni
- H-10. CChEN: Measurements and analysis of critical experiments in the 'La Reina' reactor using medium enrichment uranium fuel
  - J. Klein, R. Venegas, O. Mutis

VOLUME 4: FUELS  
(Appendices I-K)

APPENDIX I. FUEL MATERIALS DATA

- I-1. Properties of fuel meat materials
  - I-1.1. ANL: Selected thermal properties and uranium density relations for alloy, aluminide, oxide, and silicide fuels  
J.E. Matos, J.L. Snelgrove
  - I-1.2. ANL: Phases in U-Si alloys  
R.F. Domagala
- I-2. Properties of cladding and structural materials
  - I-2.1. CERCA: Description and qualification of some aluminum alloys used by CERCA as cladding materials
  - I-2.2. NUKEM: NUKEM cladding and structural materials
  - I-2.3. B&W: Babcock and Wilcox cladding and structural materials
- I-3. Corrosion resistance and experience with aluminum alloy claddings
  - I-3.1. ANL: Water corrosion of aluminum alloy claddings
  - I-3.2. GKSS: Point corrosion defects of FRG-2 fuel elements  
W. Krull
  - I-3.3. HARWELL: Note on UK experience relating to corrosion of MTR fuel  
R. Panter
  - I-3.4. GEC: Aluminium corrosion data  
C. Baglin
  - I-3.5. CRNL: CRNL experience with aluminum cladding corrosion  
R.D. Graham
  - I-3.6. KfA: Water and corrosion technology of light water research reactors  
H. Pieper
- I-4. Exothermic reactions
  - I-4.1. ANL/ORNL: Exothermic reactions in  $U_3O_8$  dispersion fuel
  - I-4.2. ANL: A differential thermal analysis study of  $U_3Si-Al$  and  $U_3Si_2-Al$  reactions  
R.F. Domagala, T.C. Wiencek, J.L. Snelgrove, M.I. Homa, R.R. Heinrich
  - I-4.3. KfK: Reaction behaviour of  $U_xSi_y-Al$  and  $U_6Fe-Al$  dispersions  
S. Nazaré
  - I-4.4. ATLAS: Differential thermal analysis and metallographic examinations of  $U_3Si_2$  powder and  $U_3Si_2/Al$  (38 w/o) miniplates  
P. Toft, A. Jensen
- I-5. Structural stability
  - I-5.1. ANL: Structural stability of plate-type fuel elements used in US research and test reactors
  - I-5.2. JAERI: Hydraulic tests on dummy fuel elements for JAERI reactors  
K. Tsuchihashi, T. Sato, K. Simizu, K. Kurosawa, M. Banba, S. Yamaguchi, J. Tsunoda, F. Nakayama, Y. Itabashi, H. Kanekawa, R. Oyamada, M. Saito, T. Nagamatsuya
- I-6. CEA: 'Caramel' - French LEU fuel for research reactors with emphasis on the OSIRIS experience of core conversion
- I-7. GA: Uranium-zirconium hydride TRIGA-LEU fuel
  - I-7.1. GA/ORNL: Final results from TRIGA LEU fuel post-irradiation examination and evaluation following long term irradiation testing in the ORR  
G.B. West, M.T. Simmad, G.L. Copeland

## APPENDIX J. IRRADIATION AND POST-IRRADIATION EXAMINATION (PIE) OF DISPERSION FUELS WITH HIGH URANIUM DENSITY

- J-1. Irradiation and PIE of MTR HEU dispersion fuels with uranium densities up to  $1.7 \text{ g/cm}^3$ 
  - J-1.1. ANL: PIE data for HEU (93%) aluminide and oxide fuels
  - J-1.2. KfK: A statistical evaluation of the irradiation performance of HEU-based  $\text{UAl}_x\text{-Al}$  dispersion fuels  
S. Gahlert, S. Nazaré
  - J-1.3. CEA: Irradiation experiments
- J-2. GKSS: Reliability of LEU fuel  
W. Krull
- J-3. ANL: Post-irradiation examinations of dispersion fuels with reduced enrichment  
J.L. Snelgrove
- J-4. Irradiation and PIE of test plates, rods, and full sized elements
  - J-4.1. ORNL/ANL: The Oak Ridge Research Reactor
    - J-4.1.1. Miniplate irradiations in the Oak Ridge Research Reactor
    - J-4.1.2. Full-sized element irradiations in the Oak Ridge Research Reactor
      - Part I. Irradiation performance of low-enriched uranium fuel elements  
G.L. Copeland, G.L. Hofman, J.L. Snelgrove
      - Part II. Performance of low-enriched uranium aluminide-aluminum thick-plate fuel elements in the Oak Ridge Research Reactor  
G.L. Copeland, J.L. Snelgrove
      - Part III. Examination of  $\text{U}_3\text{Si}_2\text{-Al}$  fuel elements from the Oak Ridge Research Reactor  
G.L. Copeland, G.L. Hofman, J.L. Snelgrove
  - J-4.2. CEA: LEU and MEU fuel testing in CEA reactors  
C. Baas, M. Barnier, J.P. Beylot, P. Martel, F. Merchie
  - J-4.3. ECN: Final report on the irradiation testing and post-irradiation examination of low enriched  $\text{U}_3\text{O}_8\text{-Al}$  and  $\text{UAl}_x\text{-Al}$  fuel elements by the Netherlands Energy Research Foundation (ECN)  
H. Pruimboom, E. Lijbriek, K.H. van Otterdijk, R.J. Swanenburg de Veye
  - J-4.4. GKSS: Full size element irradiations in the FRG-2  
W. Krull
  - J-4.5. CRNL: The conversion of NRU from HEU to LEU fuel  
D.F. Sears, M.D. Atfield, I.C. Kennedy
  - J-4.6. DOUNREAY: Development of low enrichment MTR fuel at Dounreay  
D. Sinclair
  - J-4.7. RISØ: Part I. Irradiation of MEU and LEU test fuel elements in DR 3  
K. Haack
    - Part II. Irradiation in DR 3 of the three Danish manufactured LEU silicide test fuel elements
- J-5. Fission product release
  - J-5.1. ANL: Fission product release from alloy, aluminide, oxide and silicide fuels  
D. Stahl, J.L. Snelgrove
  - J-5.2. KURRI/ORNL/ANL: Release of fission products from irradiated aluminide fuel at high temperatures  
T. Shibata, T. Tamai, M. Hayashi, J.C. Posey, J.L. Snelgrove
  - J-5.3. ORNL: Release of fission products from miniature fuel plates at elevated temperature  
J.C. Posey

J-5.4. JAERI: Further data of silicide fuel for the LEU conversion of JMTR

M. Saito, Y. Futamura, H. Nakata, H. Ando, F. Sakurai,  
N. Ooka, A. Sakakura, M. Ugajin, E. Shirai

#### APPENDIX K. EXAMPLES OF FUEL SPECIFICATIONS AND INSPECTION PROCEDURES

K-1. GKSS: Standardization of specifications and inspection procedures for LEU plate-type research reactor fuels

W. Krull

K-2. ANL/FNR: Fuel elements with LEU  $UAl_x$ -Al fuel for the Ford Nuclear Reactor

K-2.1. Specifications

K-2.2. Inspection scheme

K-3. RISØ: Fuel elements with LEU  $U_3O_8$ -Al fuel for the DR-3 reactor

K-3.1. Specifications

K-3.2. Inspection scheme

K-4. ANL/ORNL: Specifications for fuel plates with LEU  $U_3Si_2$ -Al fuel for the Oak Ridge Research Reactor

K-5. DOUNREAY: Notional specification for MTR fuel plates/tubes at uranium densities up to  $1.6 \text{ g/cm}^3$

B. Hickey

K-6. KURRI/CERCA: Fabrication of medium enriched uranium fuel plate for KUCA critical experiment: Design, fabrication, inspection and transportation

K. Kanda, Y. Nakagome, T. Sagane, T. Shibata

K-7. JAERI: Specifications for fuel elements with MEU  $UAl_x$ -Al fuel for the JMTRC reactor

R. Oyamada, Y. Yokemura, K. Takeda

K-8. CRNL: Summary of specifications for Canadian enriched U-Al pin-type fuel

R.D. Graham

K-9. NUKEM: Determination of cladding thickness in fuel plates for material test and research reactors (MTR)

T. Görgenyi, U. Huth

**VOLUME 5: OPERATIONS  
(Appendices L-N)**

**APPENDIX L. STARTUP EXPERIMENTS**

- L-1. GKSS: Startup experiments with reduced enrichment fuels  
W. Krull

**APPENDIX M. EXPERIENCE WITH MIXED AND FULL CORE OPERATION**

**Mixed cores**

- M-1. CRNL: CRNL experience with research reactor fuel conversion and mixed core operation  
R.D. Graham
- M-2. OEFZS: Experience with mixed cores in the ASTRA reactor  
J. Casta
- M-3. KURRI: HEU-MEU mixed core experiments in the KUCA  
K. Kanda, S. Shiroya, M. Hayashi, K. Kobayashi, T. Shibata
- M-4. ORNL/ANL: The transition phase of the whole-core demonstration at the Oak Ridge Research Reactor  
R.W. Hobbs, M.M. Bretscher, R.J. Cornella, J.L. Snelgrove

**Full cores**

- M-5. FNR: Operational impacts of low enrichment uranium fuel conversion on the Ford Nuclear Reactor  
R.R. Burn
- M-6. JAERI: Full core MEU fuel demonstration in the JMTR  
M. Saito, Y. Nagaoka, S. Shimakawa, F. Nakayama, R. Oyamada, Y. Okamoto

**APPENDIX N. TRANSPORTATION, SPENT FUEL STORAGE, AND REPROCESSING**

- N-1. Transportation of fresh fuel elements
- N-1.1. TN: Transportation of MTR fuel elements within the Federal Republic of Germany
- N-1.2. KURRI: Transportation of fresh fuel elements for Japanese research reactors  
K. Kanda, Y. Nakagome
- N-1.3. UKAEA: The UKAEA unirradiated fuel transport containers  
R. Panter
- N-1.4. GA: Transportation of unirradiated TRIGA-LEU fuel
- N-2. Transportation of spent fuel elements
- N-2.1. GKSS: Remarks on the transportation of spent fuel elements  
W. Krull
- N-2.2. TN: Transnuklear spent fuel shipping containers
- N-2.3. UKAEA: UKAEA's 'UNIFETCH' irradiated fuel transport containers  
R. Panter
- N-2.4. CEA: The transport of spent fuel elements of research reactors
- N-2.5. GA: Transportation of irradiated TRIGA-LEU fuel

- N-3. Spent fuel storage
  - N-3.1. ANL: Nuclear criticality assessment of LEU and HEU fuel element storage  
R.B. Pond, J.E. Matos
  - N-3.2. KURRI: Fresh fuel storage  
Y. Nakagome, K. Kanda, T. Shibata
  - N-3.3. ECN: Spent fuel storage  
E.C. Mérelle, A. Tas
- N-4. USDOE: Receipt and financial settlement provisions for nuclear research reactor fuels

## LIST OF CONTRIBUTING ORGANIZATIONS\*

Argonne National Laboratory	ANL	United States of America
Athens Univ. of Agr. Sciences - Physics Lab.	P.L. AUAS	Greece
ATLAS - Denmark A/S	ATLAS	Denmark
Australian Atomic Energy Commission	AAEC	Australia
Babcock & Wilcox	B&W	United States of America
Chalk River Nuclear Laboratories	CRNL	Canada
Comisión Chilena de Energía Nuclear	CChEN	Chile
Comisión Nacional de Energía Atómica	CNEA	Argentina
Commissariat à l'Energie Atomique	CEA	France
Compagnie Pour l'Etude et la Réalisation de Combustibles Atomiques	CERCA	France
Eidg. Institut für Reaktorforschung	EIR	Switzerland
EG&G - Idaho	EG&G	United States of America
GA Technologies Inc.	GA	United States of America
GEC Energy Systems, Ltd.	GEC	United Kingdom
GKSS-Forschungszentrum Geesthacht GmbH	GKSS	Germany
Greek Atomic Energy Commission	GAEC	Greece
Internationale Atomreaktorbau GmbH	INTERATOM	Germany
Japan Atomic Energy Research Institute	JAERI	Japan
Joint Research Centre - Petten Establishment	JRC-Petten	Netherlands
Junta de Energía Nuclear	JEN	Spain
Kernforschungszentrum Jülich	KfA	Germany
Kernforschungszentrum Karlsruhe	KfK	Germany
Kyoto University Research Reactor Institute	KURRI	Japan

---

\* The listed names are those in use when contributions were finalized and have been retained for internal consistency of the guidebook text and references. It is acknowledged that a number of the organizations listed have since been renamed.



Netherlands Energy Research Foundation	ECN	Netherlands
NUKEM GmbH	NUKEM	Germany
Oak Ridge National Laboratory	ORNL	United States of America
Oesterreichisches Forschungszentrum Seibersdorf	OeFZS	Austria
Risø National Laboratory	RISØ	Denmark
Transnuklear GmbH	TN	Germany
United Kingdom Atomic Energy Authority	UKAEA	United Kingdom
Atomic Energy Research Establishment (AERE)	HARWELL	United Kingdom
Dounreay Experimental Research Establishment (DERE)	DOUNREAY	United Kingdom
Safety and Reliability Directorate	SRD-UKAEA	United Kingdom
University of Michigan – Ford Nuclear Reactor	FNR	United States of America
U.S. Department of Energy	USDOE	United States of America

## LIST OF PARTICIPANTS

### ARGENTINA

#### CNEA

R. Racana  
D. Parkansky  
M.R. Madariaga

Comisión Nacional de Energía Atómica  
Avenida del Libertador 8250  
1429 Buenos Aires

### AUSTRALIA

#### AAEC

D.B. McCulloch

Nuclear Technology Division  
Australian Atomic Energy Commission  
Private Mailbag  
Sutherland, NSW 2232

#### PERMANENT MISSION

J. Rolland

Permanent Mission of Australia  
to the IAEA  
Mattiellistrasse 2-4/III  
A-1040 Vienna

### AUSTRIA

#### RESEARCH CENTRE SEIBERSDORF

A. Burtscher  
J. Casta

Research Centre Seibersdorf  
ASTRA Reactor Institute  
A-2444 Seibersdorf

### BELGIUM

#### CEN/SCK

A. Beekmans

CEN-SCK  
Boeretang 200  
B-2400 Mol

### CANADA

#### AEC

D.J. Axford  
P. Garvey  
P. Garrell  
F. McAuley

Atomic Energy of Canada Ltd.  
Chalk River Nuclear Laboratories  
Chalk River, Ontario

### DENMARK

#### RISØ NATIONAL LABORATORY

K. Haack  
C.F. Hoyerup

Risø National Laboratory  
Postbox 49  
DK-4000 Roskilde

## FRANCE

### CERCA

M. Joly  
J.C. Marquin  
Y. Fanjas

CERCA  
Les Berauds  
F-26104 Romans-sur-Isere

### SCSIN

M. Jackquemart

SCSIN  
99 rue de Grenell  
F-75700 Paris

### CEA-FONTENAY-AUX-ROSES

M. Lerouge

Département de Sûreté Nucléaire  
CEN-Fontenay-aux-Roses  
B.P. No. 6  
F-92260 Fontenay-aux-Roses

### CEA-GRENOBLE

M. Baas

CEA-Centre d'Etudes Nucléaires  
de Grenoble  
Service des Piles  
F-85X - 38041 Grenoble

### CEA-SACLAY

M. Barnier

CEN-Saclay  
Service des Piles  
B.P. No. 2  
F-91190 Gif-sur-Yvette

## GERMANY

### NUKEM

U. Schuett  
M. Hrovat  
H. Hassel

NUKEM GmbH  
Postfach 110080  
D-6450 Hanau 11

### INTERATOM

J. Benemann  
H. Didier  
H.J. Rögler

INTERATOM  
Friedrich-Ebert-Strasse  
D-506 Berglich Gladbach 1

### GKSS-GEESTHACHT

W. Krull

GKSS-Forschungszentrum Geesthacht  
Postfach 1160  
D-2054 Geesthacht

KFA-JUELICH

G. Thamm  
H. Kalker

Kernforschungsanlage Jülich GmbH  
Research Reactor Division  
Postfach 1913  
D-5170 Jülich 1

GESELLSCHAFT F. REAKTORSICHERHEIT

L. Franzen  
A. Kraut

Gesellschaft für Reaktorsicherheit  
Glockengasse 2  
D-5060 Köln 1

GREECE

NRC "DEMOKRITOS"

N.G. Chrysochoides

Greek Atomic Energy Commission  
N.R.C. "Demokritos"  
Aghia Paraskevi  
Athens

INDONESIA

BATAN

S. Supadi  
I. Subki

Bandung Reactor Centre  
Jalan Tamansari  
Bandung

PERMANENT MISSION

P. Suratno

Permanent Mission of Indonesia to the IAEA  
Gustav Tschermak-Gasse 5-7  
A-1180 Vienna

JAPAN

JAERI

S. Matsuura  
K. Tsuchihashi

Japan Atomic Energy Research Institute  
Tokai-mura, Naka-gun  
Ibaraki-ken

KURRI

K. Kanda

Kyoto University  
Research Reactor Institute  
Kumatori-cho Sennan-gun  
Osaka 590-04

STA

K. Sumita

Department of Nuclear Engineering  
Osaka University  
Yamadakami, Suita  
Osaka

## NETHERLANDS

### NETHERLANDS ENERGY RESEARCH CENTRE

A. Tas                                      Netherlands Energy Research Foundation  
3 Westerduinweg  
P.O. Box 1  
NL-1755 ZG Petten

### IRI DELFT

S. Van der Veen                              Reactor Operations Department  
IRI Delft  
Mekelweg 15  
NL-2600 GA Delft

## SAUDI ARABIA

### PERMANENT MISSION

K.A. Nahdi                                      Permanent Mission of Saudi Arabia  
to the IAEA  
Sieveringerstrasse 72  
A-1190 Vienna

## SPAIN

### JEN

M. Gomez-Alonzo                              Reactor Engineering Section  
Junta de Energia Nuclear  
Avda. Complutense 22  
28040 Madrid

## SWITZERLAND

### EIR

H. Winkler                                      SAPHIR Division  
Swiss Federal Institute for Reactor  
Research (EIR)  
CH-5303 Würenlingen

### GA EUROPE

H. Holm    GA Technologies Europe  
Dorfstrasse 63  
CH-8126 Zumikon-Zurich

### SWISS NUCLEAR SAFETY DEPARTMENT

B. Balmer                                      Division pour la securite des  
R. Müller                                      Installations Nucleaires  
CH-5303 Würenlingen

UNITED KINGDOM

HARWELL

R. Panter  
G. Constantine

AERE-Harwell  
Bldg. 521  
Oxfordshire OX11 0RA

SRD

F. Allen  
F. Dawson

S.R.D. - U.K.A.E.A.  
Wigshaw Lane  
Culcheth, Warrington

GEC ENERGY SYSTEMS

C. Baglin

GEC Energy Systems  
Cambridge Road, Whetstone  
Leicester LE8 3LH

USA

ANL

A. Travelli  
J. Matos

Argonne National Laboratory  
9700 South Cass Avenue  
Argonne, Illinois 60439

USNRC

H. Bernard  
R. Carter

U.S. Nuclear Regulatory Commission  
Washington, D.C. 20555

B&W

J. Freim  
J. Kelly

Naval Reactor Fuel Division  
Babcock & Wilcox  
P.O. Box 785  
Lynchburg, VA 24505

ACDA

H. Hoenig

U.S. Arms Control and Disarmament Agency  
Department of State Building  
320 21st St. N.W.  
Washington, D.C. 20451

YUGOSLAVIA

BORIS KIDRIC INSTITUTE

R. Martinc

Boris Kidric Institute of Nuclear Science  
P.O. Box 522  
Y-11001 Belgrade

**IAEA**

R.G. Muranaka  
R. Palabrica  
M. Toshikage  
J. Powers  
W. Byszewski  
N.G. Chrysochoides

IAEA  
P.O. Box 100  
A-1400 Vienna

## **LIST OF PUBLICATIONS ON INTERNATIONAL MEETINGS SINCE 1983 ON REDUCED ENRICHMENT FUEL FOR RESEARCH AND TEST REACTORS**

Proceedings of the International Meeting on Reduced Enrichment for Research and Test Reactors, 24-27 October 1983, Tokai, Japan, JAERI-M 84-073 (1984).

Proceedings of the 1984 International Meeting on Reduced Enrichment for Research and Test Reactors, Argonne, USA, 15-18 October 1984, ANL/RERTR/TM-6 (1985).

Proceedings of the International Meeting on Reduced Enrichment for Research and Test Reactors, Petten, Netherlands, 14-16 October 1985, D. Reidel Publishing Co., Dordrecht (1986).

Proceedings of the International Meeting on Reduced Enrichment for Research and Test Reactors, Gatlinburg, USA, 3-6 November 1986, ANL/RERTR/TM-9 (1987).

Proceedings of the International Meeting on Reduced Enrichment for Research and Test Reactors, Buenos Aires, Argentina, 28 September - 1 October 1987, CNEA (1990).

Proceedings of the International Meeting on Reduced Enrichment for Research and Test Reactors, San Diego, California, USA, 19-22 September 1988.

Proceedings of the International Meeting on Reduced Enrichment for Research and Test Reactors, Berlin, Germany, 10-14 September 1989, Forschungszentrum Jülich GmbH (1991).

Proceedings of the International Meeting on Reduced Enrichment for Research and Test Reactors, Newport, Rhode Island, USA, 23-27 September 1990 (to be published).

Proceedings of the International Meeting on Reduced Enrichment for Research and Test Reactors, Jakarta, Indonesia, 4-7 November 1991 (to be published).



# HOW TO ORDER IAEA PUBLICATIONS



An exclusive sales agent for IAEA publications, to whom all orders and inquiries should be addressed, has been appointed for the following countries:

CANADA  
UNITED STATES OF AMERICA UNIPUB, 4611-F Assembly Drive, Lanham, MD 20706-4391, USA

---



In the following countries IAEA publications may be purchased from the sales agents or booksellers listed or through major local booksellers. Payment can be made in local currency or with UNESCO coupons.

ARGENTINA	Comisión Nacional de Energía Atómica, Avenida del Libertador 8250, RA-1429 Buenos Aires
AUSTRALIA	Hunter Publications, 58 A Gipps Street, Collingwood, Victoria 3066
BELGIUM	Service Courrier UNESCO, 202, Avenue du Roi, B-1060 Brussels
CHILE	Comisión Chilena de Energía Nuclear, Venta de Publicaciones, Amunategui 95, Casilla 188-D, Santiago
CHINA	IAEA Publications in Chinese: China Nuclear Energy Industry Corporation, Translation Section, P.O. Box 2103, Beijing IAEA Publications other than in Chinese: China National Publications Import & Export Corporation, Deutsche Abteilung, P.O. Box 88, Beijing
CZECHOSLOVAKIA	S.N.T.L., Mikulandska 4, CS-116 86 Prague 1 Alfa, Publishers, Hurbanovo námestie 3, CS-815 89 Bratislava
FRANCE	Office International de Documentation et Librairie, 48, rue Gay-Lussac, F-75240 Paris Cedex 05
HUNGARY	Kultura, Hungarian Foreign Trading Company, P.O. Box 149, H-1389 Budapest 62
INDIA	Oxford Book and Stationery Co., 17, Park Street, Calcutta-700 016 Oxford Book and Stationery Co., Scindia House, New Delhi-110 001
ISRAEL	YOZMOT (1989) Ltd, P.O. Box 56055, Tel Aviv 61560
ITALY	Libreria Scientifica, Dott. Lucio de Biasio "aeiou", Via Meravigli 16, I-20123 Milan
JAPAN	Maruzen Company, Ltd, P.O. Box 5050, 100-31 Tokyo International
PAKISTAN	Mirza Book Agency, 65, Shahrah Quaid-e-Azam, P.O. Box 729, Lahore 3
POLAND	Ars Polona-Ruch, Centrala Handlu Zagranicznego, Krakowskie Przedmiescie 7, PL-00-068 Warsaw
ROMANIA	Illexim, P.O. Box 136-137, Bucharest
RUSSIAN FEDERATION	Mezhdunarodnaya Kniga, Smolenskaya-Sennaya 32-34, Moscow G-200
SOUTH AFRICA	Van Schaik Bookstore (Pty) Ltd, P.O. Box 724, Pretoria 0001
SPAIN	Díaz de Santos, Lagasca 95, E-28006 Madrid Díaz de Santos, Balmes 417, E-08022 Barcelona
SWEDEN	AB Fritzes Kungl. Hovbokhandel, Fredsgatan 2, P.O. Box 16356, S-103 27 Stockholm
UNITED KINGDOM	HMSO, Publications Centre, Agency Section, 51 Nine Elms Lane, London SW8 5DR
YUGOSLAVIA	Jugoslavenska Knjiga, Terazije 27, P.O. Box 36, YU-11001 Belgrade



Orders from countries where sales agents have not yet been appointed and requests for information should be addressed directly to:



Division of Publications  
International Atomic Energy Agency  
Wagramerstrasse 5, P.O. Box 100, A-1400 Vienna, Austria