

Demonstration Test Program for Long-term Dry Storage of PWR Spent Fuel

17 June 2015

S.Fukuda, The Japan Atomic Power Company

N.Irie, The Kansai Electric Power Co., Inc.

Y.Kawano, Kyusyu Electric Power Co., Inc.

K.Nishi, [J.Kishimoto](#), [Mitsubishi Heavy Industries, Ltd.](#)

Contents

1. Background

2. Demonstration Test Program

- **Organization**
- ***Test Overview and Process***
- ***Fuel Specification for Demonstration Test***
- ***Verification Method of Fuel Integrity***

3. Test Container

- ***Outline of Test Container***
- ***Manufacturing of Test Container***
- ***Heat Transfer Test Plan***
- ***Test Results and Thermal Analysis***


4. Preparation for Demonstration Test

- ***Fuel Temperature Estimated***
- ***Fuel Inspections***

5. Summary

1. Background

- ***Mutsu interim spent fuel storage facility in Japan*** is preparing for the **maximum 50-year storage** of spent fuels in dry metal casks for both transportation and storage.
- To reduce risk of radiation exposure to workers and waste materials, the facility has **no hot cell**. It is required that ***the spent fuels stored will be confirmed for their integrity indirectly by monitoring cask*** during storage, and also will be transported after the storage ***without opening the cask lid***.



2. Demonstration Test Program (1/4)

Organization

Utilities(Customer)

- The Japan Atomic Power Company
- The Kansai Electric Power Co. ,Inc.
- Kyushu Electric Power Co. ,Inc.


Contractor

- Mitsubishi Heavy Industries Ltd. (MHI)

Test Facility

- Nuclear Development Corporation (NDC)


Location of the Test Facility



2. Demonstration Test Program (2/4)

Test Overview and Process

Time Schedule of Demonstration Test for PWR Fuel Storage



2. Demonstration Test Program (3/4)

Fuel Specification for Demonstration Test


- Two spent fuel assemblies are planned to be loaded in the test container.

Fuel Specification for Demonstration Test

Fuel Type	48GWd/t	55GWd/t
	17x17	17x17
Burn-up [MWd/t]	42,800 (past record)	≤55,000 (assumption)
Cladding material	Zircalloy-4	MDA or ZIRLO
Cooling period when loaded [years]	21 (as of June, 2015)	≥10 (as of October, 2025)
Time to loading	At the middle of 2015	At the middle of 2025
Remarks	15 empty fuel rods (used for PIE)	a proper spent fuel will be prepared in the future


2. Demonstration Test Program (4/4)

Verification Method of Fuel Integrity




3. Test Container (1/5)


Outline of Test Container



Case 1



Case 2



- ✓ With outer thermal insulator
- ✓ Vacuum inside (negative pressure)

- ✓ Without outer thermal insulator
- ✓ Helium gas filled in

Size	Approx. $\Phi 5.2\text{m} \times 2.1\text{m}$
Contents	Two PWR spent fuels

3. Test Container (2/5)

Manufacturing of Test Container



1
Welding of Flange, Inner Container and Base plate




2
Installing of Inner Thermal Insulator



3
Welding of Mid-body



4
Attachment of Outer Shell with Resin Filled in



5
Gauge Test and Pressure Test



6
(Top View)
Test Container Completed




(Overview)

3. Test Container (3/5)

Heat-transfer Test Plan



- Two heat transfer tests were conducted in order to evaluate thermal performance of the test container.



3. Test Container (4/5)

Test Results and Thermal Analysis (Case 1)

- One of dummy fuels was heated electrically under the vacuum condition in the cavity to simulate the 48 GWd/t type fuel storage test.
- Thermal analysis was conducted by using ABAQUS code.
- Temperatures estimated are well agreed with the heat transfer test results.



Heat Load	513W
Cover Gas	Vacuum
Thermal Insulator	Attached



	Test	Analysis
Outer Shell	22.5 °C	25.6 °C
Dummy Fuel (48GWd/t)	206.2 °C	205.9 °C

Temperature estimation method for the 48 GWd/t type storage test was verified.

3. Test Container (5/5)

Test results and Thermal Analysis (Case 2)

- Both of dummy fuels were heated electrically under the Helium gas condition in the cavity to simulate the 48/55 GWd/t type fuels storage test.
- Thermal analysis was conducted by using FLUENT code in order to consider a convection heat transfer with Helium gas.
- Temperatures estimated are well agreed with the heat transfer test results.



Heat Load	1397W (428W / 969W)
Cover Gas	Helium Gas
Thermal Insulator	Detached

	Test	Analysis
Outer Shell	18.5 °C	19.0 °C
Dummy Fuel (48GWd/t)	186.5 °C	179.8 °C
Dummy Fuel (55GWd/t)	192.4 °C	198.6 °C


Temperature estimation method for the 48/55 GWd/t type storage test was verified.

4. Preparation for Demonstration Test (1/2)

Fuel Temperature Estimated

- Temperatures of the fuels at the beginning of each test case are estimated by using the verified temperature estimation methods.

	Case 1	Case 2	
Fuel type	48GWd/t fuel	48GWd/t fuel	55GWd/t fuel
Heat load	513W	428W	969W
Ambient temperature	10°C	10°C	10°C
Max. fuel temperature estimated	216°C	172°C	190°C




4. Preparation for Demonstration Test (2/2)

Fuel Inspections

- Before loading the 48 GWd/t type fuel into the test container, visual inspections of the fuel were carried out.
- Visual / dimensional inspections of four fuel rods extracted from the fuel were also carried out.

- ✓ No significant crack,
- ✓ No deformation
- ✓ No adhesion of foreign substances



External Surface of 48GWd/t Type Fuel

5. Summary

- ◆ Some Japanese utilities planned to conduct the demonstration test for up to 60 years to accumulate knowledge and experiences on long-term integrity of PWR spent fuel during dry storage.
- ◆ The test container was manufactured. Heat-transfer tests were carried out to evaluate a thermal performance of the test container and thermal estimation methods were established.
- ◆ Maximum fuel temperatures at the beginning of the test were estimated by using the verified temperature estimation methods.
- ◆ Visual inspections for 48GWd/t type fuel have been carried out before loading and its integrity was confirmed.
- ◆ Final licensing procedure for the test facility is being performed. The demonstration test will start at the middle of JFY2015.
- ✓ Others --- We thank Nuclear Regulation Authority (Formerly Japan Nuclear Energy Safety Organization) for incorporating in the heat-transfer tests.

Thank you for your attention.
