The IAEA desalination economic evaluation programme (DEEP)

KHAMIS, Ibrahim



Summary of Presentation

Introduction

- General structure of DEEP
- Further development
- Conclusion



Following successive general conference resolutions:

- The IAEA held its first symposium on nuclear desalination at Madrid 1968.
- The IAEA renewed its activities on nuclear desalination in 1989.
- The IAEA published a report assessed the need for desalination and the most promising desalination processes and energy sources, including nuclear systems proposed by potential suppliers in 1990.
- In 1991-92, a generic investigation was conducted on the technical approach and the comparative cost for utilising nuclear energy with various state-of-the-art desalination technologies.



- An essential outcome of the IAEA's studies was the development of a methodology for preliminary economic evaluation and comparison of various energy source options to be coupled with different seawater desalination processes.
- The methodology included cost and technical performance models of several types of nuclear and fossil energy sources as well as seawater desalination processes.



- At IAEA's request, the "Co-generation and Desalination Economic Evaluation" Spreadsheet, CDEE was developed by General Atomics under contract.
- CDEE was converted into a more user friendly software, called DEEP with the possibilities for :
 - 1- Preliminary economic evaluation of desalination by a wide range of fossil and nuclear energy sources, coupled to selected desalination technologies.
 - 2- Feasibility studies of nuclear desalination

To be used by designers and decision makers



- It is a spreadsheet tools (based on linked Microsoft Excel Spreadsheets: Case, Comparative Presentation, and Control files)
- DEEP has been widely used within the nuclear & conventional desalination community. It is now an international reference code for desalination
- Efforts have been made to expand its scope over the years.
- DEEP is oversized & in need of thorough review.
- Recent efforts have been made to "upgrade" it with contributions from the " DEEP Users Group".
- Specific changes were proposed during RCM-2 of CRP-2.



DEEP

- is not intended for precise calculation of the cost of either potable water or electricity, nor as engineering or design tool for detailed design.
- To be used to provide guidance for strategic analysis and generic studies
- DEEP is based on empirical performance and cost models which are valid for certain ranges of input parameters (in particular unit sizes of power and desalination plants, Ro feedwater temperature and salinity)

Role of thump: Analysis should be kept within 10-20%



Oarai 16-19 April 2007

2007-06-12

7

Inherent Drawbacks of DEEP

Simplified models and correlations for Power Plant Calculations

1. Inherent assumptions and limitation on the models will result in approximate results.

1. Total construction costs of the power plant are calculated in DEEP on the basis of specific construction cost which is user input value.



Oarai 16-19 April 2007

2007-06-12

Inherent Drawbacks of DEEP

Simplified models and correlations for Power Plant Calculations

- 1. Method of calculating power plant operating availability from "planned and unplanned outage rates" is based on the plant either out of service or operating continuously at full power over the rest of the year.
- 2. Calculation of net saleable power plant coupled to MED is based on the adjusted power level (to account for the steam conditions of MED)



Inherent Drawbacks of DEEP

Simplified models and correlations for Desalination Plant Calculations

- 1. Capacity of Desalination plant is made of smaller units (multiples of 12000 m3/d).
- Water plant costs are calculated on the basis of " base unit cost" with introduction of correcting factor for #s of units.
- 3. DEEP is not suitable to calculate the beneficial effect of spiral wound membrane performance characteristics in RO case, or the lower water cost for the preheated feed water.
- 4. Absence of recirculation stages in the MSF process.



Drawbacks of DEEP (corrected in DEEP-3)

1. Clear distinction between backpressure & extraction steam cases (Lost shaft work error-prone) was needed.

2. Levelized electricity cost calculation did not properly account for the penalty effect introduced by the desalination unit.

3. The "minimum maximum brine temperature" calculation was questionable.



Drawbacks of DEEP

4. The number of effects/stages was an important distillation design parameter, but was not left at the user's disposal for input.

5. The RO performance curves needed a major overhaul.

6. Many constants dispersed in the code are still unnecessarily hardwired and in need of validation.



Drawbacks of DEEP

- 7. Advanced reactor design concepts, which are relevant to nuclear desalination, are not included as built-in models.
- 8. The presentation of the user interface (input/output) does not seem to make a clear distinction between important & less-important parameters. The user is left with a false sense of program control.
- 9. The documentation is in line with the above.

10. Error checking is minimal (the user is cautioned to check for the accuracy of his input data)



Main functions of DEEP

• DEEP main calculation sheet supports both nuclear and fossil power options.

 Supports dual and single purpose power plants.

 Supports distillation processes MSF, and MED, and RO as stand alone models or hybrid systems.



Oarai 16-19 April 2007

The Various energy options considered in DEEP

Desalination is an energy-intensive process

RC	Energy source	Abbreviation	Description	Plant type
1	Nuclear	PWR	Pressurised light water reactor	Co-generation plant
2	Nuclear	PHWR	Pressurised heavy water reactor	Co-generation plant
3	Fossil – coal	SSBC	Superheated steam boiler	Co-generation plant
4	Fossil oil - gas	SSBOG	Superheated steam boiler	Co-generation plant
5	Fossil	GT	Open cycle gas turbine	Co-generation plant
6	Fossil	CC	Combined cycle	Co-generation plant
7	Nuclear	HR	Heat reactor (steam or hot water)	Heat-only plant
8	Fossil	В	Boiler (steam or hot water)	Heat-only plant
9	Nuclear	GTMHR	Gas turbine modular helium reactor	Power plant
10	Fossil	D	Diesel	Power plant
11	Nuclear	SPWR	Small PWR	Co-generation plant



The desalination processes considered in DEEP

Desalination requires LOW-TEMP steam for distillation and HIGH-PRESS pumping power for RO

Process	Abbreviation	Description
Distillation	MED	Multi-Effect Distillation
	MSF	Multi-Stage Flash
Membrane	SA-RO	Stand-Alone Reverse Osmosis
	C-RO	Contiguous Reverse Osmosis
Hybrid	MED/RO	Multi-Effect Distillation with Reverse Osmosis
	MSF/RO	Multi-Stage Flash with Reverse Osmosis



Oarai 16-19 April 2007

icrosoft Excel - DEEP3										
<u>File E</u> dit <u>V</u> iew <u>I</u> nsert F <u>o</u> rmat	<u>T</u> ools <u>D</u> ata <u>W</u> indow <u>H</u> elp <u>C</u> ASE	PRESENTATION		Type a question for help 🛛 🚽 🗕						
💕 🔒 👌 🍰 🚳 🛍 🛍 🔸	") - 🎧 🧶 Σ - ½↓ 🛄 🕢	🙄 🕴 Arial	• 10 • B I U 🖹 🖉 🔤	\$ 🗲 ோ 🔛 - 🆄 - <u>A</u>						
J15 ▼ fx										
			Show Case							
New Case	View Case	Edit Input Data	Results	Exit						
	International Atomic Energy Agency									
DEEP-3.1										
Desalination Economic Evaluation Programme										
Disclaimer: The Inter	rnational Atomic Energy Agency does	not bear any responsibili	ty for the accuracy of results obtained using	this code.						
New/Edit CP	View CP S	Show CP Results	View Directories	Help						
► M Main				<						
,,				I SCPI						

Case input form

Specify Case and Configuration Data			X
Project: My Site	Case: My Case		
Water Plant Capacity			
Total Capacity: 100000 m3/d	Feed Salinity 35000 pp:		degC
	Interest Rate 5 %	Purchased Electricity Cost 0.06	\$/kWh
Power Plant Data	Distillation Plant Data	Reverse Osmosis Plant Data	Pipeline Transport Option
Thermal Power 2000 MWt		Energy Recovery Fraction 95 %	✓ Transport cost
Net Electric Power 600 MWe		Recovery Ratio (optional) 0 %	50 Distance (kms)
FuelCost 6 \$/MWh	Heating Steam Temperature N/A deg C	Design Flux 13.6 1/(m2 h)	O Power (MWe)
Specific Construction Cost 1700 \$/kW	Specific Construction Cost N/A \$/(m3/d)	Specific Construction Cost 900 \$ / (m3/d)	1 scc (M\$/km)
- First, select a coupling configuration from the n	atrix of supported energy sources and desalination tech	nologies — Configuration Switches —	7 o&m (% of scc)
MED	MSF RO MED-RO MS	5F-RO	, , ,
C NUCLEAR STEAM TURBINE NSC+MED	NSC+MSF NSC+RO NSC+MED-RO NSC+	+MSF-RO	Carbon Tax Option
E NUCLEAR GAS TURBINE NBC+MED	NBC+MSF NBC+RO NBC+MED-RO NBC+	-MSF-RO C Backpressure	🔽 Carbon Tax
R NUCLEAR HEAT NH+MED	NH+MSF		0 CO2 emission (t/MWh)
STEAM CYCLE - COAL COAL+MED	COAL+MSF COAL+RO COAL+MED-RO COAL	+MSF-RO	50 Carbon tax(\$/t)
STEAM CYCLE - OIL OIL+MED	OIL+MSF OIL+RO OIL+MED-RO OIL+	-MSF-RO Thermal Vapor Compression	
GAS TURBINE / HRSG GT+MED	GT+MSF GT+RO GT+MED-RO GT+	MSF-RO C Yes	
	CC+MSF CC+RO CC+MED-RO CC+	MSF-RO	
FOSSIL HEAT FH+MED	FH+MSF		
R RENEWABLE HEAT RH+MED	RH+MSF Duration of an American	Backup heat source	
	RH+M5F Desalination Type: RO	•	
STAND-ALONE RO	SA-RO Power Source: NSC	•	
File Name: New NSC+RO		O.K.	Cancel
Atoms for Peace: The First Half Century	<i>I</i> V	Oarai 16-19 April 2007	2007-06-12 18

DEEP edit input data

N	🔟 Microsoft Excel - DEEP 3									×
:1	🖭 Eile Edit View Insert Format Iools Data Window Help CASE PRESENTATION Type a question for help 🚽 🗗 🗙									
ED) 📂 🗔 💪 🗐 🖪 📖 🛍 • 🔊 • I	සි 🧟 Σ		0 2	Arial	• 10 • B I U ≣ ≣ ≣	\$€		3 - A -	12
_	DistPivot - fx				<u> </u>					-
	B	С	D	E	F	G	Н		L.	
1	_	-		_					-	^
2	CASE IDENTIFICATION & BA		VFIGUR			Double-click on any green input cell to edit its valu				
3										
4	Project identification	text	Project	My Site					Close	
5	Case identification	text	Case	My Case						
6										_
7	Energy plant type	text	EnPtt	NSC		Required total desalination capacity	Hybrid	plant cap	acities	
8	Desalination plant type	text	DslpType	RO						
9	Reference coupling diagram	#	RefDiag	N/A		Required total desalination capacity	m³/d	Wc_t	100 000	
10										
11										
12		ORMAN	CE DATA	<u> </u>		DISTILLATION PLANT PERFORMANCE DATA				
13										
14	Ref. thermal power	MV∿t	Qtp	2 000						
	Ref. net electric power	Mwe	Pen	600		Seawater feed temp. (if 0, defautt of 30 is used)	°C	Tsdo	N/A	
16						Feed salinity	ppm	TDS	35 000	
	Planned outage rate		орр	0.100		GOR (if 0, value is calculated)		GORo	N/A	
	Unplanned outage rate		oup	0.110		Distillation plant modular unit size	m³/d	Wduo	N/A	
	Operating availability (if 0, value is calculated)		Appo	0.900		Condenser range	°C	DTdcr	N/A	
	Lifetime of energy plant	а	Lep	60		- · ·				-
	Energy plant contingency factor		kec	0.00		Condenser approach	°C	DTdca	N/A	-
	Construction lead time	m	Le	60		Steam temperature (if 0, value is calculated)	0C	Tomo	N/A	-
23		kg/kVV.h	CO2e	N/A		Max. brine temperature (if 0, value is calculated)	°C \√ক।	Tmbo	N/A	-
24	Site specific inlet air temp (for GT/CC cases) Condenser-to-Interm. loop approach temp.	"⊂ "⊂	Tair DTca	N/A		Thermal vaport compression option (TVC) TVC vapor entrainment ratio (if 0, default of 1 is used)	Y/N	TVC Rtvco	N/A N/A	-
	Turbine type (ExtrCon / BackPr)	C	TurType	N/A		Seawater pump head	bar	DPsd	N/A	-
	Interm. loop temperature drop	°C	DTft	N/A		Seawater pump read	Dai	Esd	N/A	-
28		•c	DT1s	N/A		Specific power use	kW(e)h/m ³	Qsdp	N/A	-
29	Intermediate loop pressure loss	bar	DPip	N/A		Planned outage rate		opd	N/A	-
30			Eip	N/A		Unplanned outage rate		oud	N/A	
31	and the second sec					Plant availability (if 0, value is calculated)		Adpo	N/A	
32										~
I .	🔸 🕨 🔪 Main 🔪 Input 🖉 Output 🏑 #P-I 🖉 #	W-I / #P-I	B&W / #V	v-I B&W /			<		>	
Rea	dy								SCRL	

DEEP result

Microsoft Excel - DEEP3										_ 7 🗙	
:12	<u>File E</u> dit <u>V</u> iew Insert F <u>o</u> rmat	e Edit View Insert Format Tools Data Window Help CASE PRESENTATION Type a question for he						stion for help	8 ×		
: n	📴 🖬 👌 🖨 🖪 🛍 🛍 •	0 - 18	δ 🥺 Σ - ϟ	📔 👔 🕜 📲 🗄 Times New Ro	man 🖵 10	- B I U			\$€ ₫	= - 3	- A - 2
Perf	Performance										
	A	В	С	D	E	F	G	Н		J	K 🗖
1	s	alts			Class			^			
1 Summary of Performance and Cost Results Close I 2 I											
3											
4											
5	Project	My Site	-		Case	My Case					
6											
7	Power Plant Data			Water Plant Data							
8	Туре	NSC		Туре	RO						
9	Ref. Thermal Power	2 000	MW	Required capacity	100 000	m ³ /d					
10	Ref. Net Electric Power	600	MW	Hybrid Dist. Capacity	N/A	m ³ /d					
11	Construction Cost	1 700	\$/kW	Dist. Construction Cost	N/A	\$/(m ³ /d)					
	FuelCost	6	\$/MWh	Maximum Brine Temp.	N/A	°C					
13	Purchased Electricity Cost	0.06	\$/kWh	Heating Steam Temp.	N/A	°C					
14	Interest Rate	5	%	Dist. Feed Temp.	N/A	°C					
15				Seawater Feed Salinity	35000.0	ppm					
	16 Configuration Switches Hybrid RO Capacity		N/A	m ³ /d							
17	Steam Source	N/A		RO Construction Cost	900	m ³ /d					
18	Intermediate Loop	Y		RO Recovery Ratio	0.00						
	TVC Option	N/A		RO Energy Recovery Fraction	0.95						
	Backup Heat	N/A		RO Design Flux	13.6	1/(m ² hour)					
21		-		RO Feed Temp.	30.0	°C					
	Water Transport	ļ									
	Distance	50	km	Carbon Tax							
	Pipeline System Construction Cost	1	M\$ / km	Specific Carbon Tax	N/A	\$/ton					
	Pumping Power	0	MWe	Specific CO2e Emission	N/A	tons / MWh					
26	O&M Cost	7	% of scc								
27											
28								Close			
29				,,							~
4 4	U	#P-I / #W	-I (#P-I B&W	/ #W-I B&W /					<		
Read	dy										SCRL
	$\langle \land \rangle$										



mprovements (some have already been made or under consideration)

DEEP 3.1 includes very simplified models for Water transport cost and Carbon Tax

1. Proper calculation of lost shaft work & levelized electricity cost.

2. Clear distinction in the code between extraction & back-pressure systems.

3. Minimum maximum brine temperature calculation are cleared out.




Improvements (some have already been made or under consideration)


4- Design parameters such as the number of effects/stages and temperature range to user input has been modified.
(Minor correction to GOR correlations)
Result: easier estimation of GOR, steam flow & its temperature/pressure conditions.



Flow chart of the overall DEEP







mprovements (some have already been made or under consideration)

5. Updated RO performance data where

- Feed is characterized by salinity, temp. & pressure.
- Permeate is characterized by flux, salinity & recovery ratio.

6. Validation of all hardwired data.

Validation of DEEP using recent operational data (power & water) is needed.



RO performance model

User: either specify, or estimate RR

Recovery ratio estimate

Product flow & quality estimate

Feed flow & pressure estimate

Pumping power requirements



Improvements (some have already been made or under consideration)

7. Upgrade & validation of built-in heat source models (nuclear & non-nuclear).

8. Consolidation of input/output sheets. Separation of important from less-important parameters where the user is given the level of control is needed.

9. Upgrade the DEEP documentation.



Conclusions

- Deep is suitable for feasibility studies of nuclear desalination (not as a design code)
- Upgrade of DEEP is a continuous process as the cost parameters of both nuclear reactors and desalination processes are changing with time (due to numerous innovations in the technologies).
- New development is made (DEEP3.1) and further ones will be made (some soon).
- More and more scientists/ engineers and researchers (including some commercial firms) from various countries are using DEEP for cost estimation of desalination plants using nuclear/ fossil energy sources. Therefore, Benchmark of DEEP is needed.
- DEEP has been and still be distributed by the IAEA free of charge. Any comments or feedback is most welcome.





New CRP on "Advances in Nuclear Power Process Heat Applications"

Big remark: *Only research Agreements will be accepted (No money)*

Info sheet is available at the Conference desk



Oarai 16-19 April 2007



