



Safety Evaluation of VHTR Cogeneration System

***Hiroyuki Sato, Tetsuo Nishihara,
Xinglong Yan, Kazuhiko Kunitomi***

Japan Atomic Energy Agency

***IAEA International Conference
on Non-electric Applications of Nuclear Power
18 April 2007 Oarai Japan***

HTTR



High temperature operation (950 °C) : 2004

IS Process




**Continuous hydrogen production
30NL/h 175hr : 2005**

2010

2030

HTTR-IS system



- **World's first demonstration of hydrogen production utilizing heat from nuclear power**
- **Hydrogen production rate : Around 1000 Nm³/h**

Commercial VHTR system



- **Hydrogen production for commercial use**
- **Economically competitive**

GTHTR300C (170MWth for H₂ plant)


for **Cogeneration of electricity and hydrogen**

- Electricity generation : 202MWe
- Hydrogen production rate : 25,000Nm³/h

GTHTR300C (370MWth for H₂ plant)


for **Hydrogen production**

- Hydrogen production rate : 52,000Nm³/h
- Electricity generation for H₂ plant






Bird's eye view of GTHTR300C



Why Non-nuclear grade IS process ?

- *Open the door to non-nuclear industries*
 - *IS process will be managed by oil and gas companies*
- *Reducing the construction costs of the IS process*
 - *Apply the chemical plant design standard to the IS process*




Non-nuclear Design for IS process

Safety philosophy for non-nuclear graded IS process

Exempt the IS process from nuclear safety system


- Operate reactor normally under all conditions of the IS process -

Non-nuclear graded IS process



- a. Mitigate thermal load disturbance originated by IS process
- b. Protect the nuclear safety components from H₂ explosion
- c. Protect central control room of reactor against toxic gas
- d. Reduce tritium concentration in 2nd helium loop and the IS process

Variation of H2 Plant Thermal Load



**Malfunction of equipments
e.g. pump, valve, control system**

Variation of thermal load

**Variation of IHX outlet He
temperature**

**Variation of turbine inlet
temperature**


**If mitigation system is not
available**

Turbine shutdown


Reactor scram


Mitigation system for controlling the turbine inlet temperature is required

Event Sequence of loss of thermal load



- CV1 : Turbine bypass flow control valve
- CV2 : Recuperator inlet temperature control valve
- CV3 : Turbine inlet temperature control valve
- V4 : Turbine bypass valve







- *Thermal-hydraulic model*
 - *Non-condensable gas model*
 - *Field equations*
Mass continuity, Momentum conservation, Energy conservation
 - *Heat transfer correlation equation*
Experimental equation, Conventional equation
- *Component model*
 - *Gas Turbine*
 - *Compressor*
 - *Control system*
- *Reactor kinetics*
 - *Point nuclear kinetic equation*
 - *Reactor kinetics data*

Dynamic Calculation (1/2)

- Loss of thermal load of H₂ Plant (170MW) in GTHT300C -




- CV1 : Turbine bypass flow control valve
- CV2 : Recuperator inlet temperature control valve
- CV3 : Turbine inlet temperature control valve
- V4 : Turbine bypass valve






Dynamic Calculation (2/2)

- Loss of Thermal Load of H₂ Plant (170MW) in GTHTR300C -



- CV1 : Turbine bypass flow control valve
- CV2 : Recuperator inlet temperature control valve
- CV3 : Turbine inlet temperature control valve
- V4 : Turbine bypass valve



Elapsed time from loss of the IS process thermal load [s]



Concluding Remarks

- *JAEA started the design study including the safety design of commercial VHTR systems GTHTR300C for cogeneration of hydrogen and electricity*
- *One of the key safety related events is to mitigate the effect of thermal load variation of hydrogen plant on the reactor system*
- *Plant dynamic calculation for loss of the H₂ plant thermal load was performed*
- *Availability of the control system was verified*

Thanks for your attention.
sato.hiroyuki09@jaea.go.jp



Back ground information



Control valve data

	<i>Diameter</i>	<i>CV value</i>	<i>Acting time</i>
<i>CV1</i>	<i>500A</i>	<i>4679</i>	<i>5.0 s</i> <i>(Including dead time 2.0s)</i>
<i>CV2</i>	<i>400A</i>	<i>1202</i>	<i>5.0 s</i> <i>(Including dead time 2.0s)</i>
<i>CV3</i>	<i>400A</i>	<i>2070</i>	<i>5.0 s</i> <i>(Including dead time 2.0s)</i>



IHX Heat transfer correlation

(Shell side)

$$Nu = C_1 Re^{0.8} Pr^{0.4} \quad (800 < Re \leq 7000)$$

$$Nu = C_2 Re^{0.6} Pr^{0.3} \quad (Re > 7000)$$

(Tube side)

$$Nu = 0.0223 Re^{(5/6)} di \frac{Pr}{Pr^{0.6} - 0.0057} \times \left(1 + \frac{0.0615}{(Re \cdot di^{2.5})^{(1/6)}} \right)$$

C_1, C_2 : Design Coefficient



Regenerative heat exchanger heat transfer correlation

$$\alpha_{\text{He}} = Nu\lambda/De$$

$$De = 2WH/(W + H)$$

$$j = 0.48 \left(\frac{X}{De} \right)^{0.16} \left(\frac{W}{H} \right)^{0.18} Re^{0.54} \quad (Re \leq 1000)$$

$$j = 0.24 \left(\frac{X}{De} \right)^{0.32} \left(\frac{t_F}{De} \right)^{0.09} Re^{0.37} \quad (Re \geq 2000)$$

U : Flow velocity

W : Flow path width of fins + fin thickness

H : Flow path height

X: Fin length

t_f : Fin thickness [m]



Pre-cooler Heat transfer correlation

(Helium side)

$$\alpha_{He} = 0.023 Re^{0.8} Pr^{0.4} \lambda / D_{in}$$

(Water side)

$$\alpha_w = J \cdot Cp G Pr^{-2/3} C_i$$

$$J = 0.292 Re^k \left(\frac{S}{D}\right)^{1.115} \left(\frac{S}{H}\right)^{0.257} \left(\frac{t_f}{S}\right)^{0.666} \left(\frac{D}{D_0}\right)^{0.473} \left(\frac{D}{t_f}\right)^{0.7717}$$

$$k = -0.415 + 0.0346 \ln\left(\frac{D}{S}\right)$$

D_{in} : Tube inner diameter [m]

D_o : Tube outer diameter [m]

C_p : Specific heat [kJ/kg K]

C_i : Correction coefficient

S : Clearance between fins [m]

D : Fin outer diameter [m]

H : Fin height [m]

t_f : Fin thickness [m]

G : Tube outer mass velocity [kg/s m²]

Turbine model

(Rotational speed)

$$\sum I_i \frac{d\omega}{dt} = \sum T_i - \sum F_i \omega$$

(Pressure ratio & Turbine Efficiency)

$$\eta_t = f\left(\frac{U}{C_0}\right)$$

$$U = \frac{\pi D_m N}{60}$$

$$C_0 = \sqrt{2g \frac{K}{K-1} R T_i \left(1 - \pi_T^{\frac{1-K}{K}}\right) / Z}$$

$$\Phi = 0.208 \left(\frac{U}{C_0}\right)^{-1.25}$$

$$\frac{G \sqrt{T_i}}{P_i} = \Phi \frac{N}{\sqrt{T_i}} \frac{\pi D_m}{60} A_m \frac{1}{R}$$

I : Inertia [kg m²]

ω : Rotational speed [rad/s]

τ : Shaft torque [Nm]

F : Friction coefficient (=0)

U : Turbine average circumferential velocity [m/s]

D_m : Turbine average diameter (=2m)

C_0 :

K : Adiabatic index (=1.667)

T_i : Turbine inlet temperature [K]

π_T : Pressure ratio

Z : Turbine stage (=6)

C_m : Turbine inlet axial velocity [m/s]

G : Turbine flow rate [kg/s]


P_i : Turbine inlet pressure [MPa]

A_m : Turbine inlet flow area [m²]


P_o : Turbine outlet pressure [MPa]

Dynamic Calculation (3/4)

- Loss of Thermal Load of H₂ Plant (370MW) in GTHTR300C -




- CV1 : Turbine bypass flow control valve
- CV2 : Recuperator inlet temperature control valve
- CV3 : Turbine inlet temperature control valve
- V4 : Turbine bypass valve






Dynamic Calculation (4/4)

- Loss of Thermal Load of H₂ Plant (370MW) in GTHTR300C -




- CV1 : Turbine bypass flow control valve
- CV2 : Recuperator inlet temperature control valve
- CV3 : Turbine inlet temperature control valve
- V4 : Turbine bypass valve





Dynamic calculation (1/4)

- Loss of thermal load of H₂ Plant (170MW) in GTHT300C -



Thermal disturbance

IHX

2nd inlet

: **+400 K**

Turbine

Inlet

: **+19.7 K**


Turbine R.P.M. increase

: **+ 5 r.p.m.**



Dynamic calculation (2/4)

- Loss of thermal load of H₂ Plant (170MW) in GTHT300C -



IHX pressure difference

MAX
: +0.19 MPa

Reactor inlet flow rate variation

: -34.0 kg/s

Reactor power variation

: -93.5 MW


Reactor outlet temperature

: Constant



Dynamic calculation (4/4)

- Loss of thermal load of H₂ Plant (370MW) in GTHT300C -



IHX pressure difference

MAX

: +0.16 MPa

Reactor inlet flow rate variation

: -59.7 kg/s

Reactor power variation

: -293 MW


Reactor outlet temperature

: Constant



Dynamic calculation (3/4)

- Loss of thermal load of H₂ Plant (370MW) in GTHT300C -



Thermal disturbance

IHX

2nd inlet

: **+400 K**

Turbine

Inlet

: **+201 K**

Turbine R.P.M. increase

: **+ 90 r.p.m.**