

Experimental Measurements for Plate Temperatures of MTR Fuel Elements at Sudden Loss-of Flow Accident and Comparison with Computed Results

Dr. Bülent SEVDİK

TR-2 Reactor Unit Head

**Turkish Atomic Energy Authority, CNAEM,
Istanbul, Turkey**

The aim of this study:


- To generate experimental data to be used for sensitivity analysis and assessment calculations on the thermal-hydraulic codes written for **Loss of Flow Accident** (LOFA) analysis of research reactor with MTR- type (plate type) fuel elements.


How does it Happen:

- In an open pool research reactor with downward coolant flow, an accident such as shaft breaks between pump and flywheel can lead to **sudden loss of flow.**

- In the TR-2 Research Reactor;
- Sudden Loss of Flow Accident is simulated by closing the *pool inlet valve*.
- It is a butterfly type valve and total closing time is about 30 seconds but effective flow decrease occurs in 10seconds.
- The beginning of the flow decrease by the closing of valve was accepted as zero time and decrease curve of flow rate versus time was plotted.

Flow Decay Curve





TR-2 Reactor Cooling Systems

- Power distributions of the fuel elements in the reactor core were determined experimentally by using copper wire activation technique.
- According to the existing core loading of the TR-2 Reactor;
- **core positions**
- **power distributions** (U-235 weights, relative flux dist.)


of the fuel elements were given for the inputs of the calculations to simulate the **LOFA** at the **(PARET)** computer codes.

Instrumented Fuel Element:


- An instrumented fuel element, which has five thermocouples along the vertical direction of the fuel plate, was used for the experiments.

Instrumented
Fuel Element
top view.

23 Fuel Plates



Thermo-couples are
placed on second fuel
plate (first cooling
channel) (Cooling
gap:2.1 mm)



Location of the Chromel –Alumel Thermocouples on Fuel Plate of the Instrumented Fuel Element

W TX5


THE SIMS




TR-2 Core Configuration

88	78 Grafit	68 BE	58 BE	48 BE	38 Grafit	28
87 Grafit	77 BE	67 S-107	57 I-003	47 S-106	37 BE	27 Grafit
86 Grafit	76 S-120	66 C-015	56 S-108	46 C-012	36 S-119	26 Grafit
85 WB	75 S-105	65 S-111	55 I-001	45 S-114	35 S-117	25 WB
84 BE	74 S-118	64 C-017	54 S-101	44 C-011	34 S-116	24 BE
83 WB	73 BE	63 S-115	53 SI-01	43 S-110	33 BE	23 WB
82	72 Punomatic	62 BE	52 BE	42 BE	32 Grafit	22

Instrumented Fuel Element was Placed .






Experiments:

- Four experiments were performed for SLOFA.
- Three of these experiments were repeated with different initial conditions such as different core inlet temperatures and different reactor operation times at 5 MW nominal power level and 750 m³/h primary flow rate.
- The reactor was shutdown by flow scram at these three experiments.
- Last Exp. was performed without scram.
(Nötronic Power: 50 kw)

1. Experiment




P=5 MW Total reactor operation time is 5 minute before scram

Initial flow rate: **750 m³/h (reverse flow)**


Pool Water temperature : **23 °C (Core inlet)**

2. Experiment




P=5 MW Total reactor operation time is 5 minute before scram
Initial flow rate: **750 m³/h (reverse flow)**
Pool Water temperature : **17 °C (Core inlet)**

3. Experiment



P=5 MW Total reactor operation time is 2 hours before scram
Initial flow rate: **750 m³/h (reverse flow)**
Pool Water temperature : **29.5 °C (Core inlet)**

4. Experiment




P= 50 KW Neutronic Power - Total reactor operation time is 5 minutes

before flow decrease Without SCRAM

Initial flow rate: **750 m³/h (reverse flow)**

Pool Water temperature : **19 °C (Core inlet)**


1. & 2. EXPERIMENT




P=5 MW **Total reactor operation time is 5 minute before scram**
Initial flow rate: 750 m³/h (reverse flow)

They are compatible

5 Minutes 5 MW Power Operation
Pool Water: 23 °C




2 Hours 5 MW Power Operation
Pool Water: 29.5 °C




5 Minutes 5 MW Power Operation


Pool Water :23 °C



2 Hours 5 MW Power Operation

Pool Water :29.5 °C






For Paret Calculations : P=5 MW , Reactor operation time before scram 5 minutes at **1 MW** , **(to decrease decay heat at the calculations)**


Initial Flow Rate: **750 m³/h**

Pool Water Temperature: **17 °C**

Decreased Decay Heat



5 Minute Power Operation at
1 MW and
5 MW before SCRAM



5 Minute Power Operation
at 5 MW
before SCRAM

Pool water temperature: 17°C

Conclusions:

- Residual decay heat calculation and the natural convection modeling for narrow rectangular channels of PARET code are **not quite realistic**.
- PARET uses the standard fission-product decay heat curve for uranium-fuelled thermal reactors published by the American Nuclear Society as a proposed standard (ANS-5.1/N18.6).

- **For the calculation of the residual decay heat, special attention must be given to the fact that**
- *“Approximately one-half of the decay heat is due to gamma radiation with energies in the range of about 0.2-2.0 MeV.*
- *The e-folding length for 1 MeV gamma radiation in aluminum is 6 cm, i.e., the source gamma intensity is attenuated to 1/e of its original value after passing through 6 cm of aluminum.*


- *This corresponds to a penetration of 40-50 fuel plates and hence shows that a significant portion of a given level of fuel element decay heat will be deposited at the outside of the fuel element".*
- **Realistic calculations can be done for LOFA and LOCA analysis by using the decreased (1/2) values of decay heat generation curve of ANS.**

Thank you very much

Ramp Reactivity Insertion (Lin.Power& Clad Temps)

Initial Power level: 50 kW, Coolant Flow rate: 750 m³/h


CR2 withdrawn from 544 to 620, Reactivity insertion rate 34.7 pcm/s and Scram came after 12 sec. from periyot (4.2sec)




Ramp Reactivity Insertion(Periot&Clad Temps)

Initial Power level: 50 kW, Coolant Flow Rate: 750 m³/h

CR2 withdrawn from 544 to 620, Reactivity insertion rate: 34.7 pcm/s and after 12 seconds Scram came from periot (4.2sec)



Ramp Reactivity Insertion (Clad Temps & Period)
Initial Power 1 MW, Flow rate: 730m³/h
Reactivity insertion rate 30 pcm/s and after 13 sec Scram came from Max. Power (5MW) .



Ramp Reactivity Insertion (Lin.Power& Clad Temps)

Initial power level 1MW, Cooland Flow Rate: 730 m³/h

CR2 withdrawn from 478 to 550'ye çekildi. Reactivityinsertion rate 30 pcm/s and after 13 sec SCRAM came from Max.Power (5 MW) .

