

# THE DESIGN CHARACTERISTICS OF ADVANCED POWER REACTOR 1400

KIM, HAN-GON



*Advanced NPP Development Office  
Korea Hydro & Nuclear Power Co., Ltd.*



# CONTENTS

I . Introduction

II . Description of Nuclear Systems

III . Description of Secondary Systems

IV . Safety System Design Characteristics

V . Plant Layout

VI . Conclusions



# Nuclear Power Plants in Korea

In Operationa 20(17,716) + Under Const 8(9,600) = 23(27,316)

## Ulchin Total 8 (8,700)

- In Operation  
Ulchin # 1,2,3,4,5,6  
88.09~05.04  
Units: MW  
6 (5,900)
- Under Const.  
Shin Ulchin #1,2  
Units: MW  
2 (2,800)

## Wolsong Total 6 (4,779)

- In Operation  
Wolsong #1,2,3,4  
83.04~99.10  
Units: MW  
4 (2,779)
- Under Const.  
ShinWolsong #1,2  
Units: MW  
2 (2,000)

## Yonggwang Total 6 (5,900)

- In Operation  
Yonggwang  
# 1,2,3,4,5,6  
86.08~2002.12  
Units: MW  
6 (5,900)
- Under Const.  
—

## Kori Total 8 (7,937)

- In Operation  
Kori #1,2,3,4  
78.04~86.04  
Units: MW  
4 (3,137)
- Under Const.  
Shin Kori #1,2,3,4  
Units: MW  
4 (4,800)




(As of Dec.31, 2007)

# APR1400 Construction Schedules




## Shin-Ulchin

### Construction Plans of Shin-Ulchin #1,2



## Shin-Kori

### Key Milestones of Shin-Kori 3&4



## Development History of APR1400

- Evolutionary ALWR in Korea based on current OPR1000 Design
- Design Certification for the Standard Design

## General Requirement

- Rated Power : 4000 MWth
- Plant Life time : 60 years for major components
- Seismic Design : SSE 0.3g
- Safety Goal : CDF <  $10^{-5}$ , CFF <  $10^{-6}$

## Performance & Economic Goals

- Plant Availability : 90%
- Construction Period : 48 Months for Nth Plant
- Economic Goal : 20% advantage over coal



## Overall Description


- **Rated Power : 4000 MWth**
- **2-Loop PWR :**
  - One Reactor Vessel
  - Two Steam Generators
  - Four Reactor Coolant Pumps
  - One Pressurizer
- **Thermal Margin > 10%**



### Hot Leg Temperature Reduction

- 621°F → 615°F
- To prevent SG tube corrosion

### Integrated Head Assembly



- Integration of
  - Cooling shroud assembly
  - CEDM cooling system
  - Missile shielding material
- Expected effects of IHA
  - Reducing refueling time
  - Reducing occupational dose
  - Reducing comp. storage area
  - Improving safety for workers



### Steam Generator

- Increased tube plugging margin : 8 → 10%
- Corrosion resistant tube material : I600 → I690
- Increased secondary inventory to prolong SG dryout time
- Automatic level control for all power level

### Pressurizer


- Larger steam space to accommodate RCS transients
- Adoption of POSRV instead of PSV + SDS
  - 4 PSVs + 2 SDS → 4 POSRVs
  - Over pressure protection + Safety depressurization function
  - High reliability





## Design Characteristics of I&C Systems

- Digital Technology & Data communication network
- Open & Standard Architecture
- Defense on Common mode failure
- Operability & Maintenance : Auto test, Self-diagnosis



## Characteristics of MCR Design

- Multiple Compact Workstation MCR
- Large Display Panel
- Soft-Controller : Safety & Non-safety control
- Computerized Procedure Systems
- Adoption of Human Factor Engineering



### Design Characteristics

4 independent trains (Each train consists of 1 SIP and 1 SIT)


No cross tie between trains

Unified water source from IRWST

No re-circulation mode during LOCA

Fluidic Device installed in SIT

Elimination of LPSIP






Effective use of ECC water and Better response to Transient and SBLOCA



### Design Characteristics

- Principles : Vortex flow resistance
  - Stand pipe : Low resistance
  - Control port : high resistance
- Purpose : Extending SIT injection period during LOCA
- Effect : Removal of LPSIPs




### Test Facility

- Actual physical dimension
  - Inside diameter : 2.74 m
  - Total Height : 12.0 m
- Full Pressure : 50 bar



### Test Results

- Test Results
  - Total 28 tests has been performed
  - Performance is fully verified
  - Detailed design spec. is finalized



# Integral Test Loop

## IV. Safety System Design Characteristics

### ■ ATLAS Facility

#### Characteristics

- ① 1/2 height and 1/144 scaled down based on flow area
- ② NSSS and safety systems of APR1400 are modeled

#### Purpose


- ① Major system behavior for LBLOCA, DVI Break, MSLB, MFLB, SGTR, TLOFW and so on

#### Milestone

- ① Construction Completion : '06.5
- ② LBLOCA Tests : '06.9 ~

#### Effects

- ① Better understanding of APR1400 SIS Performance
- ② Benchmarking safety analysis codes



### Functions


## IRWST

### Design characteristics

- Supply cooling water during refueling
- Supply the water source to safety injection and containment spray systems during DBA
- Removed recirculation mode because bled coolant is collected in IRWST through HVT (Hold-up Volume Tank)
- Supply heat sink during rapid depressurization of RCS and feed and bleed operation
- Supply water source for reactor cavity flooding system
- Collect the coolant from POSRV to IRWST through sparger
- Removing of Pressurizer Relief Tank (PRT)
- Reduce operator's burden with simplified operation mode
- Reduce containment penetrations



## IRWST





# External Cooling of RPV (ERV)C

## IV. Safety System Design Characteristics

### ERV


- Strategy to retain corium in vessel by submerging reactor vessel exterior with water
- Used in Lovisa and AP600 and AP1000
- Theofanous conducted a structured study on its performance
- Chosen as a key accident management strategy for APR1400

### Accident Management Strategy of APR1400

- If water can be injected to reactor cavity : ERVC
- If not (eg. SBO): corium spread to reactor cavity and cooling from IRWST using gravity head.


### ERV Concept of APR1400

- One train of SCP + BAMP
- Associated system is already included in APR1400 design.




### RPV Insulation

- Passage way for the water to cool the hot reactor vessel
- Natural circulation path for the two-phase flow and influence CHF
- Streamlined insulation design for APR1400 is in progress



### Feasibility Study


- 4 Major scenarios using MAAP
- Margin for APR1400 shows the usefulness of the ERVC strategy



**Power Block : NI & TI**

NI : Reactor Building,  
Aux. Building,  
Compound Building

TI : Turbine Building,  
SwitchGear



**Basic Design  
Concept**

2 Units reference

Parallel Sliding Type

Aux. Building  
: Quadrant structure




## VI. Conclusions



신울진 1,2호기 원자력발전소

Basic Design of APR1400  
has been finished



**First commercial NPPs of APR1400**  
[ Shin-Kori 3&4 are in progress ]



Human

Environment

**Thank you !**

Technology

