

# Overview on New RRs in China

**CHEN Huiqiang**

**China Institute of Atomic Energy**



# Contents

- A. China Advanced Research Reactor  
(CARR)**
- B. China Experimental Fast Reactor  
(CEFR)**



# Part A CARR

- Reactor complex
- Design parameters
- Safety systems
- Utilization



# CARR

- Tank- in-Pool
- 60 MW
- H<sub>2</sub>O coolant, D<sub>2</sub>O reflector
- Maximum thermal neutron flux:  
 $8 \times 10^{14} \text{ n-cm}^{-2}\cdot\text{s}^{-1}$  (in reflector)



# Pool



Pipe of hot-water layer

Tube for Ionization chamber

Pipe of Primary loop

Flow guiding tank

Heavy water tank

Decay tank

Pool gate

Concrete shielding

Reactor pool

Safety rod drive mechanism


Vertical channel

Storage shelves of spent fuel assembly

Core vessel

Fuel assembly

Control rod drive mechanism



# CARR\_\_\_\_\_Reactor Complex

## Fuel

- Plate type
  - $^{235}\text{U}$  enrichment: 19.75 wt%
  - 17 Fuel Assemblies (FA)
  - 21 plates in each FA
- Meat:  $\text{U}_3\text{Si}_2\text{-Al}$  , thickness=0.6mm
- Cladding: 6061 Al alloy , thickness=0.38mm



# CARR\_\_\_\_\_Reactor Complex

## Control Rod

- Neutron absorb: Hafnium
- Shim rods : 3
- Regulating rods : 1
- Safety rods : 2





# CARR\_\_\_\_\_Reactor Complex

## Reactor Vessel

- Al alloy, life  $\approx$  10 years
- D=459mm
- Separating H<sub>2</sub>O and D<sub>2</sub>O



# Reactor vessel




# CARR\_\_\_\_\_Reactor Complex

## Heavy Water Tank


- $D = 2200\text{mm}$
- Material= SS
- $H_{\text{heavy water}} = 2320\text{mm}$   
 $H_{\text{helium}} = 190\text{mm}$



# Heavy Water Tank



# Heavy Water Tank




# CARR\_\_\_\_\_Reactor Complex

## Decay Tank

- 3 Cylinders: inner + middle + outer
- $D_{\text{outer cylinder}} = D_{\text{reactor pool}}$
- Material= SS
- Decay time=40 s



# Decay Tank



# Decay Tank






# CARR\_\_\_\_\_Reactor Complex

## Coolant Guiding Tank

- **D = 1364mm**
- **Material= SS**
- **Making coolant flow stably**



# Coolant Guiding Tank



# Coolant Guiding Tank



# CARR\_\_\_\_\_Reactor Complex

## Coolant Guiding Tank

- **D = 1364mm**
- **Material= SS**
- **Making coolant flow stably**



# CARR\_\_\_\_\_Reactor Complex

## CRDM

- CRDM for safety rods: Hydraulic
- CRDM for other rods: Electromagnetic



# CRDM



# CARR\_\_\_\_\_Design parameters

<b>Power</b>	<b>MW</b>	<b>60</b>
<b>Equivalent diameter of active area</b>	<b>cm</b>	<b>39.92</b>
<b>Height of active area</b>	<b>cm</b>	<b>85</b>
<b>Maximum thermal neutron flux</b>	<b>n/ (cm<sup>2</sup>.s)</b>	<b><math>\sim 1.0 \times 10^{15}</math></b>
<b>Primary coolant flow rate</b>	<b>m<sup>3</sup>/h</b>	<b>2385</b>
<b>Primary coolant inlet pressure</b>	<b>MPa</b>	<b>0.936</b>
<b>Primary coolant outlet temperature</b>	<b>°C</b>	<b>56</b>
<b>Depth of reactor pool</b>	<b>m</b>	<b>15.54</b>
<b>Inner diameter of reactor pool</b>	<b>m</b>	<b>5.5</b>



# **CARR\_\_\_\_\_Safety System**

## **Reactor Shutdown System**

- **Control rod falling**

**Triggered by FRPS and SRPS**

- **Heavy water discharge**

**Triggered by SRPS**





# CARR—Reactor shutdown

## Protection variable of FRPS

<b>1</b>	<b>Reactor power</b>	<b>Over setting value</b>
<b>2</b>	<b>period of reactor power</b>	<b>Under setting value</b>
<b>3</b>	<b>Primary coolant inlet temperature</b>	<b>Over setting d value</b>
<b>4</b>	<b>Primary coolant outlet temperature</b>	<b>Over setting value</b>
<b>5</b>	<b>Primary coolant inlet pressure</b>	<b>Under setting value</b>
<b>6</b>	<b>Primary coolant inlet flow rate</b>	<b>Under setting value</b>
<b>7</b>	<b>secondary coolant inlet pressure</b>	<b>Under setting value</b>
<b>8</b>	<b>Dosage of coolant</b>	<b>Over setting value</b>
<b>9</b>	<b>Dosage above reactor pool</b>	<b>Over setting value</b>



# CARR—Reactor shutdown

## Protection variable of FRPS

10	Dosage of stack drainage	Over standard value
11	Radioactivity of inert gases in reactor hall	Over setting value
12	Inlet temperature of heavy water	Over setting value
13	Outlet temperature of heavy water	Over setting value
14	Heavy water flow rate	Under setting d value
15	Power supply	OFF
16	Frequency of off-site power	Under setting value
17	Pressure in operation hall	Over setting value
18	The ratio of thermal power to nuclear power	Over setting value
19	The ratio of heavy water thermal power to reactor power	Over setting value



# CARR—Reactor shutdown

## Protection variable of SRPS

<b>1</b>	<b>Reactor power</b>	<b>Over standard value</b>
<b>2</b>	<b>Primary coolant outlet temperature</b>	<b>Over standard value</b>
<b>3</b>	<b><math>\gamma</math> dose of primary coolant</b>	<b>Over standard value</b>
<b>4</b>	<b>Power supply</b>	<b>OFF</b>



# **CARR\_\_\_\_\_Safety System**

## **Emergency Core Cooling System**

- **2 pumps running continuously**
- **Cooling pool water under normal condition**
- **Cooling core under LOCA/LOFA condition**



# CARR---ECCS




Fig.1 Flow Diagram of CARR ECCS

# CARR\_\_\_\_\_Safety System

## Confinement

- $30\text{ m} \times 30\text{ m} \times 23\text{ m}$  (L  $\times$  W  $\times$  H)

Reinforced concrete

- Isolated in case of accident so as to retaining rad-gas for some 12 hours
- Be able to withstand SSE
- Leak-rate  $\not\geq 5\% \text{v/d}$



# CARR\_\_\_\_\_Utilization

21 vertical tubes and 9 beam tubes for:

- △ Neutron Scattering
- △ RI production
- △ Neutron activation analysis
- △ Fuel /material irradiation test
- △ Silicon NTD



# CARR

2010,5,13

**First critical reached**

2011,9,22

**Phase B commission finished**






# Part B CEFR

- Reactor Block
- Design parameters
- Safety systems



# COMPUTER IMAGINATION OF CEFR




Turbine building

Nuclear building

Nuclear assistant building


Building

# REACTOR HALL



FIG

# CEFR REACTOR BLOCK




FIG



# CEFR











- Pool type
- 65 MW t / 25 MW e
- Coolant = Sodium





## CEFR Core

Core Fig

	Fuel subassembly	81
	Stainless steel rod	1
	Stainless steel reflector subassembly	37
	Stainless steel reflector rod	132
	Stainless steel reflector rod	167
	Shielding subassembly	230
	Storage position for spent fuel subassemb	56
	Safety subassembly	3
	Regulation subassembly	2
	Compensation subassembly	3

# CEFR \_\_\_\_\_ Reactor block

## Fuel

- 81 hexagonal Fuel Assemblies (FA)
- 61 rods in each FA
- $^{235}\text{U}$  enrichment: 64.4 wt%
- Meat:  $\text{UO}_2 \rightarrow \text{U-Pu}$  dioxide  
Cladding: SS  
D=6mm



# CEFR \_\_\_\_\_ Reactor block

## Control Rod Assembly

- Shim rod assembly: 3 (B10 enrichment 91%)
- Regulating rod assembly : 2 (10%)
- Safety rod assembly : 3 (91%)
- Each assembly consists of 7 rods
- Neutron absorb:  $B_4C$
- Cladding : SS





# CEFR \_\_\_\_\_ Reactor block

## Reflector

- **336 SS Reflector Assemblies (RA)**
- **2 types**
  - A: 7 rod (d=20mm) in each RA;**
  - B: 1 rod (d=54mm) in each RA**
- **In the future, the 3 inner circles of RAs will be replaced by conversion assemblies for fuel breeding research**



# CEFR \_\_\_\_\_ Reactor block

## Shielding Assembly

- 230 hexagonal Shielding Assemblies (SA)
- Each assembly consists of 7 rods
- Rod Meat:
  - $B_4C$  (B10 enrichment=19.8%)
  - D= 16.2mm
- Rod clad: SS, D=19.2



## CEFR \_\_\_\_\_ Reactor block

### CRDM

- 8 CRDMs, one for one CRA
- Type A for shim and regulating rod
- Type B for safety rod



# CEFR---CRDM



# CEFR\_\_\_\_\_Reactor block

## Reactor Vessel

- **H=12765**
  - main vessel: d=7960mm, t=25mm**
  - guard vessel: d=8185mm, t=25mm**
- **PCS loops ( 2 ) in it , including:**
- **2 pumps, 4 intermediate heat exchangers**
- **2 independent heat exchangers for RHRS**



# CFER---Parameters

<b>Thermal Power</b>	<b>MW</b>	<b>65</b>
<b>Electric Power</b>	<b>MW</b>	<b>20</b>
<b>Plant life</b>	<b>year</b>	<b>30</b>
<b>Bum-up, first load max.</b>	<b>MWd/t</b>	<b>60000</b>
<b>Bum-up, target max.</b>	<b>MWd/t</b>	<b>100000</b>
<b>Fuel exchange</b>	<b>Day</b>	<b>80</b>
<b>Fuel (First Loading)</b>		<b>UO2</b>
<b>Primary loop type</b>		<b>Pool</b>
<b>Number of circuits per loop</b>		<b>2</b>
<b>Number of IHX per circuit</b>		<b>2</b>
<b>Steam pressure</b>	<b>MPa</b>	<b>14</b>



# CEFR\_\_\_\_\_ Safety System

## Reactor Shutdown System

- FSS + SSS, diversities include:
  - (1) FSS is equipped with magnetic damper  
SSS is equipped with electromagnetic clutch
  - (2) FFS is actuated by motor power-off  
SSS is actuated by clutch power-off
  - (3) FSS rod falling by gravity  
SSS rod falling by gravity and spring

And so on



# CEFR\_\_\_\_\_ Safety System

## Reactor Shutdown System

- 2 independent reactor protection systems.  
Variables are:  
period, power, outlet temperature, liquid Na level in main vessel, primary flow-rate, secondary flow-rate, feed-water loss of SG, closedown of turbine valve, loss of power supply, earthquake, etc.





# CEFR\_\_\_\_\_ Safety System

## Residual Heat Removal System

- 2 loops, capacity of each=0.525MW
- In the accident condition, reactor residual heat will be transferred to the hot sodium zone by means of primary pump inertia and natural circulation, and then to intermediate loop through independent heat exchangers located in the hot sodium zone, and finally to the atmosphere through air coolers.






图 6.3—1 事故余热排出系统总体布置图

**CEFR\_\_\_\_\_ Safety System**

**Containment System**

**consists of 3 confining boxes and the confinement wherein the 3 boxes located.**



# CEFR \_\_\_\_\_ Safety System

## Containment System--- Confinement

- retain and sedimentate the radioactive material
- concrete structure (thickness 1m)  
36m × 36m × 57m (L × W × H)
- Leakage rate is  $\leq 5 \Delta v/v/d$  under 100Pa



**CEFR\_\_\_\_\_ Safety System**

**Containment System--- BOX1**

**When argon pressure reactor vessel reaches 0.06MPa, the liquid-sealing device opens to transfer argon to room 302 for temporary storage and decay, and then to the chimney through ventilation system. Leakage rate of room 302 is less than  $4\% \Delta v/v/d(0.03\text{MPa})$ .**



**CEFR\_\_\_\_\_ Safety System**

**Containment System--- BOX2**

- **Reactor cap, carbon steel.**
- **When the radioactive level exceeds the setting value, emergency ventilation system starts up to replace the normal ventilation system by which the radioactive argon and Na aerosol can be prevented from escaping into the confinement.**



# CEFR\_\_\_\_\_ Safety System

## Containment System--- BOX2

- Groove is laid beneath the pipes and equipments in this BOX
- In case of accident, the leaked Na will flowed into the groove where isolated space will be formed so that the Na fire can be put out automatically.



# CEFR

- First critical 2010/7/21
- Electricity generation 2011/7/21







谢谢！  
*Thanks for your attention!*