



IAEA

International Atomic Energy Agency

INSAG-28

Application of the Principle of Defence in Depth in Nuclear Safety to Small Modular Reactors

Addendum to INSAG-10

INSAG

A REPORT BY THE INTERNATIONAL NUCLEAR SAFETY ADVISORY GROUP

IAEA SAFETY STANDARDS AND RELATED PUBLICATIONS

IAEA SAFETY STANDARDS

Under the terms of Article III of its Statute, the IAEA is authorized to establish or adopt standards of safety for protection of health and minimization of danger to life and property, and to provide for the application of these standards.

The publications by means of which the IAEA establishes standards are issued in the **IAEA Safety Standards Series**. This series covers nuclear safety, radiation safety, transport safety and waste safety. The publication categories in the series are **Safety Fundamentals**, **Safety Requirements** and **Safety Guides**.

Information on the IAEA's safety standards programme is available on the IAEA web site:

<http://www-ns.iaea.org/standards/>

The site provides the texts in English of published and draft safety standards. The texts of safety standards issued in Arabic, Chinese, French, Russian and Spanish, the IAEA Safety Glossary and a status report for safety standards under development are also available. For further information, please contact the IAEA at: Vienna International Centre, PO Box 100, 1400 Vienna, Austria.

All users of IAEA safety standards are invited to inform the IAEA of experience in their use (e.g. as a basis for national regulations, for safety reviews and for training courses) for the purpose of ensuring that they continue to meet users' needs. Information may be provided via the IAEA Internet site or by post, as above, or by email to Official.Mail@iaea.org.

RELATED PUBLICATIONS

The IAEA provides for the application of the standards and, under the terms of Articles III and VIII.C of its Statute, makes available and fosters the exchange of information relating to peaceful nuclear activities and serves as an intermediary among its Member States for this purpose.

Reports on safety in nuclear activities are issued as **Safety Reports**, which provide practical examples and detailed methods that can be used in support of the safety standards.

Other safety related IAEA publications are issued as **Emergency Preparedness and Response** publications, **Radiological Assessment Reports**, the International Nuclear Safety Advisory Group's **INSAG Reports**, **Technical Reports** and **TECDOCs**. The IAEA also issues reports on radiological accidents, training manuals and practical manuals, and other special safety related publications.

Security related publications are issued in the **IAEA Nuclear Security Series**.

The **IAEA Nuclear Energy Series** comprises informational publications to encourage and assist research on, and the development and practical application of, nuclear energy for peaceful purposes. It includes reports and guides on the status of and advances in technology, and on experience, good practices and practical examples in the areas of nuclear power, the nuclear fuel cycle, radioactive waste management and decommissioning.

APPLICATION OF THE PRINCIPLE
OF DEFENCE IN DEPTH IN
NUCLEAR SAFETY TO
SMALL MODULAR REACTORS

ADDENDUM TO INSAG-10

INSAG-28

A report by the International Nuclear Safety Advisory Group

The following States are Members of the International Atomic Energy Agency:

AFGHANISTAN	GERMANY	PALAU
ALBANIA	GHANA	PANAMA
ALGERIA	GREECE	PAPUA NEW GUINEA
ANGOLA	GRENADA	PARAGUAY
ANTIGUA AND BARBUDA	GUATEMALA	PERU
ARGENTINA	GUINEA	PHILIPPINES
ARMENIA	GUYANA	POLAND
AUSTRALIA	HAITI	PORTUGAL
AUSTRIA	HOLY SEE	QATAR
AZERBAIJAN	HONDURAS	REPUBLIC OF MOLDOVA
BAHAMAS	HUNGARY	ROMANIA
BAHRAIN	ICELAND	RUSSIAN FEDERATION
BANGLADESH	INDIA	RWANDA
BARBADOS	INDONESIA	SAINT KITTS AND NEVIS
BELARUS	IRAN, ISLAMIC REPUBLIC OF	SAINT LUCIA
BELGIUM	IRAQ	SAINT VINCENT AND THE GRENADINES
BELIZE	IRELAND	SAMOA
BENIN	ISRAEL	SAN MARINO
BOLIVIA, PLURINATIONAL STATE OF	ITALY	SAUDI ARABIA
BOSNIA AND HERZEGOVINA	JAMAICA	SENEGAL
BOTSWANA	JAPAN	SERBIA
BRAZIL	JORDAN	SEYCHELLES
BRUNEI DARUSSALAM	KAZAKHSTAN	SIERRA LEONE
BULGARIA	KENYA	SINGAPORE
BURKINA FASO	KOREA, REPUBLIC OF	SLOVAKIA
BURUNDI	KUWAIT	SLOVENIA
CABO VERDE	KYRGYZSTAN	SOUTH AFRICA
CAMBODIA	LAO PEOPLE'S DEMOCRATIC REPUBLIC	SPAIN
CAMEROON	LATVIA	SRI LANKA
CANADA	LEBANON	SUDAN
CENTRAL AFRICAN REPUBLIC	LESOTHO	SWEDEN
CHAD	LIBERIA	SWITZERLAND
CHILE	LIBYA	SYRIAN ARAB REPUBLIC
CHINA	LIECHTENSTEIN	TAJIKISTAN
COLOMBIA	LITHUANIA	THAILAND
COMOROS	LUXEMBOURG	TOGO
CONGO	MADAGASCAR	TONGA
COSTA RICA	MALAWI	TRINIDAD AND TOBAGO
CÔTE D'IVOIRE	MALAYSIA	TUNISIA
CROATIA	MALI	TÜRKIYE
CUBA	MALTA	TURKMENISTAN
CYPRUS	MARSHALL ISLANDS	UGANDA
CZECH REPUBLIC	MAURITANIA	UKRAINE
DEMOCRATIC REPUBLIC OF THE CONGO	MAURITIUS	UNITED ARAB EMIRATES
DENMARK	MEXICO	UNITED KINGDOM OF GREAT BRITAIN AND NORTHERN IRELAND
DJIBOUTI	MONACO	UNITED REPUBLIC OF TANZANIA
DOMINICA	MONGOLIA	UNITED STATES OF AMERICA
DOMINICAN REPUBLIC	MONTENEGRO	URUGUAY
ECUADOR	MOROCCO	UZBEKISTAN
EGYPT	MOZAMBIQUE	VANUATU
EL SALVADOR	MYANMAR	VENEZUELA, BOLIVARIAN REPUBLIC OF
ERITREA	NAMIBIA	VIET NAM
ESTONIA	NEPAL	YEMEN
ESWATINI	NETHERLANDS, KINGDOM OF THE	ZAMBIA
ETHIOPIA	NEW ZEALAND	ZIMBABWE
FIJI	NICARAGUA	
FINLAND	NIGER	
FRANCE	NIGERIA	
GABON	NORTH MACEDONIA	
GAMBIA	NORWAY	
GEORGIA	OMAN	
	PAKISTAN	

The Agency's Statute was approved on 23 October 1956 by the Conference on the Statute of the IAEA held at United Nations Headquarters, New York; it entered into force on 29 July 1957. The Headquarters of the Agency are situated in Vienna. Its principal objective is "to accelerate and enlarge the contribution of atomic energy to peace, health and prosperity throughout the world".

INSAG-28

APPLICATION OF THE PRINCIPLE
OF DEFENCE IN DEPTH IN
NUCLEAR SAFETY TO
SMALL MODULAR REACTORS

ADDENDUM TO INSAG-10

A report by the International Nuclear Safety Advisory Group

INTERNATIONAL ATOMIC ENERGY AGENCY
VIENNA, 2024

COPYRIGHT NOTICE

All IAEA scientific and technical publications are protected by the terms of the Universal Copyright Convention as adopted in 1952 (Geneva) and as revised in 1971 (Paris). The copyright has since been extended by the World Intellectual Property Organization (Geneva) to include electronic and virtual intellectual property. Permission may be required to use whole or parts of texts contained in IAEA publications in printed or electronic form. Please see www.iaea.org/publications/rights-and-permissions for more details. Enquiries may be addressed to:

Publishing Section
International Atomic Energy Agency
Vienna International Centre
PO Box 100
1400 Vienna, Austria
tel.: +43 1 2600 22529 or 22530
email: sales.publications@iaea.org
www.iaea.org/publications

© IAEA, 2024

Printed by the IAEA in Austria

July 2024

STI/PUB/2094

<https://doi.org/10.61092/iaea.w9s3-1k5y>

IAEA Library Cataloguing in Publication Data

Names: International Atomic Energy Agency.

Title: Application of the principle of defence in depth in nuclear safety to small modular reactors / International Atomic Energy Agency.

Description: Vienna : International Atomic Energy Agency, 2024. | Series: INSAG series, ISSN 1025-2169 ; no. 28 | Includes bibliographical references.

Identifiers: IAEAL 24-01688 | ISBN 978-92-0-121724-0 (paperback : alk. paper) | ISBN 978-92-0-121824-7 (pdf) | ISBN 978-92-0-121924-4 (epub)

Subjects: LCSH: Nuclear reactors — Safety measures. | Nuclear reactors — Design and construction. | Nuclear industry — Regulations.

Classification: UDC 621.039.58 | STI/PUB/2094

FOREWORD

by the Chair of INSAG

Defence in depth is a fundamental principle of nuclear safety that applies to all types of nuclear installation. As noted in INSAG-12, Basic Safety Principles for Nuclear Power Plants, published in 1999 (itself an update of INSAG-3 from 1988), defence in depth at its core focuses on the strategy to provide multiple levels of protection to ensure that failures in carrying out safety activities, whether organizational, behavioural or equipment related, are corrected or compensated for without causing harm to individuals or the public at large. The International Nuclear Safety Advisory Group (INSAG) further elaborated on the concept in INSAG-10, Defence in Depth in Nuclear Safety, published in 1996, and noted that the concept was appropriate to guide the development of future nuclear installations.

The expanding interest in the design and deployment of small modular reactors (SMRs) prompted INSAG to re-examine INSAG-10 and its relevance to these emerging technologies. Consequently, INSAG has prepared this report as an addendum or supplement to INSAG-10 to specifically address the application of the defence in depth principle to SMRs. We emphasize that the concept of defence in depth and its underlying principles remain fundamental to the safety of nuclear installations. We also note that the type, extent and implementation of measures to address defence in depth may differ when considering the wide variability of SMR types as well as the application of the graded approach to nuclear safety.

We trust that this report will aid in the understanding of the principle of defence in depth and its ongoing application to new technologies.

The International Nuclear Safety Advisory Group (INSAG) is a group of experts with high professional competence in the field of nuclear and radiation safety and experience of working in regulatory organizations, nuclear industry, technical support organizations, research or academic institutions. INSAG is convened by the International Atomic Energy Agency (IAEA) with the objective of providing the Director General of the IAEA with authoritative advice and recommendations on current and emerging issues in nuclear and radiation safety approaches, policies and principles. INSAG addresses fundamental safety issues as well as current and emerging matters of importance relevant to the nuclear and radiation safety of all facilities and activities, including nuclear security issues insofar as they relate to nuclear and radiation safety.

EDITORIAL NOTE

The opinions and recommendations stated in this publication are those of INSAG and do not necessarily represent the views of the IAEA or its Member States.

CONTENTS

EXECUTIVE SUMMARY	1
1. INTRODUCTION.....	2
2. SMALL MODULAR REACTOR DESIGNS.....	3
3. APPROACH OF INSAG-10 TO DEFENCE IN DEPTH	3
4. APPLICATION TO SMALL MODULAR REACTORS	4
4.1. Passive features of SMRs compared with large evolutionary nuclear power plants	4
4.2. Common cause failures	5
4.3. Defence in depth	5
4.4. Graded approach	7
4.5. Performance and prescriptive based regulation	8
5. CONCLUSIONS AND RECOMMENDATIONS	8
REFERENCES.....	10
MEMBERS OF THE INTERNATIONAL NUCLEAR SAFETY ADVISORY GROUP	11
PUBLICATIONS OF THE INTERNATIONAL NUCLEAR SAFETY ADVISORY GROUP	13

EXECUTIVE SUMMARY

This publication provides more specific context for the application of INSAG-10, Defence in Depth in Nuclear Safety [1], to small modular reactors (SMRs).

While INSAG-10 noted the application of the defence in depth concept to all types of nuclear power plant, and possible variations in how it is implemented, experience shows that its implementation needs to take full account of the adequate independence of the levels of defence in depth, redundancy, diversity and protection against internal and external hazards, with a focus on improving mitigation as well as prevention.

The defence in depth concept and its principles, including the number of levels, are valid and applicable to all SMRs. However, the type, extent and implementation of specific measures may differ, since SMRs vary in design. Thus, the application of this concept and its principles needs to be implemented on a case by case basis using a graded approach. Furthermore, any analysis or demonstration related to potential harm on or off the site has to be performed on a site basis, not only for an individual SMR.

1. INTRODUCTION

1. The aim of this publication is to provide the necessary background and information for the application of the defence in depth concept to small modular reactors (SMRs), which may be useful in their design and safety assessment. SMRs vary in their design, and the application of this concept needs to be adapted to individual designs of different types.

2. Small modular reactors are emerging as a potential source of electricity and heat, as well as for use in other applications such as hydrogen generation and desalination. Various countries are considering SMRs as a viable and safe option for a carbon free source of energy. Some SMRs have advanced safety features that may prove to significantly reduce the likelihood of having a severe accident compared with Generation III nuclear power plants.

3. More than 25 years have passed since the publication of INSAG-10, Defence in Depth in Nuclear Safety [1], which expanded on the concept of defence in depth and became an international milestone for assessing the safety of nuclear power plants. The IAEA has made wide use of this concept and has established requirements and provided recommendations related to defence in depth in many of its safety standards.

4. INSAG-10 was intended to be a comprehensive report addressing all types of nuclear power plant, including those designed in the future. In fact, it has a separate section entitled Development of Defence in Depth for Future Nuclear Power Plants. However, feedback since its publication (see Ref. [2]) shows that, while the defence in depth concept remains valid, implementation of the concept needs to be strengthened at all levels through adequate independence of the levels of defence in depth, redundancy, diversity and protection against internal and external hazards. In addition, there is a need to focus not only on accident prevention, but also on improving mitigation measures.

5. Taking into consideration the current interest and needs of the nuclear safety community, the objective of this report, which is to be read as providing additional context to INSAG-10, is to explore, at a high level, the ways in which INSAG-10 can be applied to various types and sizes of SMR in the present circumstances.

2. SMALL MODULAR REACTOR DESIGNS

6. Small modular reactors vary widely in their use of innovative features and in the maturity of their design. The IAEA defines six types of SMR [3]:

- (1) Land based water cooled SMRs;
- (2) Marine based water cooled SMRs;
- (3) High temperature gas cooled SMRs;
- (4) Liquid metal cooled fast neutron spectrum SMRs;
- (5) Molten salt SMRs;
- (6) Microreactors.

7. The variability in SMR designs is due to differences in the following:

- Power;
- Fuel and coolant characteristics;
- Innovative features (as opposed to evolutionary features);
- Maturity of development;
- Utilization (e.g. electricity to the grid, heat generation, dedicated power source).

Hence, each design needs to be considered on a case by case basis for the application of the defence in depth concept.

3. APPROACH OF INSAG-10 TO DEFENCE IN DEPTH

8. Paragraph 17 of INSAG-10 [1] outlines the objectives of defence in depth as follows:

- “— to compensate for potential human and component failures;
- to maintain the effectiveness of the barriers by averting damage to the plant and to the barriers themselves; and
- to protect the public and the environment from harm in the event that these barriers are not fully effective.”

9. These objectives are based on INSAG-3, Basic Safety Principles for Nuclear Power Plants¹. They are performance based and their implementation is open to a graded approach, as provided for in para. 16 of INSAG-10 [1].

10. Section 5 of INSAG-10 is dedicated to a discussion of defence in depth for future nuclear power plants. This is generally focused on large evolutionary nuclear power plants, with the assumption that they would have “a probability of severe core damage below 10^{-5} per plant operating year combined with a further reduction by a factor of at least ten in the probability of a major release requiring a short term off-site response” [1].

11. Thus, as minimum objectives, a core damage frequency (CDF) of around $10^{-5}/a$ and a large early release frequency (LERF) of around $10^{-6}/a$ are specified. It is obvious that the considerations for future nuclear power plants outlined in section 5 of INSAG 10 [1] would change if the CDF and LERF values for those plants were significantly different. It is also worth mentioning that in para. 119 of INSAG-10 [1], it is stated that values much smaller than presented would be difficult to validate. Therefore, it is important to understand the uncertainties involved in the computation of such small probabilities. It is also particularly important to remember that section 5 of INSAG-10 [1] considers multiple failure events at level 3 of defence in depth and the fact that “hypothetical severe accident sequences that could lead to large radioactive releases due to early containment failure are essentially eliminated with a high degree of confidence” [1]. It also states that “Meeting the safety objectives set for the next generation of nuclear power plants will necessitate improving the strength and independence of the different levels of defence” [1].

4. APPLICATION TO SMALL MODULAR REACTORS

4.1. PASSIVE FEATURES OF SMRs COMPARED WITH LARGE EVOLUTIONARY NUCLEAR POWER PLANTS

12. Small modular reactors have smaller radionuclide inventories and generally make greater use of passive safety features (e.g. residual heat removal) than do large nuclear power plants. The failure modes of some passive systems tend to be

¹ INTERNATIONAL NUCLEAR SAFETY GROUP, Basic Safety Principles for Nuclear Power Plants, 75-INSAG-3, IAEA, Vienna (1988) (superseded by INSAG-12 [4]).

gradual compared with the failures of active systems. Thus, their design typically helps to more effectively avoid cliff edge failures of active components. On the basis of such features, some SMRs claim to lower the mentioned CDF and LERF values by about one order of magnitude.

4.2. COMMON CAUSE FAILURES

13. Small modular reactors might be more prone to common cause failures, especially with respect to external hazards at the same site. Sharing of some safety related systems and components (such as the control room, reactor pool and spent fuel pool) is another factor to consider. Furthermore, in order to preserve their ‘modular’ attribute (regarding their source term), more than one module failing because of an external hazard (or any other common cause) would lead to unacceptable off-site consequences if the regulatory limits were set for a single module. Therefore, robustness against common cause failures, including external hazards, is essential if the assumptions concerning the occurrence of severe accidents and considerations of the sizes of external zones are based only on the failure of a single module.

4.3. DEFENCE IN DEPTH

14. Principle 8 of the Fundamental Safety Principles [5] emphasizes the importance of defence in depth, stating:

“Defence in depth is implemented primarily through the combination of a number of consecutive and independent levels of protection that would have to fail before harmful effects could be caused to people or to the environment.”

15. IAEA Safety Standards Series No. SSR-3, Safety of Research Reactors [6], presents five levels of defence (see para. 2.12), but notes that in the application of the defence in depth concept, the measures that will be necessary will depend on the source in terms of “the amount and the isotopic composition of the radionuclides, the effectiveness of the individual barriers, the possible internal and external hazards, and the potential consequences of barrier failures” (see para. 2.13).

16. An approach similar to that presented in SSR-3 [6] for research reactors might be applied in grading the application of the defence in depth concept for

SMRs, but recognition is needed of their function as nuclear power plants, not research reactors. In this respect, IAEA Safety Standards Series No. SSR-2/1 (Rev. 1), Safety of Nuclear Power Plants: Design [7], may be more relevant. The implementation of the defence in depth concept and principles for most SMRs might not lead to a significant reduction in measures at the various defence levels, although in some cases (e.g. microreactors), it may be possible for designers to demonstrate that there can be a significant reduction in measures at higher levels of defence in depth. There are SMR designers who are working to improve the safety features of their designs to be able to relax some siting constraints, as these reactors would be used for urban heating or, for other reasons, may need to be sited near population centres.

17. Paragraph 3.22 of the Fundamental Safety Principles [5] refers to a graded approach in the assessment of what is reasonably achievable. IAEA Safety Standards Series No. GSR Part 4 (Rev. 1), Safety Assessment for Facilities and Activities [8], also presents the application of a graded approach as its first requirement. In some SMR designs, it may be possible to demonstrate convincingly that the measures needed at defence in depth level 4, whose definition would be based on the fact that the core could melt, would not be applicable. An in-depth analysis would be needed to justify the omission of core melt and the development of a new approach for a more appropriate definition of defence in depth level 4.

18. The justification presented above does not apply to level 5, which is not directly related to the design of the plant, but rather to the protection of society. Uncertainties in the analysis for levels 3 and 4 need to be considered, to provide for the unexpected.

19. For some SMR designs, the source term used as a basis for the emergency preparedness measures could be minor. Measures for level 5 should be based on a plant specific assessment of hazards.

20. Paragraph 50 of INSAG-12, Basic Safety Principles for Nuclear Power Plants [4], discusses the human aspects of defence in depth, including personnel qualification and training, and safety culture. This is important for SMRs used for district heating and other specific purposes, as new organizational solutions and structures may be needed in their construction, operation and ownership. The local district heating companies will not necessarily have the competence in their own organizations. Efficient cooperation and clear division of responsibilities are needed between the organizations taking part in such projects, as part of good safety culture. Paragraph 3.32 of the Fundamental Safety Principles [5] stresses

the need for a strong management commitment to safety and a strong safety culture among the elements providing defence in depth [5]. These are essential in the activities of all the organizations participating in such projects.

21. The independence of all levels of defence in depth for SMRs is a crucial issue of the concept. Implementation of independence and separation of these levels in all SMR designs may present some challenges, but the importance of the issue needs to be recognized.

4.4. GRADED APPROACH

22. The graded approach is based on the assessment of potential hazards associated with the facility and the consequences of systems or component failure in terms of the impact on facility safety, public health and the environment.

23. This approach defines the extent of analysis, documentation and actions necessary to meet regulatory requirements. Risk assessment in accordance with a graded approach considers the following:

- (a) Rated power and intended application of the SMR;
- (b) Siting characteristics (including external hazards);
- (c) Inventory of fissile and fissionable material;
- (d) Fuel characteristics and source term;
- (e) Innovative features of SMRs.

24. The Fundamental Safety Principles present the principle of the graded approach in safety assessment (para. 3.15), stating that “Safety has to be assessed for all facilities and activities, consistent with a graded approach” [5]. The principle of optimization of protection, presented as Principle 5, refers to the graded approach in assessing whether radiation risks are as low as reasonably achievable. In addition, the application of a graded approach for safety assessment is presented in Requirement 1 of GSR Part 4 (Rev. 1) [8], which states:

“A graded approach shall be used in determining the scope and level of detail of the safety assessment carried out at a particular stage for any particular facility or activity, consistent with the magnitude of the possible radiation risks arising from the facility or activity.”

25. This may lead to a simplification of assessments in site evaluation and implementation of the defence in depth concept and its principles. Similarly,

the application of requirements concerning staffing; scope and depth of safety analysis; safety classification of structures, systems and components; use of codes and industry standards; qualification of components; and quality assurance requirements might also be affected.

4.5. PERFORMANCE AND PRESCRIPTIVE BASED REGULATION

26. The wide variety of SMR types and their design characteristics necessitates consideration of mainly performance based regulations. The graded approach would be more difficult to apply if prescriptive requirements were in place, as these do not lend themselves so easily to a grading process.

5. CONCLUSIONS AND RECOMMENDATIONS

27. A large number of SMR designs will need to implement all levels of defence in depth as currently defined to comply with this concept and its principles. However, for some SMRs, the path to the implementation of defence in depth in design is not so evident. In this case, a new approach needs to be developed to adequately define the implementation of all levels of defence in depth. Moreover, the need for a graded approach is established in the Fundamental Safety Principles as part of the process of optimization of protection and safety [5]. The insights from the application of the requirements established in SSR-3 [6] to new research reactors might be applied in grading the application of the defence in depth concept for SMRs in an appropriate way. In this context, due consideration is needed of the difference in the nature and goals of research reactors, as compared with SMRs.

28. All relevant safety requirements have to be complied with in applying a graded approach to defence in depth. The application of this approach needs to be based both on the deterministic model and on all the relevant levels of probabilistic safety analyses, and unless there is clear justification for doing so, any modification of the way in which these requirements are implemented will be unlikely.

29. The starting point in the design of a nuclear power plant, including an SMR, should always be the five levels of defence in depth presented in INSAG-10 [1]. In the implementation of the defence in depth concept to SMRs, especially in the

range of low power SMRs, a graded approach could be used. For this purpose, an in-depth analysis should be performed to define the implementation of the defence in depth concept for the specific SMR design. This includes identifying a definition for, and practical implementation of, the fourth level of defence in depth. In some SMR designs, the term core melting is not valid, and the concept of barriers and containment can be quite different compared with that for existing nuclear power plants. Implementation of the concept of defence in depth for these designs may differ significantly from past practices. There is a lack of practical guidance to assess the implementation of the defence in depth concept to innovative reactor designs and SMRs.

30. The practical implementation of the fifth level of defence in depth should depend on the results of a plant specific hazard assessment. With regard to the fifth level of defence in depth, the lack of an internationally harmonized approach to the determination of emergency planning zones and associated requirements complicates this assessment. Harmonization and internationally agreed practices would be useful in terms of the source term assessment, dose criteria and determination of emergency planning zones, and other emergency preparedness arrangements. This would entail the review of the use of prescriptive approaches, which have been the traditional basis for regulatory appraisals in the past.

31. Efficient cooperation and clear division of responsibilities are essential elements of a strong safety culture in all applications of SMRs, and especially in applications for district heating and other purposes where new organizational solutions may be needed for the construction and operation of these facilities.

32. The need for independence of all levels of defence in depth is also emphasized in the application of the concept for SMRs. It is possible that the compactness of some SMRs may entail the multipurpose use of systems, which might have an impact on independence.

33. INSAG emphasizes that there is a need to be clear that the defence in depth concept and its principles remain valid, but the type, extent and implementation of measures to address all levels of defence in depth may differ considering the large variability of SMR types and in line with the application of the graded approach. Care needs to be taken in the way relevant information is expressed so that designers cannot think they can ‘eliminate’ or ‘not implement’ one or more levels of defence in depth, but rather they can demonstrate that the way to implement the concept meets all relevant safety principles and ensures the safety of design.

34. Analysis related to harm on and off the site has to be performed on a site basis. This is particularly important when multiple SMRs or other nuclear installations are situated on a single site and countermeasures need to be related to potential hazards at the entire site. This case by case approach needs, inter alia, to consider all external events associated with the site that might result in common cause failures.

REFERENCES

- [1] INTERNATIONAL NUCLEAR SAFETY ADVISORY GROUP, Defence in Depth in Nuclear Safety, INSAG Series No. 10, IAEA, Vienna (1996).
- [2] INTERNATIONAL ATOMIC ENERGY AGENCY, The Fukushima Daiichi Accident, IAEA, Vienna (2015).
- [3] INTERNATIONAL ATOMIC ENERGY AGENCY, Advances in Small Modular Reactor Technology Developments: 2022 Edition, A Supplement to: IAEA Advanced Reactors Information System (ARIS), IAEA, Vienna (2022).
- [4] INTERNATIONAL NUCLEAR SAFETY ADVISORY GROUP, Basic Safety Principles for Nuclear Power Plants: 75-INSAG-3 Rev. 1, INSAG Series No. 12, IAEA, Vienna (1999).
- [5] EUROPEAN ATOMIC ENERGY COMMUNITY, FOOD AND AGRICULTURE ORGANIZATION OF THE UNITED NATIONS, INTERNATIONAL ATOMIC ENERGY AGENCY, INTERNATIONAL LABOUR ORGANIZATION, INTERNATIONAL MARITIME ORGANIZATION, OECD NUCLEAR ENERGY AGENCY, PAN AMERICAN HEALTH ORGANIZATION, UNITED NATIONS ENVIRONMENT PROGRAMME, WORLD HEALTH ORGANIZATION, Fundamental Safety Principles, IAEA Safety Standards Series No. SF-1, IAEA, Vienna (2006),
<https://doi.org/10.61092/iaea.hmxn-vw0a>
- [6] INTERNATIONAL ATOMIC ENERGY AGENCY, Safety of Research Reactors, IAEA Safety Standards Series No. SSR-3, IAEA, Vienna (2016).
- [7] INTERNATIONAL ATOMIC ENERGY AGENCY, Safety of Nuclear Power Plants: Design, SSR-2/1 (Rev.1), IAEA, Vienna (2016).
- [8] INTERNATIONAL ATOMIC ENERGY AGENCY, Safety Assessment for Facilities and Activities, IAEA Safety Standards Series No. GSR Part 4 (Rev. 1), IAEA, Vienna (2016).

MEMBERS OF THE INTERNATIONAL NUCLEAR SAFETY ADVISORY GROUP

Blommaert, W.C.

Niel, J.C.

Burns, S.G. (Chair)

Parvez, A.

El Shanawany, M.

Reiman, L.

Ferapontov, A.

Rouyer, V.

Fuketa, T.

Shen, Y.

Giménez, M.O.

Stoll, U.

Gürpınar, A.

Tyobeka, B.

Jae, M.

Velshi, R.

James, A.

Weightman, M.

Manohar, S.

PUBLICATIONS OF THE INTERNATIONAL NUCLEAR SAFETY ADVISORY GROUP

75-INSAG-1	Summary Report on the Post-accident Review Meeting on the Chernobyl Accident	1986
75-INSAG-2	Radionuclide Source Terms from Severe Accidents to Nuclear Power Plants with Light Water Reactors	1987
75-INSAG-3	Basic safety Principles for Nuclear Power Plants	1988
75-INSAG-4	Safety Culture	1991
75-INSAG-5	The Safety of Nuclear Power	1992
75-INSAG-6	Probabilistic Safety Assessment	1992
75-INSAG-7	The Chernobyl Accident: Updating of INSAG-1	1993
INSAG-8	A Common Basis for Judging the Safety of Nuclear Power Plants Built to Earlier Standards	1995
INSAG-9	Potential Exposure in Nuclear Safety	1995
INSAG-10	Defence in Depth in Nuclear Safety	1996
INSAG-11	The Safe Management of Sources of Radiation: Principles and Strategies	1999
INSAG-12	Basic Safety Principles for Nuclear Power Plants 75-INSAG-3 Rev. 1	1999
INSAG-13	Management of Operational Safety in Nuclear Power Plants	1999
INSAG-14	Safe Management of the Operating Lifetimes of Nuclear Power Plants	1999

INSAG-15	Key Practical Issues in Strengthening Safety Culture	2002
INSAG-16	Maintaining Knowledge, Training and Infrastructure for Research and Development in Nuclear Safety	2003
INSAG-17	Independence in Regulatory Decision Making	2003
INSAG-18	Managing Change in the Nuclear industry: The Effects on Safety	2003
INSAG-19	Maintaining the Design Integrity of Nuclear Installations Throughout Their Operating Life	2003
INSAG-20	Stakeholder Involvement in Nuclear Issues	2006
INSAG-21	Strengthening the Global Nuclear Safety Regime	2006
INSAG-22	Nuclear Safety Infrastructure for a National Nuclear Power Programme Supported by the IAEA Fundamental Safety Principles	2008
INSAG-23	Improving the International System for Operating Experience Feedback	2008
INSAG-24	The Interface Between Safety and Security at Nuclear Power Plants	2010
INSAG-25	A Framework for an Integrated Risk Informed Decision Making Process	2011
INSAG-26	Licensing the First Nuclear Power Plant	2012
INSAG-27	Ensuring Robust National Nuclear Safety Systems — Institutional Strength in Depth	2017
AdSec/ INSAG-1	A Systems View of Nuclear Security and Nuclear Safety: Identifying Interfaces and Building Synergies	2023



IAEA

International Atomic Energy Agency

No. 27

ORDERING LOCALLY

IAEA priced publications may be purchased from our lead distributor or from major local booksellers.

Orders for unpriced publications should be made directly to the IAEA.

Orders for priced publications

Please contact your preferred local supplier, or our lead distributor:

Eurospan

1 Bedford Row
London WC1R 4BU
United Kingdom

Trade orders and enquiries:

Tel: +44 (0)1235 465576
Email: trade.orders@marston.co.uk

Individual orders:

Tel: +44 (0)1235 465577
Email: direct.orders@marston.co.uk
www.eurospanbookstore.com/iaea

For further information:

Tel. +44 (0) 207 240 0856
Email: info@eurospan.co.uk
www.eurospan.co.uk

Orders for both priced and unpriced publications may be addressed directly to

Publishing Section
International Atomic Energy Agency
Vienna International Centre
PO Box 100
1400 Vienna, Austria
Telephone: +43 1 2600 22529 or 22530
Email: sales.publications@iaea.org
www.iaea.org/publications

