



Plant Life Management experience at Tarapur Atomic Power Station (INDIA)

By
VINAY THATTEY,
Senior Engineer, TAPS-1,2




NPCIL Profile

- NPCIL is responsible for Design, Construction, Commissioning, Operation, Maintenance, Life management, and De-commissioning of Indian NPPs.
- 17 reactors in operation. Installed Capacity 4120 Mwe (3% share of energy)
- Oldest : TAPS-1,2 (Oct 1969)
- Latest : KAIGA-3 (May 2007)
- 6 reactors under construction (PHWR, LWR, FBR) Total 3380 Mwe




Optimum construction periods




Salient Features OF TAPS 1 & 2

- IGE turnkey project
- Construction started: MAY 1964
- Commercial operation: NOV 1969
- 38TH Year of operation.
- Rating : SINGLE CYCLE – 160 MW_e
DUAL CYCLE – 210 MW_e
- Energy produced > 70 BU
- Present tariff: 93 paise /unit (< 2 cents)




Review of Life Management aspects for continued operation of TAPS

- Periodic Safety Review of TAPS initiated in 2000 as part of License Extension. This included:
 - Probabilistic Safety Assessment. (Level-1)
 - Review of Operational Performance.
 - Review of Ageing Management and residual life of SSCs.
 - Review of Design Basis of plant systems and Safety analysis, vis-à-vis the current requirements.
 - Seismic Re-evaluation.




Review Requirement & Objectives

- Review required because of:
 - Changes in applicable design codes
 - Availability of better analytical tools
 - Better understanding of degradation mechanisms
 - Comparing with current standards
- Objectives of review:
 - To identify and prioritize safety issues
 - To identify and implement corrective measures where necessary




Review of Life Management aspects for continued operation of TAPS

- **Review Of Life Management**
 - Present status of the SSCs
 - Identified modes of degradation
 - Monitoring methods
- **Assessment of available margins taking account of**
 - Results of revised Safety Analysis
 - Comparison of the current Codal with the earlier requirements followed for TAPS units
 - Various upgradations




Review Of Ageing

- Identification of key systems, structures and components(SSCs).
- Classified as
 - Major critical components
 - Important systems
 - Other critical components.
- Components further classified as
 - Not replaceable
 - Replaceable with re-engineering
 - Replaceable on routine basis.
- For each component mode of degradation identified, ageing assessment done and action plan indicated.




PLIM in TAPS-1,2

- Information pertaining to the sscs is systematically documented and analysed
 - Present status of health
 - Known degradation mechanisms
 - Adequacy of present monitoring methods and practices
- Action plans evolved
 - For ageing studies
 - Residual life assessment
 - Need for development activities for inspection / health assessment of presently un-inspectable areas
 - Equipment replacement.




PLIM Objective

- Improvement of safety performance of TAPS-1,2
- Maximising operating life without compromising safety
- Harmonizing various good practices
- Address various aspects to be considered during different stages of plant, starting from the conceptual design as well as the organizational aspects.
 - Reference Documents:
 - AERB safety guide on Life Management of NPPs.AERB/NPP-SG-O-14




Selection of SSC





- Screening & Categorising of SSC (Replaceable/Non-replaceable)
- Prioritization of Safety Issues
- Condition Monitoring & ISI
- Measures to Mitigate Ageing
- License Renewal

Safety Goal: " 'Plant reference safety level is expected to be maintained during extended period of operation as per the original design' "




Safety State Of Components And Safety Margin As Function Of Time





Components of PLIM


- Maintenance Programme
- Surveillance Programme
- In-service Inspection Programme
- Performance Review Programme
- Programme related to life management



PLIM Study Findings


- Condition of RPV & internals is satisfactory .
- Fast neutron fluence at the end of 40 EFPY will be less than threshold value for causing IASCC. RPVs have operated for around 21 EFPY.
- Generic issue of IGSCC with SS 304 piping has been addressed
- Condition of containment is satisfactory.
- Important systems are in good condition.
- AMP for power & control cables based on RLA findings.
- Replacement of equipments done based on condition monitoring:

SSW pumps, CRD pumps, EC tubes , FW heaters, C/U heat exchangers, Station batteries, etc



Continuous Upgradation (Based On Operating Experience.)

- Augmentation of battery banks.
- Additional start-up transformer
- Station Black Out DG
- Augmentation of compressed air system.
- Augmentation of Reactor clean-up system.
- Augmentation of condensate demin. system
- Thermal insulation upgradation
- Augmentation of Spent Fuel Storage Facility.



Upgradations done for Life Extension


- Retrofitting 3 x 100% capacity EDGs in Seismically qualified Bldg.
- Segregation of Electrical Distribution system
- Additional CRD pump for augmenting Emergency Feed



- Segregation of Reactor Shutdown Cooling system
- Provision of Supplementary Control Room
- Segregation of Fuel Pool Cooling system
- Seismic upgrades


16 October 2007, 16.00 hrs.

License to Operate extended till 2011



Conclusion

- Plant Life Management is a necessity on account of safety as well as economy.
- With an effective PLIM programme in place, life of NPPs can be maximized while maintaining acceptable level of safety.
- The scope of Life Management will increase as NPPs grow old and the safety standards evolve.
- The endeavor at NPCIL is to ensure that the safety standards of all NPPs remain at an acceptable level, through effective ageing management.



Thank You All!