



# Material Degradation Management of the Point Lepreau Reactor Coolant System


*by John Slade & Tracy Gendron*

*Serious RCS  
Degradation  
→ Early  
Refurbishment,  
2008*

**Recirculating SGs**  
(alloy 800 tubing)


**Carbon steel  
feeder piping**

**380 Zr alloy fuel channels**



# *Feeder Degradation → Development of Aggressive AMP, 2003*

- ❑ 18 bends replaced
  - ❑ 2 forced outages
  - ❑ Extended 2 planned outages
  - ❑ Replacement energy ~50M\$
  - ❑ 3% annual O&M budget
  - ❑ Increased radiation exposure
    - ~30% of total outage exposure
    - Key inspectors reach annual limit
  - ❑ Increased stakeholder concern about rupture
- 



## *Successful Feeder AMP...*

- ☐ Reduced unplanned maintenance
- ☐ Incapability factor dropped from 5% to 1%
- ☐ Fewer emerging issues, allows focus on improvement initiatives
- ☐ Improved stakeholder confidence

—→ *Similar approach for whole RCS*

# ***AMP Approach***

**Based on review of industry best practices**

- ❑ Follows general principles common to many industry guidance documents**
  - Use existing station processes based on INPO AP-913**
  - Satisfy intent of NEI 03-08**
- ❑ The key to success was a focus on implementation - *making plans easy to use***

# *Presentation Purpose*

**Share the most useful and practical features of the Point Lepreau RCS AMP**

- consider the end-user early in the development of AMPs*

# *Acknowledgements*

## **Practical experience implementing aging management activities:**

**Southern Nuclear, South Texas Project, Florida Power & Light, Beznau NPP, Biblis NPP, Palo Verde NPP, Ontario Power Generation, Gentilly-2 GS, Bruce Power, Babcock & Wilcox Canada, Dominion Engineering Inc., CNSC, EPRI, Point Lepreau GS, AECL.**



# *Key Features of the AMP*

- 1. Improved Integration of Management Activities**
- 2. Improved Implementation of Technical Information**
- 3. Application of Risk-Based Decision Making**

***Focus on implementation – easy to use***



# ***1. Integration of Management Activities – the need:***

- ☐ **Manage system-level degradation**  
*(radiation fields, thermal performance...)*
- ☐ **Manage requirements of system-operating activities** *(chemistry control, warm-up procedures...)*
- ☐ **Formal interfaces, clear responsibilities**

# ***1. Integration of Management Activities***

**Using an RCS system-level plan**

- ☐ modelled after industry-defined mandatory requirement of NEI 03-08, *Guidelines for the Management of Materials Issues***

# ***RCS Aging Management Plan***

*using NEI 03-08 Guidelines*

## ***Major Component Plans***

**Feeder  
Piping**

**Fuel  
Channels**

**Steam  
Generators**

## ***Multi-System Programs***

**Periodic  
Inspection**

**Fatigue**

**Chemistry  
Control**

**NDE, FAC,  
Vessels, Welds,  
Supports, etc.**

## ***2. Improved Implementation of Technical Information - the need:***

- ❑ AMPs not always used**
  - Too lengthy
  - Include superfluous information
  - Practical information not included
- ❑ Key R&D results not always used in AMPs**
  - Not communicated in a practical way

## ***Consistent, Easy-to-Use Plan Format***

- ❑ Follows existing station processes, based on INPO AP-913**
- ❑ < 40 pages**
- ❑ Information in easy look-up tables**
- ❑ Contains practical information, e.g.**
  - *Mandatory maintenance & regulatory commitments***
  - *Clear acceptance criteria***
  - *Maintenance activity scope, schedule***
  - *Response plans***

# *Link between Degradation and Management Activity – from Feeder AMP*

| Degrad-<br>ation<br>Mechanism    | Primary Strategy to Manage Degradation                                                       |                      |                                                                                     |
|----------------------------------|----------------------------------------------------------------------------------------------|----------------------|-------------------------------------------------------------------------------------|
|                                  | Affected<br>Components                                                                       | Management<br>Option | Management<br>Activities                                                            |
| Flow<br>Accelerated<br>Corrosion | All outlet<br>locations,<br>especially tight<br>radius bends<br>& adjacent to<br>Grayloc Hub | Inspection           | Wall thickness<br>measurements                                                      |
|                                  |                                                                                              | Repair               | Replace components<br>projected to thin<br>below minimum<br>acceptable thickness    |
|                                  |                                                                                              | Chemistry<br>Control | Control pHa to lower<br>end of specification<br>(10.2-10.4) to<br>minimize FAC rate |

# Key Factors Affecting Feeder Cracking

| Primary Factors                                                                                                                 | Secondary Factors                                                                                                                                   |
|---------------------------------------------------------------------------------------------------------------------------------|-----------------------------------------------------------------------------------------------------------------------------------------------------|
| <b>Stress</b>                                                                                                                   |                                                                                                                                                     |
| <b>Residual Stress:</b> Based on physical evidence from spare bends and cracked feeders.                                        | <b>Operating Stress:</b> postulated to increase susceptibility. No physical evidence.                                                               |
| <b>Material</b>                                                                                                                 |                                                                                                                                                     |
| <b>Cold Work/Hardness:</b> associated with observed cracks.                                                                     | <b>Ovality and Impurities:</b> Postulated, based on operating experience and literature.                                                            |
| <b>Environmental</b>                                                                                                            |                                                                                                                                                     |
| <b>Temperature:</b> Cracks only in outlet feeders where temp is 40°C higher than in inlets. Consistent with proposed mechanism. | <b>FAC-generated hydrogen:</b> Consistent with all crack locations<br><b>Oxidizing Species and Impurities:</b> Based on literature and test results |

# *Response Plan to Feeder Crack Inspection Findings*

| Cracked Feeders in 2007                                | Max. Crack Length | Condition Assessment Valid | Impact on Inspection and Maintenance Strategy                                                                                                                           |
|--------------------------------------------------------|-------------------|----------------------------|-------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| <u>Reportable Cracks in Outlet Tight Radius Bends:</u> |                   |                            |                                                                                                                                                                         |
| 0-6                                                    | ~25mm             | Yes                        | No supplementary activities or changes to the plan required.                                                                                                            |
| >0                                                     | >30mm             | Review required            | Characterize indications after feeders are removed. Depending on the severity of cracking, re-assess the validity of the condition assessment prior to reactor restart. |
| <u>Reportable Cracks in Inlet Bends:</u>               |                   |                            |                                                                                                                                                                         |
| >0                                                     | N/A               | No                         | Expand scope to all inlet 1st & 2nd bends; perform operational assessment prior to reactor restart.                                                                     |

### ***3. Application of Risk-Based Decision Making - the need***

- means to allocate resources for maximum benefit**
  - for activities in a single plan**
  - to allocate resources between plans**

### ***Concept of risk-reduction***

## ***Concept of Risk Reduction considers:***

- ☐ **Reduction in risk of degradation by the management activity**
- ☐ **Consequential costs of the management activity (\$cost, worker hazards, risk of additional damage...)**
- ☐ **Likelihood that the activity will be successful**


# ***Evaluating **risk reduction** provided by management activities***

## **☐ Risk Management Index**

***- qualitative comparison***


## **☐ Calculated Change in Severe Core Damage Frequency, PSE**

***- quantitative comparison***



## ***Risk Management Index***

## *Quantitative Comparison of Risk*



### ***3. Concluding Remarks***

**Tangible benefits of program  
since 2003:**

- ☐ **less unplanned maintenance**
- ☐ **fewer emerging issues**
- ☐ **improved stakeholder confidence**

### ***3. Concluding Remarks***

**Success attributed to:**

- ☐ considering the challenges that station engineers face in using these plans, early in their development**